

**U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA)
 CERTIFICATION OF CONFORMITY
 PURSUANT TO 40 CFR PART 60 SUBPARTS AAA AND QQQQ
 2015 STANDARDS OF PERFORMANCE FOR NEW RESIDENTIAL WOOD HEATERS, NEW
 RESIDENTIAL HYDRONIC HEATERS AND FORCED-AIR FURNACES**

Disclaimer: The statutory provisions and the EPA regulations described in this document contain legally binding requirements. This document is not a substitute for those provisions or regulations, nor is it a regulation itself. In the event of a discrepancy, please refer to 40 CFR PART 60 Subparts AAA AND QQQQ, Sections 60.533(b) and 60.5475(b). This document may be revised periodically without public notice. If you have additional questions, please contact Rafael Sanchez at 202-564-7028 or via email at sanchez.rafael@epa.gov.

GENERAL INFORMATION

Manufacturer's Name:

MF Fire, Inc.

Heater Type (Circle One):	Adjustable Burn Rate Wood Heater	Pellet Stove	Single Burn Rate Heater		Hydronic Heater	Forced Air Furnace	Other:
Hydronic Heater Type (Circle ALL that apply):	Full Storage	Partial Storage	Indoor	Outdoor	Other:		
Forced-Air Furnace Type (Circle One):	Small (less than 65,000 BTU/hr heat output)		Large (greater than 65,000 BTU/hr heat output)			Other:	
Fuel Tested:	Crib	Pellet	Cordwood	Wood Chips		Other:	

Model Name(s) (as it appears on test report):

NOVA

Model Number(s) (as it appears on test report):

Same As Model Not Above

Catalyst: Yes No

Mailing Address:

1400 Greenmount Ave. Suite B04

Street Address:

1400 Greenmount Ave. Suite B04

City: Baltimore	State: MD	ZIP Code: 21202
Phone: 1-855-MFFIRE-1	Fax: Not Available	Web Site: www.mffire.com

Address of Manufacturer:
1400 Greenmount Ave. Suite B04

City: Baltimore	State: MD	ZIP Code: 21202
---------------------------	---------------------	---------------------------

EPA APPROVED THIRD PARTY CERTIFIER

Authorized Representative(s):

Robert J. Zimmerman Jr.

Company:

UL LLC

Phone: 847-664-3129	E-mail: Robert.J.Zimmermanjr@ul.com	Fax: 847-272-8129
City: Northbrook	State: IL	ZIP Code: 60062

Position:
Senior Staff Engineering Associate

**U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA)
 CERTIFICATION OF CONFORMITY
 PURSUANT TO 40 CFR PART 60 SUBPARTS AAA AND QQQQ
 2015 STANDARDS OF PERFORMANCE FOR NEW RESIDENTIAL WOOD HEATERS, NEW
 RESIDENTIAL HYDRONIC HEATERS AND FORCED-AIR FURNACES**

Disclaimer: The statutory provisions and the EPA regulations described in this document contain legally binding requirements. This document is not a substitute for those provisions or regulations, nor is it a regulation itself. In the event of a discrepancy, please refer to 40 CFR PART 60 Subparts AAA AND QQQQ, Sections 60.533(b) and 60.5475(b). This document may be revised periodically without public notice. If you have additional questions, please contact Rafael Sanchez at 202-564-7028 or via email at sanchez.rafael@epa.gov.

Report Number: 1801V2	Date(s) of Tests: March 5, 2018 thru March 12, 2018	Date of Report: April 10, 2018
Quality Assurance Plan included?: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Wood Heater/Hydronic Heater/Forced-Air Furnace Application Included: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Remarks:

Affected Source Data Summary

This affected source has been tested to (select one):
 2015 NSPS particulate matter emissions limit of 4.5 g/hr
 2020 NSPS particulate matter emissions limit of 2.0 g/hr (2.5 g/hr if cordwood)

Wood Burning Heater	Hydronic Heater	Forced-Air Furnace
Weighted particulate emission average of <u>3</u> test runs: <u>1.93</u> grams per hour	Maximum Output Rating: _____ Weighted particulate emission average: _____ Lbs/MMbtu output	Particulate emission average: _____ Lbs/MMbtu output
Weighted average HHV efficiency of <u>3</u> test runs: <u>70.6</u> %	Annual Efficiency Rating: _____	Overall thermal efficiency (HHV): _____ %
	Particulate Emissions: _____	Overall Delivered Heat Efficiency: _____ %

AFFIRMATIONS

- The above-named affected source has been tested by a laboratory qualified to test and report on the emissions of this type of product under 40 CFR Part 60, Standards of Performance for New Residential Wood Heaters, New Residential Hydronic Heaters and Forced-Air Furnaces (2015 Standards).
- The Test Report No. 1801V2, prepared by Kelli O'Brien and dated April 10, 2018, has been reviewed by Robert J. Zimmerman Jr. and was found to be complete and to have used the correct procedures in accordance to the 2015 Standards.
- The emissions levels listed in the test report and listed above comply with the relevant particulate matter limits established by the 2015 Standards.
- The model listed above was tested using the following Test method(s): 28R, ASTM E2515, and CSA B415.1-10.
- The permanent label and owner's manual meet the requirements of 40 CFR § 60.536 and/or § 60.5478.
- The above-named manufacturer, on the effective date of this certificate, was operating under a quality assurance plan, per 40 CFR § 60.533(m) and/or § 60.5475(m), that has been reviewed and approved by Robert J. Zimmerman Jr.
- The above-named manufacturer has contracted UL LLC to conduct regular (at least annual) unannounced audits of the manufacturing facility, affected source, and quality assurance plan pursuant to 40 CFR § 60.533(m) and/or § 60.5475(m).

**U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA)
 CERTIFICATION OF CONFORMITY
 PURSUANT TO 40 CFR PART 60 SUBPARTS AAA AND QQQQ
 2015 STANDARDS OF PERFORMANCE FOR NEW RESIDENTIAL WOOD HEATERS, NEW
 RESIDENTIAL HYDRONIC HEATERS AND FORCED-AIR FURNACES**

Disclaimer: The statutory provisions and the EPA regulations described in this document contain legally binding requirements. This document is not a substitute for those provisions or regulations, nor is it a regulation itself. In the event of a discrepancy, please refer to 40 CFR PART 60 Subparts AAA AND QQQQ, Sections 60.533(b) and 60.5475(b). This document may be revised periodically without public notice. If you have additional questions, please contact Rafael Sanchez at 202-564-7028 or via email at sanchez.rafael@epa.gov.

Robert J. Zimmerman Jr. – Senior Staff Engineering Associate
Print Name and Title

Robert J. Zimmerman Jr.
Signature of Authorized Third-Party Representative

April 24, 2018
Date

This is a certification of conformity to certify that the bearer has successfully completed the requirements pursuant to the 2015 Standards.

Third-party EPA approval expiration date: 2020-11-12

V1 5.19.16

Remarks:

NOVA

Free Standing Single Burn Rate Wood Stove

Prepared for:

MF Fire

Baltimore, Maryland

Prepared by:

ClearStak, LLC

Putnam, CT

Kelli O'Brien

Project Manager

CSL-00010

Report 1801V2

April 10, 2018



99 Canal Street
Putnam, CT 06260
860-237-8245


NON-CBI

1 Affidavit

MF Fire contracted ClearStak, LLC to perform emissions and efficiency testing of the single burn rate stove, Nova, in accordance with U.S. EPA's 40 CFR 60 subpart AAA, of *Standards of Performance for New Residential Wood Heaters, New Residential Hydronic Heaters and Forced Air Furnaces* (NSPS). The average PM emissions for two test runs was 1.93 g/hr., which falls below the NSPS Step 2 PM emission limit of 2.0 g/hr. An average results summary can be found in Table 1. All test results apply solely to the wood stove, Nova. This test report shall not be reproduced, except in full, without the written approval of MF Fire and ClearStak, LLC.

Table 1. Summary Results

Average Results Summary			
Burn Duration	Energy Output	PM	Efficiency (HHV)
hrs.	Btu/hr	g/hr.	%
2.48	22,592	1.93	70.6



Kelli O'Brien
Lab Manager

2 Table of Contents

Contents

1	Affidavit.....	ii
2	Table of Contents	iii
3	List of Figures	iv
4	List of Tables.....	v
5	Acronyms and Abbreviations	vi
1	Introduction	1
2	Appliance Identification.....	2
3	Test Arrangements and Set-Up	5
4	Operation Procedure	10
5	Results and Data Summary.....	12
6	Quality Control and Assurance Procedures and Results.....	15
7	Statement of Uncertainty	16
8	References	17
9	Appendices.....	18

3 List of Figures

Figure 1. Primary and Secondary Air	2
Figure 2. Stove Profile	4
Figure 3. Stove installed on scale installed on test stand	7
Figure 4. PM sampling locations	8
Figure 5. Firebox volume	9
Figure 6. Test fuel crib example	9

4 List of Tables

Table 1. Summary Results.....	ii
Table 2. Identifies the appliance to be tested.....	2
Table 3. Key Instrumentation List	5
Table 4. Emissions Summary A	12
Table 5. Emissions Summary B.....	12
Table 6. Testing Laboratory Conditions	12
Table 7. Sampling Conditions	13
Table 8. Average Surface Temperature	13
Table 9 Average Catalyst Temperatures	13

5 Acronyms and Abbreviations

Appliance	Customer system
ASTM	American Society for Testing and Materials
Btu	British thermal unit
CO	Carbon Monoxide
CSA	Canadian Standards Association
EPA	Environmental Protection Agency
g/hr	grams, grams per hour
HHV	Higher heating value
MC	Moisture content
NSPS	Standards of Performance for New Residential Wood Heaters New Residential Hydronic Heaters and Forced-Air Furnaces, 2015.
PM	Particulate matter
ppm	Parts per million
SLM	Stack loss method
U.S.	United States

1 Introduction

1.1 Purpose

MF Fire contracted with ClearStak, LLC to perform U.S. EPA certification testing on the wood stove, Nova, a single burn rate wood stove, per subpart AAA of 40 CFR 60 for wood stoves of the revised *Standards of Performance for New Residential Wood Heaters, New Residential Hydronic Heaters and Forced-Air Furnaces* (NSPS).

1.2 The Assignment

The assignment was to measure particulate matter (PM) and efficiency at a single burn rate of the free-standing Nova wood stove. PM emissions are measured in a dilution tunnel and determined using ASTM E2515-11. The stove was operated according to Method 28R, which incorporates ASTM E2780, and was fired according to the customer's written instructions. Efficiency was determined using CSA B415.1-10.

1.3 Test Environment

ClearStak's emissions and efficiency testing laboratory is located at 99 Canal Street in Putnam, CT 06260, 236 ft. above sea level. Gravimetric analysis is performed at ClearStak's laboratory located at 479 Tolland Turnpike, Willington 06279, 689 ft. above sea level.

2 Appliance Identification

The Nova stove is a free standing single burn rate wood burning stove that uses natural draft for air flow and a catalyst for emission reduction. Primary air is vented from the back of the stove through two 2.50 in. x 0.50 in. rectangular openings. Primary air is then transferred through a U-shape square tube where it is heated and then forced downward into the firebox by the door. Secondary air is drawn from the back of the stove through a 5-7/8 in. x 0.50 in. rectangular opening and four 0.50 in. diameter holes. Secondary air is forced downward into the firebox through an array of exit holes, 0.25 in. in diameter. The primary and secondary air openings from the back of the stove is depicted in Figure 1. Air flow schematic can be found in appliance drawings in Appendix A.




Figure 1. Primary and Secondary Air

Nova was delivered to the ClearStak emissions testing facility by MF Fire representatives, Taylor Myers and Ryan Fisher on February 6th, 2018. See Table 2 for appliance identification and Figure 2 for stove images.

Table 2. Identifies the appliance to be tested.

Appliance Identification	
Appliance	Free standing single burn rate wood stove
Manufacturer	MF Fire, 1400 Greenmount Ave., Suite B04, Baltimore, MD 21202
Customer Contact	Taylor Myers, Taylor@MFFire.com
Model	Nova

Automated Control System	No, manual ignition
Serial Number	Model #002
Date of Appliance Arrival	February 6 th , 2018
ClearStak Test Identification	CSL-00010
Condition	New, prototype
Aging Date	February 6 th – February 28 th , 2018, minimum 50 hours for catalyst
Testing Period	Three tests performed between March 5 th – March 12 th 2018
Catalyst	Yes, rectangular catalyst, H = 2.5 in., D = 2.0 in., W = 13 in.
Heat Exchanger Blower	No
Firebox volume	Usable firebox volume 1.63 ft ³
Outer Dimensions	H = 24 in., W = 24 - 3/8 in., D = 21 - 7/8 in.
Overall Weight	303.20 lbs.




Figure 2. Stove Profile

2.1 Informative Material to be Supplied

Written instructions from the customer was supplied and attached to this report in the Appendices. See Appendix A for the customer written instructions and appliance drawings.

3 Test Arrangements and Set-Up

The appliance was assembled by MF Fire representatives, Taylor Myers and Ryan Fisher on February 6th, 2018 in the ClearStak lab. The stove was operated by ClearStak test technicians according to procedures described in the customer's written instructions and required test methods, Method 28R and CSA B415.1-10.

The appliance was placed in the center of a floor scale and positioned under the hood of the dilution tunnel as per ASTM E2515. A 6 in. diameter single wall black steel pipe was mounted to the flue exit of the stove and extended upward 8 ft. into an 8 in. diameter double wall insulated Class A floating chimney pipe for a total height of 15 ft. above the upper surface of the floor scale.

The dilution tunnel has a 12 in. diameter horizontal mixing section and a vertical 8 in. diameter sampling section. The flow rate in the dilution tunnel was maintained at a constant flow rate throughout the test cycle by using an inducer fan at a fixed frequency of 16 Hz. Samples of the dilution tunnel flow stream were extracted from the center of the 8 in. diameter section of the dilution tunnel using a dry gas meter at a constant flow rate and drawn through two 47 mm. glass fiber filters.

K-type and J-type thermocouples were positioned per Method 28R, CSA B415.1-10, and ASTM E2515 for measuring surface temperatures, gas temperatures, and room temperature. Thermocouples measuring surface temperature were placed in sheaths welded centrally on five surfaces of the stove.

3.1 Instrumentation

The following is a list of key instrumentation used for testing, Table 3. Some of these instruments and their locations are labeled in Figure 3 and Figure 4. Calibration records on instrumentation used can be found in Appendix B, submitted electronically.

Table 3. Key Instrumentation List

Part	Manufacturer	P/N	ED #
Ambient Sampler	Gallus	2000	AS-1
Analytical Balance	Ohaus	AR2140	AB-1
Anemometer	Dwyer Instruments	24A466	AN-1
Balance Calibration Weights	Troemner	100 g – 2 mg Class 1	BCW-1
Barometer 1	Cole Parmer	EW-99760-50	BR-1
Data logger	Environmental Systems Corporation	8832	DL-1
Display (unit)	Sartorius	MIS2UR-V2	DU-2
Front Half Filter Holder	Tefzel	410-21-47	FF-01,03,04,05,07,08,12,14,17,18,20,21,

Gas Analyzer 1	Thermo-Scientific	60i	GA-1
Gas Analyzer 2	SIEMENS	Ultramat 23	GA-2
Humidity Gauge 2	Control Company	4096	HG-4
Inclined Manometer	Dwyer	115	MN-1
Isokinetic Stack Sampler 1	Graseby Nutech (Thermo Scientific)	2010A	SS-1
Isokinetic Stack Sampler 2	Graseby-Anderson (Thermo Scientific)	2010A	SS-2
J Type Thermocouple	Omega	TT-J-24-SLE-50	A23-1
K Type Thermocouple	Omega	KQIN-18U	A07-1, A24-1, A25-1, A26-1, A27 -1, A28-1, A29-1, A32-1, A33-1, A34-1, A35-1, A36-1
Pitot Tube 1	Dwyer Instruments	160F	PT-1
Scale	Sartorius	CAPP1U-1000HH-LU	SWT-1
Scale Calibration Weight Unit	Troemner	2 Kg Class F	SWU-1
Stopwatch	Fisher Scientific	14-649-50	SW-8,9
Tape Measure	Starrett	KTX12-12-N	TM-3
Tunnel Blower	Cincinnati Fan	WAF/HTF - 12	TB-1
Wood Moisture Meter 2	Delmhorst	J-2000	WMM-2



Figure 3. Stove installed on scale installed on test stand



Figure 4. PM sampling locations

3.2 Test Fuel

The test fuel used was a Douglas Fir dimensional lumber, grade 2 or better, at an average of 19-25 % moisture content. The crib(s) comprised of three 2" x 4" and two 4" x 4" pieces. The fuel loading density for a wood stove is 7.0 lbs./ft³ +/- 0.7 lbs./ft³. The weight of a full test crib was determined to be 11.44 lbs. +/- 1.141 lbs. based on a firebox volume of 1.63 ft³, as shown in the sketch provided in Figure 5. The test fuel charge piece lengths were all 14.50 in., which closely approximates 5/6th the dimensions of the firebox length and were arranged in parallel to the longest firebox dimension. Figure 6 demonstrates an example of the test fuel crib used for testing. Refer to Appendix C for detailed fuel analysis per test run.




Figure 5. Firebox volume



Figure 6. Test fuel crib example

4 Operation Procedure

Testing procedures follow the test methods: Method 28R, ASTM E2780, CSA B-415.1-10, ASTM E2515-11 and methods referenced within.

All test preparation and measurements were conducted by personnel of the laboratory responsible for the submission of the test report.

4.1 Onsite Personnel and Roles

Kelli O'Brien: Lab Manager, Test Technician

Brian Vinal: Test Technician

4.2 Observers

There were no representatives of MF Fire physically present during certification testing, however, the customer was able to view temperature and gas data live through mobile/web Kelvin application.

4.3 Sampling

Two dual filter dry sampling train systems were used in collecting particulate samples from the dilution tunnel. Two sampling trains collected particulate from an 8 in. diameter dilution tunnel and one sampling train collected particulate from ambient air. All particulate sampling conditions were in compliance with ASTM E2515-11 and collected every 10 minutes. At the end of each test run, filters were removed from their housings; filters were desiccated for 24 hours, and then weighed to a constant weight per ASTM E2515-11 section 10. Front half probe assemblies were rinsed with acetone, with help of a Teflon brush, and dried down in clean beakers and weighed to a constant weight per ASTM E2515 and EPA Method 5. Other sampling and analytical procedures used followed EPA Methods 1,2,3,4,5, and 28 and CSA B-415.1-10.

4.4 Flue Gas Analysis

Flue gas temperature was measured using k-type thermocouples in the stack of the appliance and in the dilution tunnel per ASTM E2515. CO, CO₂, and O₂ concentrations were measured in the stack of the appliance per CSA B415.1-10. Gaseous emission concentrations were collected and stored as 1-minute averages.

4.5 Temperature Measurements

Surface and catalyst temperatures were measured using calibrated k-type thermocouples and installed according to Method 28R. Surface k-type thermocouples were positioned in welded metal sleeves on the central surfaces of the wood stove's sides, bottom, top and back faces. Temperature measurements were collected and stored as 1-minute averages.

5 Results and Data Summary

The stove's emissions from two of three test runs conforms to 2020 NSPS, Step 2, with an average PM emission rate of 1.93 g/hr. See Appendix C for all test run data per run.

Table 4. Emissions Summary A

Run #	Date	Test Duration	Wood Weight	Wood Moisture	Heat Output (CSA)	Total PM Emissions	Startup PM Emissions	PM Rate	PM Factor (CSA)	Overall Efficiency HHV
		hrs.	lb.	%	Btu/hr	g	g	g/hr.	g/kg	%
1	3/5/18	2.63	11.72	22.53	19,959	5.19	5.08	1.97	1.26	67.9
3	3/12/18	2.32	11.88	21.22	25,224	4.39	4.11	1.89	1.04	73.2
Average		2.48	11.8	21.88	22,592	4.79	4.60	1.93	1.15	70.6

Table 5. Emissions Summary B

Run #	Date	Burn Rate	CSA B415 CO	CSA B415 CO	CSA B415 CO
		kg/hr.	g/hr.	g/kg dry	g/MJ Output
1	3/5/18	1.56	9.49	6.06	0.45
3	3/12/18	1.83	11.58	6.32	0.44
Average		1.70	10.54	6.19	0.45

5.1 Description of Test Conditions

Table 6. Testing Laboratory Conditions

Run #	Date	Room Temperature (°F)		Barometric Pressure (in. Hg)		Relative Humidity (%)	
		Before	After	Before	After	Before	After
1	3/5/18	65	73	29.7	29.7	40	30
3	3/12/18	68	75	29.8	29.7	37	29

Table 7. Sampling Conditions

Dilution Tunnel					PM Sampling
		Velocity	Flow rate	Temperature	Flow rate
Run #	Date	Ft./sec.	Dscfm	°F	dscfm
1	3/5/18	15.2	294	98.03	0.240
3	3/12/18	15.4	297	102.4	0.233

5.2 Temperatures

Table 8. Average Surface Temperature

Average Surface Temperatures				
		Beginning Average Surface Temperature	Ending Average Surface Temperature	Average Change in Surface Temperature
Run #	Date	°F	°F	°F
1	3/5/18	333.7	320.8	12.9
3	3/12/18	325.4	348.2	22.8

Table 9 Average Catalyst Temperatures

Catalyst Temperatures				
		Beginning Catalyst Temperature	Ending Catalyst Temperature	Average Catalyst Temperature
Run #	Date	°F	°F	°F
1	3/5/18	824.0	685.1	817.9
3	3/12/18	911.0	644.9	834.5

5.3 Process Operation Comments

Technician notes, comments, and observations, and fuel bed adjustments were recorded in the Kelvin application. All notes recorded in Kelvin are attached in Appendix D.

5.4 Information and Comments

ClearStak uses Alternate Test Method Alt-126 for determining particulate emissions from the front half filter probe assemblies. Approval of this test method is found in Appendix E in a letter from the EPA.

ClearStak collects the particulate matter recovery and weights of the front half filter probe assembly by applying procedures regarding acetone probe rinses described in section 8.7 of EPA Method 5, *Determination of Particulate Matter Emissions from Stationary Sources*, in place of using the sample recovery procedure required in section 10.2.2 of ASTM E2515-11, *Standard Test Method for Determination of Particulate Matter Emissions Collected by a Dilution Tunnel* per requirement of 40 CFR 60 part AAA and QQQQ. The difference between the two recovery procedures is that EPA Method 5 determines particulate matter of the probe by collecting the particulate through acetone rinses and dried down beakers, rather than weighing the entire 100+ gram probe assembly before and after a test to evaluate recovery values measured in milligrams.

ClearStak performs gravimetric analysis of all particulate matter samples at an offsite location and not in the emission testing laboratory to ensure quality low mass measurements uninfluenced by ground vibrations. The rinse is then transferred from the jar to clean and desiccated pre-weighed beakers where they are dried down, desiccated, and then weighed in 6-hour intervals until two consecutive weights are achieved within 0.2 mg, as required in ASTM E2515-11.

6 Quality Control and Assurance Procedures and Results

Calibration procedures and checks were conducted per EPA Method 28R, Method 5, and ASTM E2515. Calibration certificates and checks can be found in Appendix B and Appendix C, Calibration Data. Appendix F. is a copy of ClearStak Credentials.

Test method quality control procedures, including but not limited to, leak checks, volume checks, stratification checks, and proportionality results were followed in procedures outlined in section 4 and can be found in the raw data for each test run, Appendix C.

6.1 Unit Seal

The appliance was sealed with a ClearStak seal, noting the model, manufacture, and ClearStak test ID, and then metal band strapped to a wooden pallet for return to the Customer for storage.

7 Statement of Uncertainty

The average combined estimated uncertainty of measurement for PM emissions is 4.79 g. +/- 1.13 g. at 95% Confidence. The average expanded uncertainty of measurement for efficiency is 70.6% +/- 5.3% at 95% Confidence. Calculations can be found in Appendix C.

As referenced from Method 28, it is not possible to specify the precision of the procedure in this test method because the appliance operation and fueling protocols and the appliances themselves produce variable amounts of emissions and cannot be used to determine reproducibility or repeatability of this method.

As referenced from Method 28, no definite information can be presented on the bias of the procedure in this test method for measuring solid fuel biomass heater emissions because no material having an accepted reference value is available.

The test results apply only to the specific appliance tested and do not apply to other products produced by the Customer. The Customer agrees not to reproduce, duplicate, copy, sell, resell or exploit for any purpose, any portion of this report without written approval from ClearStak.

8 References

80 FR 13671 Standards of Performance for New Residential Wood Heaters New Residential Hydronic Heaters and Forced-Air Furnaces, 2015, (NSPS).

ASTM E2515-11, Standard Test Method for Determination of Particulate Matter Emissions Collected by a Dilution Tunnel, ASTM International, West Conshohocken, PA, 2011, www.astm.org

9 Appendices

Appendix A. Customer Supplied Documents

Appendix B. ClearStak Instrumentation Records

Appendix C. Test Run Data

Appendix D. Kelvin Summary Notes

Appendix E. EPA Letter

Appendix F. ClearStak Credentials

CSL-00010

Appendix A

**ENGINEERING DRAWINGS
REDACTED**

EPA Test procedure

Do not open the bypass in the EPA test model!

Establish thick coal bed by doing at least 1 full burn before pre-burn.


Pre-burn with door slightly cracked to maintain high heat

15 minutes before test remove all ash and small coals, leaving only large coals.

If Catalyst is not at 800 F prior to test start, add more pre-burn fuel and wait 15 more minutes.

Rake coals so there is a channel in the middle, spanning from the front to the back, with a slight bunching of coals near the front:

Load wood as follows:



Shut the door within 1 minute of initial loading

CSL-00010

Appendix B

CERTIFICATE OF CALIBRATION

CUSTOMER:	CLEAR STAK PUTNAM CT	CALIBRATION DATE:	01/16/18
PO NUMBER:	KELLI O'BRIEN	CALIBRATION DUE:	01/16/19
INST. MANUFACTURER:	AIRTOX/ SCHLUMBERGER	PROCEDURE:	NAVAIR 17-20MG-02
INST. DESCRIPTION:	AIR SAMPLER/ STACK SAMPLER	CALIBRATION FLUID:	AIR @ 14.7 PSIA 70 F
MODEL NUMBER:	GALLUS 2000 (AL-307744)	STANDARD(S) USED:	A4, A24 DUE 06-2020
SERIAL NUMBER:	003035641	NIST TRACE # 'S:	1446135470, 1453926155
RATED UNCERTAINTY:	+/- 1 % RD.	AMBIENT CONDITIONS:	768 mm HGA 53 % RH 70 F
UNCERTAINTY GIVEN:	TOTAL measurement uncertainty: +/- 1.90 % RD. K=2	CERTIFICATE FILE #:	471999.18
NOTES:	AS RECEIVED/ AS LEFT WITHIN SPECS. REFERENCE CONDITIONS ARE: 760 mm HGA 70 F		

TEST POINT NUMBER	UUT		CORRECTION FACTOR	UUT	
	INDICATED	DM.STD. ACTUAL		INDICATED	DM.STD. ACTUAL
	SCMH	SCMH		L/ MIN FLOW	SLPM FLOW
	PD.METER	PD.METER			
1	0.0478	0.048	1.0038	1	1.009
2	0.1007	0.101	1.0032	2	2.013
3	0.4978	0.499	1.0024	3	3.024
4	1.0003	1.002	1.0017	4	4.036
5	1.5016	1.505	1.0022	5	5.058
6	1.9930	1.997	1.0020		
7	2.2433	2.248	1.0021	GAUGE	GAUGE
8	2.4960	2.501	1.0020	"HG VAC.	"HG VAC.
		AVERAGE	1.00243	0-20	0-20

All instruments used in the performance of the shown calibration have traceability to the National Institute of Standards and Technology (NIST). The uncertainty ratio between the calibration standards (DM.STD.) used and the unit under test (UUT) is a minimum of 4:1, unless otherwise noted. Calibration has been performed per the shown procedure number, in accordance with ISO 10012:2003, ISO 17025:2005, ANSI/NCSSL-Z-540.3, and/or MIL-STD-45662A. Test methods: API2530-92 & ASME MFC-3M-1989.

Dick Munns Company • 11133 Winners Circle • Los Alamitos, CA 90720
Phone (714) 827-1215 • Fax (714) 827-0823


This Calibration Certificate shall not be reproduced, copied, or full, without approval by DICK MUNNS COMPANY. The data shown applies only to the instrument being calibrated and under the stated conditions of calibration.

Date:

Approved By:

Calibration Technician:

1/16/2018



Certificate of Calibration



13081905

Certificate Page 1 of 2

CALIBRATION CERT #2357.21

Instrument Identification

Company ID: 1087
CLEARSTAK
KELLI OBRIEN
99 CONAL STREET
PUTMAN, CT 06260

PO Number: CS17120

Instrument ID: **M26AA**
Manufacturer: DWYER
Description: THERMO ANEMOMETER

Model Number: 471B-1
Serial Number: M26AA

Accuracy: Air Velocity: $\pm 3\%$ of Full Scale. Temperature: $\pm 0.5^\circ\text{F}$.

Certificate Information

Reason For Service: CALIBRATION
Type of Cal: ACCREDITED 17025 WITH UNCERTAINTIES
As Found Condition: IN TOLERANCE
As Left Condition: IN TOLERANCE
Procedure: CSWW-CP-AIR1 ISSUE DATE 2 MAR 2017

Technician: JAMES PRESTON
Cal Date 13Dec2017
Cal Due Date: 13Dec2018
Interval: 12 MONTHS
Temperature: 25.0 C
Humidity: 20.7 %

Remarks: # Denotes unaccredited nominal. Replaced 9 volt battery. Data report attached.

Tektronix certifies the performance of the above instrument has been verified using test equipment of known accuracy, which is traceable to a National Standards Laboratory (NIST, NPL, PTB). The policies and procedures used comply with ISO/IEC 17025:2005. This certificate shall not be reproduced, except in full, without the written approval of the calibration facility. Reported uncertainties are expanded uncertainties expressed at approximately the 95% confidence level using a coverage of $k=2$.

This certificate and associated attachments relate only to the metrological quantities presented in this report. No representation is made about the long-term stability of this unit. Any number of factors can influence the calibration that may cause the unit to drift out of specification before the calibration interval has expired.

This certificate shall not be reproduced, except in full, without the written permission of Tektronix. Data Report Attached.

Approved By: JAMES PRESTON
Service Representative

Issue Date: 12/13/2017

Calibration Standards

NIST Traceable#	Inst. ID#	Description	Manufacturer	Model	Cal Date	Date Due
12044098	01-1672	THERMOMETER, HANDHELD, 1 CHANNEL	HART SCIENTIFIC	1521	20Jan2017	20Jan2018
12070503	01-2006	SECONDARY REFERENCE PROBE	FLUKE/HART	5615-12	27Jan2017	27Jan2018
12565539	01-DA01	NON-ISOLATED PRESSURE MODULE, 0 TO 2	ASHCORFT	AQS-1	27Jun2017	27Jun2018



Certificate of Calibration



13081905

CALIBRATION CERT #2357.21

Certificate Page 2 of 2

Calibration Standards

<u>NIST Traceable#</u>	<u>Inst. ID#</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model</u>	<u>Cal Date</u>	<u>Date Due</u>
12345092	01-TEMP9	PROBE	NEWPORT ELECTRC	ITHP-5-DB9	19Apr2017	19Apr2018
12562534	SP-0263	HANDHELD CALIBRATOR	ASHCROFT	ATE-100	26Jun2017	26Jun2018
12334398 REV 1	01-1951	ANEMOMETER	OMEGA	HHF-142	05Apr2017	05Apr2018



Manufacturer: DWYER
 ID / Asset Number: M26AA

Certificate Number: 13081905
 Model Number: 471B-1
 Calibration Date: 12/13/2017

Function / Range	Nominal Value	As Found	Result	As Left	Result	Min	Max	Units	Uncertainty
AIR VELOCITY FPM									
AIR VELOCITY FPM	#200.0	203.0	Pass	Same	Pass	20.0	380.0	fpm	5.1 fpm
	500.0	488.0	Pass	Same	Pass	320.0	680.0	fpm	4.4 fpm
	1000.0	945.0	Pass	Same	Pass	820.0	1180.0	fpm	2.4 fpm
	2000.0	1898.0	Pass	Same	Pass	1820.0	2180.0	fpm	5.5 fpm
	4000.0	3843.0	Pass	Same	Pass	3820.0	4180.0	fpm	9.4 fpm
TEMPERATURE °F									
TEMPERATURE °F	77.0	76.6	Pass	Same	Pass	76.5	77.5	°F	0.13 °F

Accredited Calibration Datasheets may contain measurements that are not covered by the Scope of Accreditation. These measurements are indicated by a pound sign (#).
 Measurements with an (*) indicates an Indeterminate Guardband Pass or Fail - Guardbanding is determined by the Measurement Uncertainty Method

*****END OF MEASUREMENT REPORT*****

**WEIGHT CALIBRATION CERTIFICATE**

Certificate for: ClearStak, LLC
99 Canal Street
Putnam, CT 06260

Certificate Number: 18-68566
Serial Number: 42652
ID Number: 7228-OW
Date of Calibration: 05-February-2018
Next Calibration Due: 05-February-2019

Weight Info

Weight Range: (100g-2mg) 19pc Set
Accuracy Class: (ASTM E 617) 1
Manufacturer: Troemner
Construction: Type II (100g-1g); Type I (500mg-2mg)
Material: S/S (100g-50mg, 5mg); Al (20mg's, 10mg, 2mg)

Laboratory Info

Weight(s) Received: 31-January-2018
Date of Certificate Issue: 05-February-2018
Condition of Weight(s): Good
Procedure: SWI-10.08
Weighing Design: SOP 4 NISTIR 6969

Certificate Information**Traceability Statement:**

Atlantic Scale certifies the weights listed within this certificate have been calibrated against reference standards that are directly traceable to NIST. The Weighing Design used in this calibration is derived from NIST testing methods for Precision Mass Calibrations. This Certificate represents a calibration within the scope of accreditation of ISO/IEC 17025, General Requirements for the Competence of Calibration and Testing Laboratories. The data listed only applies to the weights specifically documented in this report.

Uncertainty Statement:

A best estimate of possible inaccuracy of the measured values, due to both systematic and random components. The Combined Uncertainty includes the uncertainty reported for the standard and the uncertainty for the measurement process. The Combined Uncertainty is multiplied by the Coverage Factor, $k=2$, to give an Expanded Uncertainty, and a Confidence Level of 95%.

As Found Values & Tolerance Disposition:

The value of the weight as received by Atlantic Scale after a light cleaning and before any adjustment. When determining the tolerance disposition of a particular weight, the As Found Weight Value is rounded to the same significant figures as the documented tolerance.

Conventional Mass Values:

Weight Values documented in this report are Conventional Mass Values (i.e. results from weighing in air). For a weight taken at 20 °C, the conventional mass is the mass of a reference weight with a density of 8000 kg/m³ for which it balances in air of density of 1.2 kg/m³.

Construction Type:

Type I weights are of one-piece construction with no adjustment cavities. These weights can not be adjusted to a heavier value. Type II weights are of two-piece construction with some form of an adjusting cavity for adding and removing weight.

Air Density & Magnitude of Air Buoyancy:

The Air Density (Temperature, Barometric Pressure, and Rel. Humidity taken at the time of the calibration) is calculated to determine the mass value and adjust for any air buoyancy corrections. The Magnitude of Air Buoyancy Correction is the adjustment made to compensate for the lifting effect from air on the weight during calibration.

Comments: Weights were within tolerance

Atlantic Scale Co., Inc.

136 Washington Avenue Nutley, NJ 07110 * Tel: 973-661-7090 * Fax: 973-661-3651 * www.atlanticscale.com

ISO/IEC 17025:2005

Calibration Cert No. 2736.01



WEIGHT CALIBRATION CERTIFICATE

Certificate for: ClearStak, LLC
99 Canal Street
Putnam, CT 06260

Certificate Number: 18-68566
Serial Number: 42652
ID Number: 7228-OW
Date of Calibration: 05-February-2018
Next Calibration Due: 05-February-2019

Signatures

Calibrated By: Mark Keefe
Mass Metrologist

Mark Keefe

Approved By: Fred J. Algieri
Mass Technical Manager

F. J. Algieri

Conventional Mass Values & Tolerance Data

Nominal Value	As Found Weight Value	As Left Weight Value	(ASTM E 617) 1		As Found Disposition
			Allowable Tolerance Range (+ / -)		
100 g	99.999991 g	99.999991 g	100.00025 g	↔ 99.99975 g	In Tolerance
50 g	50.000048 g	50.000048 g	50.00012 g	↔ 49.99988 g	In Tolerance
20 g	19.999990 g	19.999990 g	20.000074 g	↔ 19.999926 g	In Tolerance
20 g*	19.999965 g	19.999965 g	20.000074 g	↔ 19.999926 g	In Tolerance
10 g	9.999964 g	9.999964 g	10.000050 g	↔ 9.999950 g	In Tolerance
5 g	4.9999837 g	4.9999837 g	5.000034 g	↔ 4.999966 g	In Tolerance
2 g	1.9999900 g	1.9999900 g	2.000034 g	↔ 1.999966 g	In Tolerance
2 g*	2.0000006 g	2.0000006 g	2.000034 g	↔ 1.999966 g	In Tolerance
1 g	1.0000032 g	1.0000032 g	1.000034 g	↔ 0.999966 g	In Tolerance
500 mg	500.0019 mg	500.0019 mg	500.010 mg	↔ 499.990 mg	In Tolerance
200 mg	200.0008 mg	200.0008 mg	200.010 mg	↔ 199.990 mg	In Tolerance
200 mg*	199.9923 mg	199.9923 mg	200.010 mg	↔ 199.990 mg	In Tolerance
100 mg	99.9918 mg	99.9918 mg	100.010 mg	↔ 99.990 mg	In Tolerance
50 mg	50.0038 mg	50.0038 mg	50.010 mg	↔ 49.990 mg	In Tolerance
20 mg	19.9971 mg	19.9971 mg	20.010 mg	↔ 19.990 mg	In Tolerance
20 mg*	20.0005 mg	20.0005 mg	20.010 mg	↔ 19.990 mg	In Tolerance
10 mg	9.9983 mg	9.9983 mg	10.010 mg	↔ 9.990 mg	In Tolerance
5 mg	5.0034 mg	5.0034 mg	5.010 mg	↔ 4.990 mg	In Tolerance
2 mg	2.0065 mg	2.0065 mg	2.050 mg	↔ 1.950 mg	In Tolerance

NIST Traceable
Calibration Report



Reference Number: **1147936**
 PO Number: **CCP507**

Clearstak LLC
 99 Canal St
 Putnam, CT 06260-1909 United States



Manufacturer: Cole-Parmer
Model Number: 99780-50
Description: Pressure, Barometer
Asset Number: BR-1
Serial Number: 150198541
Procedure: DS Control Company 4199

Calibration Date: 12/02/2017
Calibration Due Date: 06/02/2018
Condition As Found: In Tolerance
Condition As Left: In Tolerance After Adjustment

Remarks:
 NIST-traceable calibration performed on the unit referenced above in accordance with customer requirements, published specifications and the lab's standard operating procedures. Unit was received in-tolerance but adjusted to deliver readings closer to nominal.

Standards Utilized

Asset No.	Manufacturer	Model No.	Description	Cal. Date	Due Date
CP50124	Druck Inc.	DP1 142	Barometer, Indicator	07/08/2017	07/31/2018

Calibration Data

FUNCTION TESTED	Nominal Value	As Found	Out of Tol	As Left	Out of Tol	CALIBRATION TOLERANCE
Increasing Barometric Pressure Test	960.0 mbar	964.0		962.0		955.2 to 964.8 mbar [EMU 0.11 mbar]TUR 44.1]
	1000.0 mbar	1003.5		1001.5		995.0 to 1005.0 mbar [EMU 0.11 mbar]TUR 45.1]
	1050.0 mbar	1047.0		1045.0		1044.8 to 1055.2 mbar [EMU 0.11 mbar]TUR 46.1]
Decreasing Barometric Pressure Test	1000.0 mbar	1004.5		1002.5		995.0 to 1005.0 mbar [EMU 0.11 mbar]TUR 45.1]
	960.0 mbar	964.5		962.5		955.2 to 964.8 mbar [EMU 0.11 mbar]TUR 44.1]
	990.0 mbar	994.0		992.0		985.1 to 994.9 mbar [EMU 0.11 mbar]TUR 45.1]

Temperature: 20° C
 Humidity: 39% RH
 Rpt. No.: 1317978

Calibration Performed By:				Quality Reviewer:	
Name	ID#	Title	Phone	Name	Date
Ren, Jenny	339	Metrologist	847-327-5327	Szplitt, Tony	12/04/2017

This report does not represent a list of all units within possession of customer. The results stated in this report relate only to the units tested or calibrated. All measurements reported herein are traceable to SI units via national standards maintained by NIST and were performed in compliance with ISO 17025-ANAB04. ANAB04/2012. 2010-1-1994. ACP1996. Appendix B. 1003 8002 94. and ISO 17025-2005. Guard Banding, if reported on this certificate, is applied at a 2 factor of 20% for test points with a tolerance value (TUR) value of 1. In tolerance conditions are stated on test sheets listing specific tests with no reduction by the uncertainty of the measurement. The reported measurement uncertainty (UM) is indicated on this certificate, is being reported at a confidence level of 95% or 99.9% unless otherwise noted in the remarks section.



DocNumber: 000014928

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR PKG DURHAM CT HS
 89 COMMERCE CIRCLE
 DURHAM CT 06422

Praxair Order Number: 70018077
 Customer P. O. Number:
 Customer Reference Number:

Fill Date: 12/4/2015
 Part Number: NI CD5CO2RE-AS
 Lot Number: 304125338501
 Cylinder Style & Label: AS CGA 590
 Cylinder Pressure & Volume: 2000 psig 143 cu. ft.

Certified Concentration:

Expiration Date:	12/9/2023	NIST Traceable
Cylinder Number:	CC72581	Analytical Uncertainty:
2491 ppm	CARBON MONOXIDE	± 0.5 %
4.98 %	CARBON DIOXIDE	± 0.7 %
5.00 %	OXYGEN	± 0.4 %
Balance	NITROGEN	

Certification Information: Certification Date: 12/9/2015 Term: 96 Months Expiration Date: 12/9/2023

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 2500 ppm
 Certified Concentration: 2491 ppm
 Instrument Used: HORIBA VSA-3000 SN YSEY78L6
 Analytical Method: NDIR
 Last Multipoint Calibration: 11/23/2015

First Analysis Data:		Date: 12/9/2015	
Z: 0	R: 4997	C: 2487	Conc: 2492
R: 4997	Z: 0	C: 2485	Conc: 2490
Z: 0	C: 2487	R: 4995	Conc: 2492
UOM: PPM	Mean Test Assay:		2491 PPM

Reference Standard Type: GMS
 Ref. Std. Cylinder #: SA14089
 Ref. Std. Conc: 5006 PPM
 Ref. Std. Traceable to SRM #: 2638A
 SRM Sample #: 55-E-47
 SRM Cylinder #: FF23337

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: PPM	Mean Test Assay:		0 PPM

2. Component: CARBON DIOXIDE

Requested Concentration: 5 %
 Certified Concentration: 4.98 %
 Instrument Used: SIEMENS ULTRAMAT SE SN: D0-412
 Analytical Method: NON-DISPERSIVE INFRARED
 Last Multipoint Calibration: 11/23/2015

First Analysis Data:		Date: 12/9/2015	
Z: 0	R: 15.25	C: 4.99	Conc: 4.98
R: 15.27	Z: 0	C: 4.99	Conc: 4.98
Z: 0	C: 4.99	R: 15.23	Conc: 4.98
UOM: %	Mean Test Assay:		4.98 %

Reference Standard Type: GMS
 Ref. Std. Cylinder #: SA6759
 Ref. Std. Conc: 15.23 %
 Ref. Std. Traceable to SRM #: 2745
 SRM Sample #: 9-C-34
 SRM Cylinder #: CAL016129

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay:		0 %

3. Component: OXYGEN

Requested Concentration: 5 %
 Certified Concentration: 5.00 %
 Instrument Used: SIEMENS OXYMAT SF
 Analytical Method: PARAMAGNETIC
 Last Multipoint Calibration: 11/20/2015

First Analysis Data:		Date: 12/9/2015	
Z: 0	R: 12.02	C: 5	Conc: 5
R: 12	Z: 0	C: 5	Conc: 5
Z: 0	C: 5	R: 12.02	Conc: 5
UOM: %	Mean Test Assay:		5 %

Reference Standard Type: SRM
 Ref. Std. Cylinder #: CC110316
 Ref. Std. Conc: 12.01%
 Ref. Std. Traceable to SRM #: 2653A
 SRM Sample #: 71-E-24
 SRM Cylinder #: FF18300

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay:		0 %

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

DocNumber: 000014929

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR PKG DURHAM CT HS
 89 COMMERCE CIRCLE
 DURHAM CT 06422

Praxair Order Number: 70018077
 Customer P. O. Number:
 Customer Reference Number:

Fill Date: 12/30/15
 Part Number: NI CO11CO15E-AS
 Lot Number: 30412337504
 Cylinder Style & Outlet: AS GDA 500
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	12/9/2023	NIST Traceable
Cylinder Number:	CC160141	Analytical Uncertainty:
5011 ppm	CARBON MONOXIDE	± 0.5 %
10.91 %	CARBON DIOXIDE	± 0.5 %
10.98 %	OXYGEN	± 0.2 %
Balance	NITROGEN	

Certification Information: Certification Date: 12/9/2015 Term: 96 Months Expiration Date: 12/9/2023

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-800/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 5000 ppm
 Certified Concentration: 5011 ppm
 Instrument Used: HORIBA VA-3000 SN Y5EY75LE
 Analytical Method: NDIR
 Last Multiport Calibration: 11/23/2015

First Analysis Data:		Date: 12/9/2015	
Z: 0	R: 4997	C: 5000	Conc: 5010
R: 4997	Z: 0	C: 5002	Conc: 5012
Z: 0	C: 5002	R: 4995	Conc: 5012
UOM: PPM	Mean Test Assay: 5011 PPM		

Reference Standard Type: GMS
 Ref. Std. Cylinder #: SA14099
 Ref. Std. Conc: 5000 PPM
 Ref. Std. Traceable to SRM #: 2650A
 SRM Sample #: 95-E-47
 SRM Cylinder #: FF23337

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: PPM	Mean Test Assay: 0 PPM		

2. Component: CARBON DIOXIDE

Requested Concentration: 11 %
 Certified Concentration: 10.91 %
 Instrument Used: SIEMENS ULTRAMAT 6E SN 02-412
 Analytical Method: NON-DISPERSIVE INFRARED
 Last Multiport Calibration: 11/23/2015

First Analysis Data:		Date: 12/9/2015	
Z: 0	R: 15.25	C: 10.94	Conc: 10.93
R: 15.27	Z: 0	C: 10.91	Conc: 10.9
Z: 0	C: 10.92	R: 15.23	Conc: 10.91
UOM: %	Mean Test Assay: 10.91 %		

Reference Standard Type: GMS
 Ref. Std. Cylinder #: SA6799
 Ref. Std. Conc: 15.23 %
 Ref. Std. Traceable to SRM #: 2745
 SRM Sample #: 9-C-34
 SRM Cylinder #: CAL016129

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay: 0 %		

3. Component: OXYGEN

Requested Concentration: 11 %
 Certified Concentration: 10.98 %
 Instrument Used: SIEMENS OXYMAT 5F
 Analytical Method: PARAMAGNETIC
 Last Multiport Calibration: 11/23/2015

First Analysis Data:		Date: 12/9/2015	
Z: 0	R: 12.02	C: 10.98	Conc: 10.98
R: 12	Z: 0	C: 10.98	Conc: 10.98
Z: 0	C: 10.98	R: 12.02	Conc: 10.98
UOM: %	Mean Test Assay: 10.98 %		

Reference Standard Type: SRM
 Ref. Std. Cylinder #: CC110330
 Ref. Std. Conc: 12.01%
 Ref. Std. Traceable to SRM #: 2650A
 SRM Sample #: 71-E-24
 SRM Cylinder #: FF18000

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay: 0 %		

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

DocNumber: 000014908

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR PKG DURHAM CT HS
 89 COMMERCE CIRCLE
 DURHAM CT 06422

Praxair Order Number: 70018077
 Customer P. O. Number:
 Customer Reference Number:

Lot Date: 12/02/15
 Part Number: NI CD000031E-AS
 Lot Number: 304125337503
 Cylinder Size & Outlet: AS CGA 590
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	12/7/2023	NIST Traceable
Cylinder Number:	SA2659	Analytical Uncertainty:
9639 ppm	CARBON MONOXIDE	± 0.9 %
19.77 %	CARBON DIOXIDE	± 0.3 %
21.03 %	OXYGEN	± 0.2 %
Balance	NITROGEN	

Certification Information: Certification Date: 12/7/2015 Term: 98 Months Expiration Date: 12/7/2023

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-800/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 9639 ppm
 Certified Concentration: 9639 ppm
 Instrument Used: HORIBA VA-3000 SN Y5EY78L6
 Analytical Method: NDIR
 Last Multipoint Calibration: 11/23/2015

First Analysis Data:		Date: 12/7/2015	
Z: 0	R: 20370	C: 9640	Conc: 9639
R: 39370	Z: 0	C: 9640	Conc: 9639
Z: 0	C: 9640	R: 39390	Conc: 9639
UOM: PPM	Mean Test Assay: 9639 PPM		

Reference Standard Type: GMS
 Ref. Std. Cylinder #: SA12367
 Ref. Std. Conc.: 3.936 %
 Ref. Std. Traceable to SRM #: 2042a
 SRM Sample #: 51-D-21
 SRM Cylinder #: FF23113

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: PPM	Mean Test Assay: 0 PPM		

2. Component: CARBON DIOXIDE

Requested Concentration: 20 %
 Certified Concentration: 19.77 %
 Instrument Used: SIEMENS ULTRAMAT 5E SN 02-412
 Analytical Method: NON-DISPERSIVE INFRARED
 Last Multipoint Calibration: 11/23/2015

First Analysis Data:		Date: 12/7/2015	
Z: 0	R: 19.63	C: 19.8	Conc: 19.74
R: 19.81	Z: 0	C: 19.85	Conc: 19.79
Z: 0	C: 19.62	R: 19.78	Conc: 19.76
UOM: %	Mean Test Assay: 19.77 %		

Reference Standard Type: SRM
 Ref. Std. Cylinder #: GC102925
 Ref. Std. Conc.: 19.75%
 Ref. Std. Traceable to SRM #: 2745
 SRM Sample #: 9-C-34
 SRM Cylinder #: CAL016129

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay: 0 %		

3. Component: OXYGEN

Requested Concentration: 21.03 %
 Certified Concentration: 21.03 %
 Instrument Used: SIEMENS OXYMAT 5F
 Analytical Method: PARAMAGNETIC
 Last Multipoint Calibration: 11/20/2015

First Analysis Data:		Date: 12/7/2015	
Z: 0	R: 21.16	C: 21.00	Conc: 21.03
R: 21.16	Z: 0	C: 21.00	Conc: 21.03
Z: 0	C: 21.04	R: 21.18	Conc: 21.01
UOM: %	Mean Test Assay: 21.03 %		

Reference Standard Type: SRM
 Ref. Std. Cylinder #: GC162161
 Ref. Std. Conc.: 21.14 %
 Ref. Std. Traceable to SRM #: 2699A
 SRM Sample #: 71-E-24
 SRM Cylinder #: FF18300

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay: 0 %		

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information can be held herein exceed the fee established for providing such information.

DocNumber: 000019149

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

CLEARSTAK LLC
 PO BOX 109
 PUTNAM CT 06260

Praxair Order Number: 85618572
 Customer P. O. Number: CS15107
 Customer Reference Number:

Fill Date: 11/21/2016
 Part Number: NI CD110017E-AS
 Lot Number: 304322329803
 Cylinder Style & Gases: AS CGA 590
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	11/28/2024	NIST Traceable
Cylinder Number:	CC139181	Analytical Uncertainty:
2.00 %	CARBON MONOXIDE	± 0.8 %
10.78 %	CARBON DIOXIDE	± 0.5 %
10.90 %	OXYGEN	± 0.2 %
Balance	NITROGEN	

Certification Information: Certification Date: 11/28/2016 Term: 96 Months Expiration Date: 11/28/2024

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 2 %
 Certified Concentration: 2.00 %
 Instrument Used: HORIBA VIA-3000 S/N Y5EY76L6
 Analytical Method: NDIR
 Last Multiport Calibration: 11/10/2016

Reference Standard Type: GMS
 Ref. Std. Cylinder #: SA12367
 Ref. Std. Conc: 3.936 %
 Ref. Std. Traceable to SRM #: 2642a
 SRM Sample #: 51-D-21
 SRM Cylinder #: FF23113

First Analysis Data:		Date: 11/28/2016	
Z: 0	R: 4	C: 2.03	Conc: 2
R: 4	Z: 0	C: 2.03	Conc: 2
Z: 0	C: 2.03	R: 4	Conc: 2
UOM: %		Mean Test Assay: 2 %	

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: PPM		Mean Test Assay: 0 PPM	

2. Component: CARBON DIOXIDE

Requested Concentration: 11 %
 Certified Concentration: 10.78 %
 Instrument Used: SIEMENS ULTRAMAT SE S/N: D0-412
 Analytical Method: NON-DISPERSIVE INFRARED
 Last Multiport Calibration: 11/9/2016

Reference Standard Type: GMS
 Ref. Std. Cylinder #: CC103962
 Ref. Std. Conc: 17.91 %
 Ref. Std. Traceable to SRM #: 2745
 SRM Sample #:
 SRM Cylinder #:

First Analysis Data:		Date: 11/28/2016	
Z: 0	R: 18.37	C: 11.06	Conc: 10.78
R: 18.39	Z: 0	C: 11.06	Conc: 10.78
Z: 0	C: 11.06	R: 18.38	Conc: 10.78
UOM: %		Mean Test Assay: 10.78 %	

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %		Mean Test Assay: 0 %	

3. Component: OXYGEN

Requested Concentration: 11 %
 Certified Concentration: 10.90 %
 Instrument Used: SIEMENS OXYMAT 5F
 Analytical Method: PARAMAGNETIC
 Last Multiport Calibration: 11/9/2016

Reference Standard Type: GMS
 Ref. Std. Cylinder #: CC6852
 Ref. Std. Conc: 21.32%
 Ref. Std. Traceable to SRM #: 2699A
 SRM Sample #: 71-E-24
 SRM Cylinder #: FF18300

First Analysis Data:		Date: 11/28/2016	
Z: 0	R: 21.22	C: 10.88	Conc: 10.9
R: 21.24	Z: 0	C: 10.88	Conc: 10.9
Z: 0	C: 10.88	R: 21.24	Conc: 10.9
UOM: %		Mean Test Assay: 10.9 %	

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %		Mean Test Assay: 0 %	

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

DocNumber: 000019149

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Analyzed by:


Jeff Gosner

Certified by:


Jessica Goodman




cincinnati fan

Form: OMM-15-0509
Effective: 5/4/09
Supersedes: OMM-15-0507
Part No.: 01236

Installation, Safety, Operation & Maintenance Instructions And Parts List For Models TAF, WAF, HTF & WAF/HTF, Belt Drive Tube Axial Fans Arrangement 9

NOTE

READ ENTIRE MANUAL, INCLUDING "SECTION IV. INITIAL UNIT STARTUP" BEFORE ATTEMPTING TO INSTALL AND OPERATE THIS EQUIPMENT.

FAN SPECIFICATIONS

FAN SERIAL NUMBER: 1415817 MFG. DATE: 12/23/14

NOTE: The serial number above is a required reference for any assistance. It is stamped on the fan nameplate.

FAN SPECIFICATIONS:

Model: WAF/HTF-12 Propeller Number: SPECIAL

FAN PERFORMANCE DATA: (If entered on order)

CFM: 855 SP: 1.480 (Inches of Water Gauge) Motor BHP: 0.630
Density: 0.064 Altitude: _____ (Ft. above S.L.) Airstream Temperature: 160 °F.
Fan RPM: 3350 Maximum Safe Fan RPM: Call for > 3350 **DO NOT EXCEED THIS RPM**

MOTOR DATA: (This section is completed only if the motor was supplied by Cincinnati Fan)

HP: 1 RPM: 3450 Voltage: 190/380/50 & 208-230/460/60 Phase: 3
Hz: 60 Frame Size: 56 Enclosure: TEFC Efficiency: Std Eff

IF Motor is EXP, Class(es) & Group(s) are: _____

Manufacturers Model Number: 00136ES3E56-S CFV Part Number: 37270W

DRIVE DATA:

Fan Sheave: AK32H Motor Sheave: AS32X5/8 Belts: AX32
No. of Grooves: 1 Fixed Speed: Adjustable Speed:

ATTENTION: RECEIVING DEPARTMENT

All Cincinnati Fan products are packaged to minimize any damage during shipment. The freight carrier is responsible for delivering all items in their original condition as received from Cincinnati Fan. The individual receiving this equipment is responsible for inspecting this unit for any obvious or concealed damage. If any damage is found, it should be noted on the bill of lading before the freight is accepted and the receiver must file a claim with the freight carrier.

LONG TERM STORAGE NOTICE

If this fan will NOT be installed and put into operation within 30 days, refer to the "Long Term Storage Instructions" on page 15. Failure to follow all applicable long term storage instructions, will void your warranty. This fan should be stored indoors in a clean, dry location.



Certificate #	00127-BAL-6
Issue Date	2/28/18
Dept. Location	Wilmington

Instrument ID	AB-1
As Found	In Tolerance
As Left	In Tolerance

Calibration Performed	LTP-00004
Calibration Date	2/28/18
Next Calibration Due Date	6/28/18

Location	Wilmington	CT
Location Temperature*	68	deg F
Relative Humidity**	30	%RH
Start Time	15:11	
End Time	15:55	

Manufacturer	OHAUS	
Model	Adventurer	
Capacity	210	g
Division	0.0001	g

*Laboratory temperature must be in the range of 10°C - 30C (50°F to 86°F)
 **Relative humidity shall never exceed 85%

Technician Name	Kelli O'Brien
-----------------	---------------

This report attests that the above stated Instrument has been calibrated with standards traceable to National Institute of Standards and Technology (NIST) within the acceptable tolerance of 0.2 mg. The calibrated reference test weights are within the span required for intended laboratory use and are not beyond the normal capacity specified above.

Increasing-Load Test

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
0.0050	0.0051	0.0001	Pass
0.1000	0.1000	0.0000	Pass
1.0000	1.0001	0.0001	Pass
20.0000	20.0001	0.0001	Pass
100.0000	100.0000	0.0000	Pass

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
0.0050	0.0049	0.0001	Pass
0.1000	0.0999	0.0001	Pass
1.0000	1.0000	0.0000	Pass
20.0000	20.0000	0.0000	Pass
100.0000	100.0001	0.0001	Pass

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
0.0050	0.0049	0.0001	Pass
0.1000	0.1000	0.0000	Pass
1.0000	1.0000	0.0000	Pass
20.0000	20.0001	0.0001	Pass
100.0000	100.0001	0.0001	Pass

Technician Signature: Kelli O'Brien
 Quality Review: [Signature]

Decreasing-Load Test

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
100.0000	100.0001	0.0001	Pass
20.0000	20.0001	0.0001	Pass
1.0000	1.0000	0.0000	Pass
0.1000	0.1000	0.0000	Pass
0.0050	0.0050	0.0000	Pass

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
100.0000	100.0001	0.0001	Pass
20.0000	20.0000	0.0000	Pass
1.0000	1.0000	0.0000	Pass
0.1000	0.0999	0.0001	Pass
0.0050	0.0049	0.0001	Pass

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
100.0000	100.0000	0.0000	Pass
20.0000	19.9999	0.0001	Pass
1.0000	1.0000	0.0000	Pass
0.1000	0.1000	0.0000	Pass
0.0050	0.0050	0.0000	Pass

		Shift Test						
	Expected (g)	Actual (g) Q1	Actual (g) Q2	Actual (g) Q3	Actual (g) Q4	Average Difference (g)	Pass/Fail	Deviation
1	20.0000	20.0002	19.9999	20.0000	20.0001	0.0001	Pass	1E-08
2	20.0000	20.0001	19.9999	20.0000	20.0001	0.0001	Pass	5.625E-09
3	20.0000	20.0001	19.9999	20.0000	20.0001	0.0001	Pass	5.625E-09

Repeatability

g	Average	Stdev
0.0050	0.0050	8.2E-05
0.1000	0.1000	5.164E-05
1.0000	1.0000	4.0825E-05
20.0000	20.0000	8.16497E-05
100.0000	100.0001	5.163978E-05



Certificate #	00127-BAL-6
Issue Date	2/28/18
Dept. Location	Willington

Instrument ID	AB-1
As Found	In Tolerance
As Left	In Tolerance

Calibration Performed	LTP-00004
Calibration Date	2/8/18
Next Calibration Due Date	6/28/18

Location	Willington	CT
Location Temperature*	64	deg F
Relative Humidity**	25	%RH
Start Time	11:26	
End Time	11:54	

Manufacturer	OHAUS	
Model	Adventurer	
Capacity	210	g
Division	0.0001	g

*Laboratory temperature must be in the range of 10°C - 30C (50°F to 86°F)
 **Relative humidity shall never exceed 85%

Technician Name	Brian Vinal
-----------------	-------------

This report attests that the above stated Instrument has been calibrated with standards traceable to National Institute of Standards and Technology (NIST) within the acceptable tolerance of 0.2 mg. The calibrated reference test weights are within the span required for intended laboratory use and are not beyond the normal capacity specified above.

Increasing-Load Test

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
0.0050	0.0049	0.0001	Pass
0.1000	0.0999	0.0001	Pass
1.0000	1.0000	0.0000	Pass
20.0000	20.0000	0.0000	Pass
100.0000	99.9998	0.0002	Pass

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
0.0050	0.0048	0.0002	Pass
0.1000	0.1000	0.0000	Pass
1.0000	1.0000	0.0000	Pass
20.0000	20.0001	0.0001	Pass
100.0000	99.9999	0.0001	Pass

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
0.0050	0.0049	0.0001	Pass
0.1000	0.1000	0.0000	Pass
1.0000	1.0000	0.0000	Pass
20.0000	20.0000	0.0000	Pass
100.0000	99.9999	0.0001	Pass

Technician Signature: Brian Vinal
 Quality Review: Kelli O'Brien

Decreasing-Load Test

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
100.0000	99.9998	0.0002	Pass
20.0000	20.0000	0.0000	Pass
1.0000	1.0000	0.0000	Pass
0.1000	0.1000	0.0000	Pass
0.0050	0.0049	0.0001	Pass

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
100.0000	99.9999	0.0001	Pass
20.0000	20.0001	0.0001	Pass
1.0000	0.9999	0.0001	Pass
0.1000	0.0999	0.0001	Pass
0.0050	0.0049	0.0001	Pass

Expected (g)	Actual (g)	Difference (g)	Pass/Fail
100.0000	99.9999	0.0001	Pass
20.0000	20.0001	0.0001	Pass
1.0000	1.0000	0.0000	Pass
0.1000	0.1000	0.0000	Pass
0.0050	0.0049	0.0001	Pass

		Shift Test						
	Expected (g)	Actual (g) Q1	Actual (g) Q2	Actual (g) Q3	Actual (g) Q4	Average Difference (g)	Pass/Fail	Deviation
1	20.0000	20.0000	19.9999	20.0000	20.0002	0.0001	Pass	5.625E-09
2	20.0000	20.0001	20.0000	20.0000	20.0002	0.0001	Pass	5.625E-09
3	20.0000	20.0001	19.9999	19.9999	20.0001	0.0001	Pass	1E-08

Repeatability

g	Average	Stdev
0.0050	0.0049	4.1E-05
0.1000	0.1000	5.164E-05
1.0000	1.0000	4.0825E-05
20.0000	20.0001	5.47723E-05
100.0000	99.9999	5.163978E-05

PARAMETER / EQUIPMENT : **J type Sample Sensors (A23)**
 UNIT UNDER TEST : **LTP -000005**
 RANGE : **32- 109 deg F**
 Prepared By : Kelli O'Brien
 05 Feb 2018
 Reviewed By : Kelli O'Brien
 05 Feb 2018

NOMINAL : 32 deg F
Units

REFERENCE STANDARDS & ANCILLARY EQUIPMENT

Manufacturer - Model	Description	ID #	Cal Intvl	Cal Exp. Date
Thermoworks PT 100	RTD	REF-1	1 Yr	20-Dec-18

TYPE A DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	MULT	STD UNC	VARIANCE
1 Repeatability & Reproducibility	0.22669	deg F	1	Normal	5	1.11053339	0.251743	0.063374375

TYPE B - FIXED VALUE DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	DIV	STD UNC	VARIANCE
1 Test thermocouple Readout	0.05000	deg F	1	Rect	1E+01	1.732	0.028868	0.000833382
2 Reference Standard Uncertainty	0.05000	deg F	1	Normal	1E+00	2	0.025000	0.000625000
3 Reference Standard Specification	0.01980	deg F	1	Normal	1E+00	1	0.019800	0.000392040
4 Reference Standard Readout	0.00500	deg F	1	Rect	1E+02	1.732	0.002887	0.000083334
5 Temperature Influence	0.00000	deg F	1	Normal	1E+02	1	0.000000	0.000000000
6								

TYPE B - VARIABLE VALUE DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	DIV	STD UNC	VARIANCE

Combined Uncertainty 0.25540777 deg F
 Expanded Uncertainty k=2 **0.51081555** deg F

NOTES :

- A1 Repeatability and Reproducibility from data below

- B1 Resolution of the device under test, divided by 2
- B2 Uncertainty from calibration cert #13107194 (Tektronix)
- B3 Stability from calibration cert #13107194 (Tektronix)
- B4 Resolution of the device under test, divided by 2
- B5
- B6
- B7
- B8
- B9
- B10
- B11
- B12

Type A Data

LINE No. : 1
BUDGET DESCRIPTION : Repeatability and Reproducibility
UNITS : deg F

0.2266863	STANDARD DEVIATION (in Units)
5	EFFECTIVE DEGREES OF FREEDOM

# of Rdgs	VALUE	DATE	TECH #	TEMP deg F	ROOM TEMP deg F
1	33.9	1/22/18	Brian Vinal	deg F	66
2	33.5	1/22/18	Brian Vinal	deg F	66
3	34.1	1/22/18	Brian Vinal	deg F	66
4	33.7	1/22/18	Kelli O'Brien	deg F	66
5	33.5	1/22/18	Kelli O'Brien	deg F	66
6	33.6	1/22/18	Kelli O'Brien	deg F	66

PARAMETER / EQUIPMENT : **K type Sample Sensors (A24, A 25, A26, A27, A28, A29, A30,)**
 UNIT UNDER TEST : **LTP -000005**
 RANGE : **32- 124 deg F**

NOMINAL : **32** **deg F** Units

Prepared By : Kelli O'Brien
 06 Feb 2018

Reviewed By : Kelli O'Brien
 06 Feb 2018

REFERENCE STANDARDS & ANCILLARY EQUIPMENT

Manufacturer - Model	Description	ID #	Cal Intvl	Cal Exp. Date
Thermoworks PT 100	RTD	REF-1	1 Yr	20-Dec-18

TYPE A DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	MULT	STD UNC	VARIANCE
1 Repeatability & Reproducibility	0.8632209	deg F	1	Normal	41	1.012367	0.873896	0.763694805

TYPE B - FIXED VALUE DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	DIV	STD UNC	VARIANCE
1 Test thermocouple Readout	0.05000	deg F	1	Rect	1E+01	1.732	0.028868	0.000833382
2 Reference Standard Uncertainty	0.05000	deg F	1	Normal	1E+00	2	0.025000	0.000625000
3 Reference Standard Specification	0.01980	deg F	1	Normal	1E+00	1	0.019800	0.000392040
4 Reference Standard Readout	0.00500	deg F	1	Rect	1E+02	1.732	0.002887	0.000083334
5 Temperature Influence	0.00000	deg F	1	Normal	1E+02	1	0.000000	0.000000000
6								

TYPE B - VARIABLE VALUE DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	DIV	STD UNC	VARIANCE

Combined Uncertainty 0.87495918 deg F
 Expanded Uncertainty k=2 1.74991835 deg F

NOTES :

- A1 Repeatability and Reproducibility from data below

- B1 Resolution of the device under test, divided by 2
- B2 Uncertainty from calibration cert #13107194 (Tektronix)
- B3 Stability from calibration cert #13107194 (Tektronix)
- B4 Resolution of the device under test, divided by 2
- B5
- B6
- B7
- B8
- B9
- B10
- B11
- B12

Type A Data

LINE No. : 1
 BUDGET DESCRIPTION : Repeatability and Reproducibility
 UNITS : deg F

0.8632209	STANDARD DEVIATION (in Units)
41	EFFECTIVE DEGREES OF FREEDOM

# of Rdgs	VALUE	DATE	TECH #	TEMP deg F	ROOM TEMP deg F
1	32.1	1/23/18	Brian Vinal	deg F	68
2	32.3	1/23/18	Brian Vinal	deg F	68
3	32.3	1/23/18	Brian Vinal	deg F	68
4	32.5	1/23/18	Kelli O'Brien	deg F	68
5	32.5	1/23/18	Kelli O'Brien	deg F	68
6	32.1	1/23/18	Kelli O'Brien	deg F	68
7	33.0	1/23/18	Brian Vinal	deg F	66
8	32.3	1/23/18	Brian Vinal	deg F	66
9	32.3	1/23/18	Brian Vinal	deg F	66
10	32.3	1/23/18	Kelli O'Brien	deg F	66
11	32.3	1/23/18	Kelli O'Brien	deg F	66
12	32.3	1/23/18	Kelli O'Brien	deg F	66
13	32.2	1/25/18	Brian Vinal	deg F	65
14	32.2	1/25/18	Brian Vinal	deg F	65
15	32.2	1/25/18	Brian Vinal	deg F	65
16	32.2	1/25/18	Kelli O'Brien	deg F	65
17	32.2	1/25/18	Kelli O'Brien	deg F	65
18	32.2	1/25/18	Kelli O'Brien	deg F	65
19	32.2	1/26/18	Brian Vinal	deg F	68
20	32.0	1/26/18	Brian Vinal	deg F	68
21	32.0	1/26/18	Brian Vinal	deg F	68
22	32.1	1/26/18	Kelli O'Brien	deg F	68
23	32.0	1/26/18	Kelli O'Brien	deg F	68
24	32.0	1/26/18	Kelli O'Brien	deg F	68
25	31.6	1/26/18	Brian Vinal	deg F	65
26	31.8	1/26/18	Brian Vinal	deg F	65
27	31.5	1/26/18	Brian Vinal	deg F	65
28	31.8	1/26/18	Kelli O'Brien	deg F	65
29	31.6	1/26/18	Kelli O'Brien	deg F	65
30	31.6	1/26/18	Kelli O'Brien	deg F	65

PARAMETER / EQUIPMENT : UNIT UNDER TEST : RANGE :	K type Sample Sensors (A24, A 25, A26, A27, A28, A29, A30) LTP -000005 32- 124 deg F	Prepared By : Kelli O'Brien 05 Feb 2018						
NOMINAL :	124 deg F Units	Reviewed By: Kelli O'Brien 05 Feb 2018						
REFERENCE STANDARDS	Manufacturer - Model Thermoworks PT 100	Description RTD	ID # REF-1	Cal Intvl 1 Yr	Cal Exp. Date 20-Dec-18			
TYPE A DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	MULT	STD UNC	VARIANCE
1 Repeatability and Reproducibility	1.6104930	deg F	1	Normal	41	1.012367001	1.630410	2.658236534
TYPE B - FIXED VALUE DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	DIV	STD UNC	VARIANCE
1 Test thermocouple Readout	0.05000	deg F	1	Rect	1E+01	1.732	0.028888	0.000833362
2 Reference Standard Uncertainty	0.10000	deg F	1	Normal	1E+00	2	0.050000	0.002500000
3 Reference Standard Stability	0.01980	deg F	1	Normal	1E+00	1	0.019800	0.000392040
4 Reference Standard Readout	0.00500	deg F	1	Rect	1E+02	1.732	0.002887	0.000008334
5 Temperature Influence	0.00000	deg F	1	Normal	1E+02	1	0.000000	0.000000000
6								
TYPE B - VARIABLE VALUE DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	DIV	STD UNC	VARIANCE
Combined Uncertainty							1.63155456	deg F
Expanded Uncertainty k=2							3.26310912	deg F

Sanity check	100%
	0%
	0%
	0%
	0%
	0%
2.661970290	Ttl Var

NOTES :
A1 Repeatability and Reproducibility from data below

- B1 Resolution of the device under test, divided by 2
- B2 Uncertainty from calibration cert.#13107194 (Tektronix)
- B3 Stability from calibration cert.#13107194 (Tektronix)
- B4 Resolution of the device under test, divided by 2
- B5
- B6
- B7
- B8
- B9
- B10
- B11
- B12

Type A Data

LINE No. : 1
 BUDGET DESCRIPTION : Repeatability and Reproducibility
 UNITS : deg F

1.6104930
 41 STANDARD DEVIATION (in Units)
 EFFECTIVE DEGREES OF FREEDOM

#of Rdgs	VALUE	DATE	TECH #	TEMP	ROOM TEMP deg F
1	124.1	1/23/18	Brian Vinal	deg F	68
2	124.3	1/23/18	Brian Vinal	deg F	68
3	124.1	1/23/18	Brian Vinal	deg F	68
4	123.3	1/23/18	Kelli O'Brien	deg F	68
5	123.6	1/23/18	Kelli O'Brien	deg F	68
6	124.0	1/23/18	Kelli O'Brien	deg F	68
7	127.1	1/23/18	Brian Vinal	deg F	66
8	127.1	1/23/18	Brian Vinal	deg F	66
9	127.1	1/23/18	Brian Vinal	deg F	66
10	127.4	1/23/18	Kelli O'Brien	deg F	66
11	127.2	1/23/18	Kelli O'Brien	deg F	66
12	127.1	1/23/18	Kelli O'Brien	deg F	66
13	123.1	1/25/18	Brian Vinal	deg F	65
14	123.5	1/25/18	Brian Vinal	deg F	65
15	123.2	1/25/18	Brian Vinal	deg F	65
16	124.4	1/25/18	Kelli O'Brien	deg F	65
17	124.0	1/25/18	Kelli O'Brien	deg F	65
18	124.2	1/25/18	Kelli O'Brien	deg F	65
19	127.0	1/26/18	Brian Vinal	deg F	68
20	126.8	1/26/18	Brian Vinal	deg F	68
21	127.0	1/26/18	Brian Vinal	deg F	68
22	127.0	1/26/18	Kelli O'Brien	deg F	68
23	127.0	1/26/18	Kelli O'Brien	deg F	68
24	127.2	1/26/18	Kelli O'Brien	deg F	68
25	123.2	1/26/18	Brian Vinal	deg F	65
26	123.2	1/26/18	Brian Vinal	deg F	65
27	123.2	1/26/18	Brian Vinal	deg F	65
28	123.4	1/26/18	Kelli O'Brien	deg F	65
29	123.2	1/26/18	Kelli O'Brien	deg F	65
30	123.4	1/26/18	Kelli O'Brien	deg F	65
31	124.4	1/26/18	Brian Vinal	deg F	65
32	124.3	1/26/18	Brian Vinal	deg F	65
33	124.4	1/26/18	Brian Vinal	deg F	65
34	124.0	1/26/18	Kelli O'Brien	deg F	65
35	124.5	1/26/18	Kelli O'Brien	deg F	65
36	124.5	1/26/18	Kelli O'Brien	deg F	65
37	126.6	1/29/18	Brian Vinal	deg F	65

PARAMETER / EQUIPMENT : **K type Unit Stack Sensors (A07, A32)** Prepared By :
 UNIT UNDER TEST : **LTP -000005** Kelli O'Brien
 RANGE : **32- 400 deg F** 06 Feb 2018

NOMINAL : 32 deg F
Units

Reviewed By:
 Kelli O'Brien
 06 Feb 2018

REFERENCE STANDARDS & ANCILLARY EQUIPMENT

Manufacturer - Model	Description	ID #	Cal Intvl	Cal Exp. Date
Thermoworks PT 100	RTD	REF-1	1 Yr	20-Dec-18

TYPE A DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	MULT	STD UNC	VARIANCE
1 Repeatability & Reproducibility	0.2587148	deg F	1	Normal	11	1.04759136	0.271027	0.073455831

TYPE B - FIXED VALUE DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	DIV	STD UNC	VARIANCE
1 Test thermocouple Readout	0.05000	deg F	1	Rect	1E+01	1.732	0.028868	0.000833382
2 Reference Standard Uncertainty	0.05000	deg F	1	Normal	1E+00	2	0.025000	0.000625000
3 Reference Standard Specification	0.01980	deg F	1	Normal	1E+00	1	0.019800	0.000392040
4 Reference Standard Readout	0.00500	deg F	1	Rect	1E+02	1.732	0.002887	0.000083334
5 Temperature Influence	0.00000	deg F	1	Normal	1E+02	1	0.000000	0.000000000
6								

TYPE B - VARIABLE VALUE DESCRIPTION	UNCERT	UNITS	SENS	DIST	DEG	DIV	STD UNC	VARIANCE
Combined Uncertainty 0.27443503 deg F Expanded Uncertainty k=2 0.54887006 deg F								

NOTES :

- A1 Repeatability and Reproducibility from data below

- B1 Resolution of the device under test, divided by 2
- B2 Uncertainty from calibration cert #13107194 (Tektronix)
- B3 Stability from calibration cert #13107194 (Tektronix)
- B4 Resolution of the device under test, divided by 2
- B5
- B6
- B7
- B8
- B9
- B10
- B11
- B12

Type A Data

LINE No. : 1
 BUDGET DESCRIPTION : Repeatability and Reproducibility
 UNITS : deg F

0.2587148
11

STANDARD DEVIATION (in Units)
 EFFECTIVE DEGREES OF FREEDOM

# of Rdgs	VALUE	DATE	TECH #	TEMP deg F	ROOM TEMP deg F
1	32.9	1/22/18	Brian Vinal	deg F	66
2	32.7	1/22/18	Brian Vinal	deg F	66
3	33.0	1/22/18	Brian Vinal	deg F	66
4	32.6	1/22/18	Kelli O'Brien	deg F	66
5	32.6	1/22/18	Kelli O'Brien	deg F	66
6	32.9	1/22/18	Kelli O'Brien	deg F	66
7	32.8	1/22/18	Brian Vinal	deg F	66
8	32.7	1/22/18	Brian Vinal	deg F	66
9	33.1	1/22/18	Brian Vinal	deg F	66
10	33.3	1/22/18	Kelli O'Brien	deg F	66
11	33.1	1/22/18	Kelli O'Brien	deg F	66
12	32.4	1/22/18	Kelli O'Brien	deg F	66



Calibration complies with ISO/IEC 17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4096-8014959

Traceable® Certificate of Calibration for Digital Humidity/Temp. Meter

Instrument Identification:

Model: 4096 S/N: 160816582 Manufacturer: Control Company

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Chilled Mirror Hygrometer	31874/H2048MCR	10/12/16	13366
Digital Thermometer	140156093	3/08/17	4000-7479903

Certificate Information:

Technician: 104 Procedure: CAL-17 Cal Date: 10/03/16 Due Date: 10/03/18
Test Conditions: 23.4°C 52.0 %RH 1015 mBar

Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
%RH		N.A.		46.66	46	Y	43	51	1.3	3.1:1
°C		N.A.		24.465	24	Y	23	25	0.59	1.7:1

This instrument was calibrated in compliance with ISO/IEC 17025:2005 and ANSI/NCSL Z540-1-1994 Part 1.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

The calibration results published in this certificate were obtained using equipment capable of producing results that are traceable to NIST and through NIST to the International System of Units (SI).

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Judlos
Aaron Judlos, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Digital Humidity/Temp. Meter should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Humidity/Temp. Meters change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

This device was calibrated using a single test point. Should additional test points be required, please contact Control Company for factory calibration and re-certification traceable to National Institute of Standards and Technology.

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2008-AQ-HOU-RuA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).

CERTIFICATE OF CALIBRATION

CUSTOMER:	CLEAR STAK PUTNAM CT	CALIBRATION DATE:	01/16/18
PO NUMBER:	KELLI O'BRIEN	CALIBRATION DUE:	01/16/19
INST. MANUFACTURER:	NUTECH	PROCEDURE:	NAVAIR 17-20MG-02
INST. DESCRIPTION:	AIR SAMPLER/ STACK SAMPLER	CALIBRATION FLUID:	AIR @ 14.7 PSIA 70 F
MODEL NUMBER:	2010A GRASEBY ANDERSEN (2010.00)	STANDARD(S) USED:	A4, A24 DUE 06-2020
SERIAL NUMBER:	80994	NIST TRACE #'S:	1446135470, 1453926155
RATED UNCERTAINTY:	+/- 1 % RD.	AMBIENT CONDITIONS:	768 mm HGA 53 % RH 70 F
UNCERTAINTY GIVEN:	TOTAL measurement uncertainty: +/- .190 % RD, K=2	CERTIFICATE FILE #:	471997.18

NOTES: AS RECEIVED/ AS LEFT WITHIN SPECS. REFERENCE CONDITIONS ARE: 760 mm HGA 70 F


TEST POINT NUMBER	UUT		CORRECTION FACTOR	DM.STD.	
	INDICATED	PD.METER		INDICATED	PD.METER
1	5.0184	5.05	1.0063	1	1.00
2	19.9561	20.07	1.0057	4	4.00
3	35.0990	35.26	1.0046	6	6.00
4	49.7961	49.95	1.0031	8	8.00
5	64.8916	65.04	1.0023	10	10.00
6	79.6649	79.87	1.0026	GAUGE	
7	95.0355	95.32	1.0030	"HG VAC.	
8	109.7648	110.13	1.0033	0-30	0-30
AVERAGE			1.00386	TEMPERATURE	
				F DEG.	F DEG.
				70	70.04

All instruments used in the performance of the shown calibration have traceability to the National Institute of Standards and Technology (NIST). The uncertainty ratio between the calibration standards (DM.STD.) used and the unit under test (UUT) is a minimum of 4:1, unless otherwise noted. Calibration has been performed per the shown procedure number, in accordance with ISO 10012:2003, ISO 17025:2005, ANSI/NCSL-Z-540.3, and/or MIL-STD-45662A. Test methods: API2530-92 & ASME MFC-3M-1989.

Dick Munns Company • 11133 Winners Circle • Los Alamitos, CA 90720
Phone (714) 827-1215 • Fax (714) 827-0823

This Calibration Certificate shall not be reproduced, copied, or fully without approval by DICK MUNNS COMPANY. The data shown applies only to the instrument being calibrated and under the stated conditions of calibration.

Date: 1/16/2018

Approved By: 

Calibration Technician: 

CERTIFICATE OF CALIBRATION

CUSTOMER:	CLEAR STAK PUTNAM CT	CALIBRATION DATE:	01/16/18
PO NUMBER:	KELLI O'BRIEN	CALIBRATION DUE:	01/16/19
INST. MANUFACTURER:	NUTECH	PROCEDURE:	NAVAIR 17-20MG-02
INST. DESCRIPTION:	AIR SAMPLER/ STACK SAMPLER	CALIBRATION FLUID:	AIR @ 14.7 PSIA 70 F
MODEL NUMBER:	2010A GRASEBY ANDERSEN (MST-C1)	STANDARD(S) USED:	A4, A24 DUE 06-2020
SERIAL NUMBER:	90389	NIST TRACE #'S:	1446135470, 1453926155
RATED UNCERTAINTY:	+/- 1 % RD.	AMBIENT CONDITIONS:	768 mm HGA 53 % RH 70 F
UNCERTAINTY GIVEN:	TOTAL measurement uncertainty: +/- .190 % RD. K=2	CERTIFICATE FILE #:	471998.18
NOTES:	AS RECEIVED/ AS LEFT WITHIN SPECS. REFERENCE CONDITIONS ARE: 760 mm HGA 70 F		

TEST POINT NUMBER	UUT	DM.STD.	CORRECTION FACTOR	UUT	DM.STD.
	INDICATED SCFH	ACTUAL SCFH		INDICATED INCH H2O PRESS	ACTUAL INCH H2O PRESS
1	4.9538	4.98	1.0053	1	1.00
2	19.8253	19.91	1.0043	4	4.00
3	35.0441	35.15	1.0030	6	6.00
4	49.8708	49.96	1.0018	8	8.00
5	64.8846	65.02	1.0021	10	10.00
6	79.6649	79.87	1.0026	GAUGE	GAUGE
7	94.8892	95.21	1.0034	"HG VAC.	"HG VAC.
8	109.5745	109.92	1.0032	0-30	0-30
		AVERAGE	1.00320	TEMPERATURE	TEMPERATURE
				F DEG.	F DEG.
				73	73.03

All instruments used in the performance of the shown calibration have traceability to the National Institute of Standards and Technology (NIST). The uncertainty ratio between the calibration standards (DM.STD.) used and the unit under test (UUT) is a minimum of 4:1, unless otherwise noted. Calibration has been performed per the shown procedure number, in accordance with ISO 10012:2003, ISO 17025:2005, ANSI/NCSSL-Z-540.3, and/or MIL-STD-45662A. Test methods: API2530-92 & ASME MFC-3M-1989.

Dick Munns Company • 11133 Winners Circle • Los Alamitos, CA 90720
Phone (714) 827-1215 • Fax (714) 827-0823


This Calibration Certificate shall be the property of Dick Munns Company. It is loaned to you for your use only. It is to be returned to Dick Munns Company. The data shown applies only to the instrument being calibrated and under the stated conditions of calibration.

Date:

Approved By:

Calibration Technician:

1/16/2018






Calibration
Certificate No. 1750.01

Calibration complies with ISO 9001
ISO/IEC 17025 AND ANSI/NCSL Z540-1



Cert. No.: 1333-8847784

Traceable® Certificate of Calibration for Kaleidoscope Stopwatch

Manufactured for and distributed by: Fisher Scientific, 300 Industry Drive, Pittsburgh, PA 15275-1001

Instrument Identification:

Model Numbers: 14-649-53, 11526893 S/N: 170684205 Manufacturer: Control Company

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Non-contact Frequency Counter	26.6 2025	3/27/18	1000406563

Certificate Information:

Technician: 150 Procedure: CAL-01 Cal Date: 10/02/17 Due Date: 10/02/19
Test Conditions: 24.2°C 68.0 %RH 1013 mBar

Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
Sec/24hr		N.A.		0.000	1.400	Y	-8.640	8.640	0.037	>4:1

This instrument was calibrated using instruments traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contain herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=(Max-Min)/2; Min = Nominal/Rounded; Max = Nominal/Rounded + Tolerance; Date=MM/DD/YY

Neil Rodriguez
Neil Rodriguez, Quality Manager

Aaron Judon
Aaron Judon, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Kaleidoscope Stopwatch should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Kaleidoscope Stopwatches change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by DNV GL, Certificate No. CERT-01805-2008-AD-HOU-RvA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).

Traceable® is a registered trademark of Control Company



WORCESTER SCALE CO., INC.

N.L.S.T. Traceability Numbers: 41867 & 822/255592-95 an ISO/IEC 17025 Registered Company - Cert # AC1266

Page 1 of 1
Report Date: 01/03/2018
228 Brooks St., Higgins Industrial Park
Worcester, Mass. 01606
P: (508) 853-2888
F: (508) 853-2902
www.worcescale.com

Certificate of Calibration

Customer: ClearStak
Address: 99 Canal Street
City, State, Zip: Putnam, CT, 06260-0109
Attention: Kelli O'Brien

Test Number: 44793
Test Date: 01/03/2018
Calibration Due: 07/2018

Measurement Uncertainty: $\mu = 0.026\%$

Equipment Tested: Description: Digital Floor Scale (Class III)
Manufacturer: Sartorius
Capacity: 1,000 lb
Condition as Found: Good
Keyboard Functions: Pass

Model: MI S20R-V2
Division: .02 lb
Temperature: 66 °F
Repeatability: Pass
Humidity: 24 %
Decreasing Load: Pass

ID: 33166427
Calibration: On Site
W.S. Shop: <
Shift Test: Pass

Test Results:

Test Load	Readings as Found	Readings as Left	+/- Tolerance per HB-44
0.00 lb	0.00 lb	0.00 lb	.10 lb
100.00 lb	100.00 lb	100.00 lb	.20 lb
200.00 lb	200.02 lb	200.00 lb	.20 lb
300.00 lb	300.00 lb	300.00 lb	.30 lb
400.00 lb	400.02 lb	400.00 lb	.30 lb
500.00 lb	500.02 lb	500.00 lb	.50 lb
600.00 lb	600.02 lb	600.02 lb	.50 lb
700.00 lb	700.00 lb	700.02 lb	.50 lb
800.00 lb	800.02 lb	800.04 lb	.50 lb
900.00 lb	900.02 lb	900.04 lb	.50 lb
1,000.00 lb	1,000.02 lb	1,000.04 lb	.50 lb

* Denotes out of tolerance

Remarks: Tested, and certified final readings.

Standards Used: 11,27,29,33,45,52,70,83,88,96,305,308,318,320,330,726,753,768,770,828

Tested By: Mark Houseman

Technician (S) *MH*

Approved By: *[Signature]*

Service Manager

This certificate attests that the above stated instrument has been calibrated with standards traceable to the National Institute of Standards and Technology (NIST). Certificates of traceability are on file at Worcester Scale Company, Inc. Calibration procedures reference WSC-609 and manufacturer's service manuals. The calibration was performed in compliance with all applicable requirements of ISO/IEC 17025:2015. Computed uncertainties refer to WSC's Laboratory Accreditation Documents (reference Certificate AC-1266 for results). Test methods and tolerance requirements are found in the current edition of HB-44, section 2 (scale code manual). Any deviation from these should be noted in remarks section of this report. Due to numerous conditions that may affect calibration, this certificate attests only to the status of the tested equipment at the time of the test and/or calibration procedures. No sampling was performed during this calibration. Measurement Uncertainty is expressed at a 95% confidence level with a coverage factor of k=2.



This report is not to be reproduced, except in full, without written approval of Worcester Scale Co., Inc.
SALES • SERVICE • DESIGN • ENGINEERING • RENTALS • INSTALLATIONS • INSPECTIONS
SPECIALIZING IN . . . INDUSTRIAL ELECTRONIC & MECHANICAL WEIGHING EQUIPMENT & SYSTEMS,
FORCE MEASURING INSTRUMENTS
FOR NEW ENGLAND INDUSTRY SINCE 1948

WSC-064F





Certificate of Calibration



13043549

Certificate Page 1 of 1

CALIBRATION CERT #2357.08

Instrument Identification

Company ID: 1087
CLEARSTAK
KELLI OBRIEN
99 CONAL STREET
PUTMAN, CT 06260

PO Number: CS17120

Instrument ID: **50155**
Manufacturer: TROEMNER
Description: 2 KG WEIGHT

Model Number: 2 KG CLASS F
Serial Number: 50155

Class F

Certificate Information

Reason For Service: CALIBRATION
Type of Cal: ACCREDITED 17025 WITH UNCERTAINTIES
As Found Condition: IN TOLERANCE
As Left Condition: IN TOLERANCE
Procedure: 375A1053CSP REV G
Remarks: *DATA REPORT ATTACHED*

Technician: THOMAS HRYNUK
Cal Date 30Nov2017
Cal Due Date: 30Nov2018
Interval: 12 MONTHS
Temperature: 19.0 C
Humidity: 43.0 %

Tektronix certifies the performance of the above instrument has been verified using test equipment of known accuracy, which is traceable to a National Standards Laboratory (NIST, NPL, PTB). The policies and procedures used comply with ISO/IEC 17025:2005. This certificate shall not be reproduced, except in full, without the written approval of the calibration facility. Reported uncertainties are expanded uncertainties expressed at approximately the 95% confidence level using a coverage of $k=2$.

This certificate and associated attachments relate only to the metrological quantities presented in this report. No representation is made about the long-term stability of this unit. Any number of factors can influence the calibration that may cause the unit to drift out of specification before the calibration interval has expired.

This certificate shall not be reproduced, except in full, without the written permission of Tektronix. Data Report Attached.

Approved By: THOMAS HRYNUK
Service Representative

Issue Date: 11/30/2017

Calibration Standards

NIST Traceable#	Inst. ID#	Description	Manufacturer	Model	Cal Date	Date Due
11940192	1700415	WEIGHT SET	RICE LAKE WEIGHIN	45900	05Dec2016	05Dec2017
12060729R2	H046992	MASS COMPARATOR	METTLER TOLEDO	PR2004	25Jan2017	25Jan2018

Certificate Number: 13043549

Manufacturer: Troemner
 ID / Asset Number: 50155
 Class: F

Model Number: 2 KG CLASS F
 Calibration Date: 11/30/2017

Function / Range	Nominal Value	As Found	Result	As Left	Result	Min	Max	Units	Uncertainty
Mass Accuracy									
2000.0000	2000.0000	2000.0521	Pass	2000.0521	Pass	1999.8000	2000.2000	g	1.0 mg

Accredited Calibration Datasheets may contain measurements that are not covered by the Scope of Accreditation. These measurements are indicated by a pound sign (#).
 Measurements with an (*) indicates an Indeterminate Guardband Pass or Fail - Guardbanding is determined by the Measurement Uncertainty Method

*****END OF MEASUREMENT REPORT*****



ATTN: QUALITY ASSURANCE
MCMASTER-CARR SUP CO
200 NEW CANTON WAY
ROBBINSVILLE, NJ. 08691-2345

August 7, 2017

STANDARD LETTER of CERTIFICATION

THIS IS TO CERTIFY THAT THE ITEM LISTED BELOW MEETS THE REQUIREMENTS OF ACCURACY OF THE APPLICABLE SPECIFICATION ON DATE OF SHIPMENT.

STANDARDS AND EQUIPMENT USED FOR INSPECTION ARE CERTIFIED ACCURATE WITH REFERENCE TO 68 DEGREES F, TRACEABLE TO MASTER STANDARDS AT THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY, GAITHERSBURG, MD. CALIBRATION IS PERFORMED WITH TRANSFER STANDARDS WHICH ARE PROGRESSIVELY MORE ACCURATE IN THE ORDER OF 4: 1.

WE ATTEST THAT OUR MEASURING AND TEST EQUIPMENT, AND CALIBRATIONS PERFORMED ON THE ITEM (S) LISTED BELOW, ARE IN ACCORDANCE WITH ISO 17025, ISO GUIDE 25, ANSI/NCSL Z540-1, MIL-STD-45662A.

YOURS VERY TRULY,
THE L. S. STARRETT COMPANY

Susan Madex (you)
DEXTER J. CARLSON,
CHIEF INSPECTOR

YOUR ORDER NO.:	KA-86905640
STARRETT ORDER NO.:	2649825
CATALOG NO.:	KTX12-12-N ENGLISH MEASURING TAPE
SERIAL NO.:	17308312
N.I.S.T. TEST NO.:	683/282436
SPECIFICATION:	GGG-T-106F
ACCURACY:	$\pm 1/32"$ for the first 12 Feet, $\pm 1/16"$ for the remainder

The estimated uncertainties reflect a Confidence Probability of approximately 95%.
This Certificate or Report shall not be reproduced except in full, without the written approval of the Chief Inspector of The L.S. Starrett Company.

PAGE 1 OF 1

PRECISION TOOLS • GAGES • SAW BLADES • HAND TOOLS • CUSTOM
MEASURING SOLUTIONS • OPTICAL AND VISION MEASURING SYSTEMS •
TEST AND MEASUREMENT EQUIPMENT

The L.S. Starrett Company
121 Crescent Street
Athol, MA 01331-1915 • USA
Tel.: 978 249-3551 / Fax: 978 249-8495
www.starrett.com

hcf

LETTER OF CERTIFICATION

December 6, 2017

Clearstak, LLC
99 Canal Street
Putnam, CT 06260


Subject: Moisture Meter Model: J-2000, Serial No: 42318

This is to certify that the primary calibration - electrical resistance - of the Delmhorst Moisture Meter referenced above has been tested on equipment whose accuracy is certified by the following equipment:

General Radio Bridge, Model No. 1644-A, S/N 2526
Keithley Multimeter, Model No. 197, S/N 283483

The calibration of these instruments, certified by Industrial Process Measurement, Inc. with Report No. 66366-01, dated December 29, 2016 and Report No. 66366-02, dated December 28, 2016, is traceable to the NIST.

Sincerely,



John C. Laurenzi
V.P. Manufacturing

JCL: AA

**CALIBRATION VERIFICATION FOR
WOOD MOISTURE METERS**


Customer Name: Clearstak, LLC

Model #: J-2000

Serial #: 42318

Date: 12/6/17

Nominal Settings At Factory	INCOMING	OUTGOING
7.0 +/- 0.5	7.1	7.1
10.0 +/- 0.5	10.0	10.0
15.0 +/- 0.5	15.1	15.1
20.0 +/- 0.5	19.9	19.9
25.0 +/- 0.5	24.7	24.6
30.0 +/- 0.5	30.1	30.1



John C. Laurenzi
VP Manufacturing

Rev. 11/07

CSL-00010

Appendix C

Test ID	Technician	Date	Start Time	End Time	Barometric Pressure	Room Temperature	Relative Humidity	Saturation Pressure	Actual Fan Speed for Test (Hz)	Pre Test Pitot	Leak Rate (15 seconds)	Static Pressure in Appliance (no DT)	Static Pressure in Appliance (DT)	Difference	Diameter of Tunnel (in)	Static Pressure in Dilution Tunnel (beginning)	Point	% of Diameter	Distance (inches)	Delta P (in water)	Temperature (F)	Delta P (in water)	Temperature (F)
1	CSL-00010																						
2	BV, KO'B																						
3		3/5/18																					
4			10:15																				
5			10:30																				
6				29.7	in Hg																		
7				63	F																		
8				40	%																		
9				0.285	psia																		
10				16	Hz																		
11					in. water																		
12					0 in. water																		
13					0 in. water																		
14					0 in.																		
15					0 in. water																		
16					8 in.																		
17					0 in. water																		
18																							
19																							
20	1																						
21	2				0.536																	0.04	78
22	3				2.0																	0.045	87
23	Center				4.0																	0.055	96
24	4				6.0																	0.06	100
25	5				7.46																	0.065	103
26	6																						
27	Post Test Pitot																						
28	Static Pressure (after test)				0 in. water																		
29	Leak Rate (15 seconds)				0 in. water																		

ISS-1 ΔH@	
ISS-2 ΔH@	

Signature _____

Quality Review _____

CONFIDENTIAL - FOR INTERNAL USE ONLY

PRELIMINARY VELOCITY DETERMINATION

Test ID	CSL-00010
Date	3/5/18

Static Pressure (Pg)	0.000 in W.C.
Pitot Coefficient	0.99 unitless
Gas Molecular Weight (MW) wet	29.0 lb/lb-mole
Diameter of Tunnel	8.000 inches
Dilution Tunnel Cross Sectional Area	0.349 FT ²

POINT	% of Diameter	Distance (inches)	Port A			Port B				
			ΔP (in W.C.)	√ΔP (in W.C.)	Temp (F)	Temp (R)	ΔP (in water)	√ΔP (in W.C.)	Temp (F)	Temp (R)
1			0.000	0.00	0.0	460	0.000	0.00	0.0	460
2	6.7	0.54	0.030	0.17	93.0	553	0.040	0.20	78.0	538
3	25.0	2.00	0.045	0.21	93.0	553	0.045	0.21	87.0	547
Center	50.0	4.00	0.055	0.23	94.0	554	0.055	0.23	96.0	556
4	77.0	6.00	0.065	0.25	94.0	554	0.060	0.24	100.0	560
5	93.3	7.46	0.065	0.25	95.0	555	0.065	0.25	103.0	563
6			0.000	0.00	0.0	460	0.000	0.00	0.0	460
AVERAGE			0.23	AVERAGE	553					

DILUTION TUNNEL CALCULATIONS

Absolute Gas Temperature: $Tst = Ts + 459.67^{\circ}$	Tst = 553 °R
Absolute Gas Pressure: $Ps = Pb + Pg/13.6$	Ps = 29.7 inches Hg
Gas Velocity: $Vs = (85.49) \times Cp \times (avg \sqrt{\Delta P}) \times \sqrt{(Tst \cdot avg / (Ps \cdot Mw))}$	Vs = 15.44 FT/sec
Gas Flow Rate: $Qa = Vs \times 60 \times$ cross sectional area	Qa = 323 ACFM

V_{avg} CALCULATIONS

Absolute Gas Temperature: $Tst = Ts + 459.67^{\circ}$	Tst = 553 °R
Absolute Gas Pressure: $Ps = Pb + Pg/13.6$	Ps = 29.7 inches Hg
Gas Velocity: $Vs = (85.49) \times Cp \times (avg \sqrt{\Delta P}) \times \sqrt{(Tst \cdot avg / (Ps \cdot Mw))}$	Vs = 15.31 FT/sec
Gas Flow Rate: $Qa = Vs \times 60 \times$ cross sectional area	Qa = 321 ACFM

V_{sect} CALCULATIONS

Absolute Gas Temperature: $Tst = Ts + 459.67^{\circ}$	Tst = 555 °R
Absolute Gas Pressure: $Ps = Pb + Pg/13.6$	Ps = 29.7 inches Hg
Gas Velocity: $Vs = (85.49) \times Cp \times (avg \sqrt{\Delta P}) \times \sqrt{(Tst \cdot avg / (Ps \cdot Mw))}$	Vs = 15.93 FT/sec
Gas Flow Rate: $Qa = Vs \times 60 \times$ cross sectional area	Qa = 334 ACFM

METER BOX CALCULATIONS

Proposed Proportional Sampling Rate: PR	1.00
Sample Probe Inside Diameter	.175 inches
Sample Probe Cross Sectional Area	.00017 FT ²

1.0 Fp

	296 SCFM
Psrd	323 ACFM
Pact	14.696 psia
Pstat	14.4 psia
Humidity	0.285 psia
Tact	0.4 %/100
Tstd	522.67 R
	491.67 R

Signature _____

Test ID:	CSL-00010
Date:	3.5.18

Fuel Type	Doug. Fir. Crib
Preburn or Test Fuel Charge	Preburn

Test Fuel Pieces Weight (lbs)	Total Spacer Weight (lbs)	Total Test Fuel Charge Weight
10.50	0.78	11.28

Average Test Fuel MC%	Test Fuel Density	Dry Basis Weight (lbs)	Charcoal Bed Loading Range (lbs)
21.09	25	8.29	2.26 to 2.82

***Test Fuel Loading Density must be between 25-36 lb/ft³ dimension of the firebox length*

Piece Number	Piece Size (in):		Weight (lbs):	Moisture Content			Average MC (%)	Volume		Avg. MC% x Dry Basis Weight
	Length	Width		Height	Moisture #1 (%)	Moisture #2 (%)		Moisture #3 (%)	Cubic Inches	
1	14.50	3.50	1.50	1.38	20.2	20.0	20.13	76.125	0	0.00000
2							#DIV/0!	0	0	0.00000
3							#DIV/0!	0	0	0.00000
4	14.50	3.50	3.50	3.10	20.4	20.9	21.33	177.625	0	0.00000
5	14.50	3.50	3.50	3.48	22.0	21.4	21.80	177.625	0	0.00000
6							#DIV/0!	0	0	0.00000
7	14.50	3.50	1.50	1.26	21.0	21.3	20.90	76.125	0	0.00000
8	14.50	3.50	1.50	1.28	21.4	21.0	21.27	76.125	0	0.00000
9							#DIV/0!	0	0	0.00000
10							#DIV/0!	0	0	0.00000
11							#DIV/0!	0	0	0.00000
12							#DIV/0!	0	0	0.00000
13							#DIV/0!	0	0	0.00000
14							#DIV/0!	0	0	0.00000
15							#DIV/0!	0	0	0.00000
16							#DIV/0!	0	0	0.00000
17							#DIV/0!	0	0	0.00000
18							#DIV/0!	0	0	0.00000
19							#DIV/0!	0	0	0.00000
20							#DIV/0!	0	0	0.00000
21							#DIV/0!	0	0	0.00000
22							#DIV/0!	0	0	0.00000
23							#DIV/0!	0	0	0.00000
24							#DIV/0!	0	0	0.00000
25							#DIV/0!	0	0	0.00000

Total Test Fuel Volume (in³):	583.625
Total Test Fuel Volume (ft³):	0.3377

Technician Signature: 
 Quality Review: 

Number of Spacers	10
Total Spacer Weight (lbs)	0.78
Average Spacer Moisture (%)	14.16

Spacer Number	Piece Size (in)			Moisture Content (%)
	Length	Width	Height	
1	5.00	1.50	0.75	12.6
2	5.00	1.50	0.75	13.6
3	5.00	1.50	0.75	12.0
4	5.00	1.50	0.75	14.8
5	5.00	1.50	0.75	14.3
6	5.00	1.50	0.75	14.8
7	5.00	1.50	0.75	15.0
8	5.00	1.50	0.75	13.8
9	5.00	1.50	0.75	15.6
10	5.00	1.50	0.75	15.1
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

RS
Kelli O'Brien

Test ID:	CSL-00010
Date:	3.5.18

Test Fuel Pieces Weight (lbs)	Total Spacer Weight (lbs)	Total Test Fuel Charge Weight
10.88	0.84	11.72

Fuel Type
Doug. Fir Cribwood
Preburn or Test Fuel Charge
Test Fuel

Average Test Fuel MC%	Test Fuel Density	Dry Basis Weight (lbs)	Charcoal Bed Loading Range (lbs)
22.53	25	8.43	2.34 to 2.93

must be between 19-25% **Test Fuel Loading Density must be between 25-36 lb/ft³ ***Invariable piece length snail closely approximate 5/16 the dimension of the firebox length *Test Fuel Load Range 7lbs +/- 0.7 lbs per ft³*

Piece Number	Piece Size (in):			Weight (lbs):	Moisture Content			Average MC (%)	Volume		Avg. MC% x Dry Basis Weight
	Length	Width	Height		Moisture #1 (%)	Moisture #2 (%)	Moisture #3 (%)		Cubic Inches	Avg. MC% x Dry Basis Weight	
1	14.50	3.50	1.50	1.26	20.8	20.7	23.5	21.67	76.125	0.00000	
2	14.50	3.50	1.50	1.32	22.5	23.1	23.5	23.03	76.125	0.00000	
3	14.50	3.50	1.50	1.28	23.5	23.5	21.0	22.67	76.125	0.00000	
4	14.50	3.50	3.50	3.52	22.6	22.3	23.6	22.83	177.625	0.00000	
5	14.50	3.50	3.50	3.50	23.0	22.0	22.4	22.47	177.625	0.00000	
6								#DIV/0!	0	0.00000	
7								#DIV/0!	0	0.00000	
8								#DIV/0!	0	0.00000	
9								#DIV/0!	0	0.00000	
10								#DIV/0!	0	0.00000	
11								#DIV/0!	0	0.00000	
12								#DIV/0!	0	0.00000	
13								#DIV/0!	0	0.00000	
14								#DIV/0!	0	0.00000	
15								#DIV/0!	0	0.00000	
16								#DIV/0!	0	0.00000	
17								#DIV/0!	0	0.00000	
18								#DIV/0!	0	0.00000	
19								#DIV/0!	0	0.00000	
20								#DIV/0!	0	0.00000	
21								#DIV/0!	0	0.00000	
22								#DIV/0!	0	0.00000	
23								#DIV/0!	0	0.00000	
24								#DIV/0!	0	0.00000	
25								#DIV/0!	0	0.00000	

Total Test Fuel Volume (in³):	583.625
Total Test Fuel Volume (ft³):	0.3377

Technician Signature: 
 Quality Review: 

Number of Spacers	10
Total Spacer Weight (lbs)	0.84
Average Spacer Moisture (%)	17.04

Spacer Number	Piece Size (in)			Moisture Content (%)
	Length	Width	Height	
1	5.00	1.50	0.75	20.9
2	5.00	1.50	0.75	13.2
3	5.00	1.50	0.75	17.6
4	5.00	1.50	0.75	14.2
5	5.00	1.50	0.75	20.9
6	5.00	1.50	0.75	17.0
7	5.00	1.50	0.75	17.8
8	5.00	1.50	0.75	16.0
9	5.00	1.50	0.75	13.7
10	5.00	1.50	0.75	19.1
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

RB-29


Kelli O'Brien


Method 28 Data Collection	
Date	3/5/18
Operator	BV, KO'B
Test Type	Method 28R
Run #	1
Wood Heater Information	
Manufacturer/Model	MF Fire/ Nova
Test ID	CSL-00010
Volume of water in Appliance (gal)	n/a
Weight of Appliance (empty) (lbs)	303.2
Volume of water in Storage (gal)	n/a
Weight of Storage Tank(s) (empty) (lbs)	n/a
Primary Air Setting (Hz)	single burn rate stove
Secondary Air Setting (Hz)	single burn rate stove
Thermostat Setting (F)	n/a
Fuel Type	doug fir crib wood

Velocity Traverse	
Static Pressure (in WC)	0
Vstrav (ACFM)	321
Vscent (ACFM)	334
Pre-Test Conditions	
Desired Flow Rate (load Side) (GPM)	n/a
Pre-test destratification volume pumped (need 2x) (gal)	n/a
Pre-test temperature difference (post destratification) (F)	n/a
Test facility temp at test start (F)	65
Room air velocity (FPM)	8,8,13
Ambient relative humidity (%)	40
Ambient barometric pressure (in Hg)	29.7
Adjustments to pre-test fuel	See Kelvin notes
Coal-bed weight prior to test start (lbs)	2.62

Post-Test Conditions	
Time of TFS ₅₀ (hh:mm) (leave blank if Cat. III or IV)	
room air velocity immediately following run (FPM)	8,12,9
test facility temperature after run (F)	73
ambient relative humidity after run (%)	30
ambient barometric pressure after run (in Hg)	29.7
Weight of unburnt fuel (lbs)	n/a

Note** When inputting data from the logger, the start time of the input must coincide with the start time of the test.

Signature 

Quality Review 

Ambient

Test ID	CSL-00010
Date	3/5/18
Start Time (hh:mm:ss)	11:41
End Time (hh:mm:ss)	14:19
Y (DGM calibration factor)	1.00243
Pre test leak (A cfm @ B in Hg)	0.00 @ 20 in. WC
Post test leak (A cfm @ B in Hg)	0.00 @ 20 in WC

Filter Assemblies		
A	FH #	FH-01,FF-15
	Front Filter #	G-18-0001
	Back Filter #	n/a
B	FH #	
	Front Filter #	
	Back Filter #	

*Pre and Post leak checks should be 60 seconds in duration

Duration (hh:mm:ss)	DGM (m ³)	ΔH (in H ₂ O)
0:00:00	90.8896	4.0
0:10:00	90.9022	4.0
0:20:00	90.9251	4.0
0:30:00	90.9473	3.5
0:40:00	90.9695	3.5
0:50:00	90.9916	3.5
1:00:00	91.0154	3.5
1:10:00	91.0300	3.5
1:20:00	91.0520	3.5
1:30:00	91.0739	3.5
1:40:00	91.0956	3.5
1:50:00	91.1177	3.5
2:00:00	91.1395	3.5
2:10:00	91.1616	3.5
2:20:00	91.1832	3.5
2:30:00	91.2055	3.5
2:38:39	91.2244	3.5
2:50:00		
3:00:00		
3:10:00		
3:20:00		
3:30:00		
3:40:00		
3:50:00		
4:00:00		

Flow (l/min)	ΔP (in H ₂ O)
2.0	0.060
2.0	0.060
2.0	0.050
2.0	0.050
2.0	0.050
2.0	0.060
2.0	0.055
2.0	0.060
2.0	0.060
2.0	0.055
2.0	0.050
2.0	0.050
2.0	0.045
2.0	0.055
2.0	0.055
2.0	0.050
2.0	

Signature *[Handwritten Signature]*
 Quality Review *Kelli O'Brien*

ISS-1

Test ID	CSL-00010
Date	3/5/18
Start Time (hh:mm:ss)	11:41:00
End Time (hh:mm:ss)	14:19:00
Y (DGM calibration factor)	1.004
Pre test leak (A cfm @ B in Hg)	0.00 @ 10 in. Hg
Post test leak (A cfm @ B in Hg)	0.00 @ 5 in. Hg


Filter Assemblies		
A	FH #	FH-2, FH-4, FF-12
	Front Filter #	G-18-0008
	Back Filter #	G-18-0003
B	FH #	
	Front Filter #	
	Back Filter #	

*Pre and Post leak checks should be 60 seconds in duration

PM Sampling Flow may be 0.15-.25 cfm

Duration (hh:mm:ss)	DGM (ft ³)	Δ H (in H ₂ O)
0:00:00	370.395	0.15
0:10:00	373.110	0.15
0:20:00	375.400	0.15
0:30:00	377.842	0.15
0:40:00	380.318	0.15
0:50:00	382.788	0.15
1:00:00	385.218	0.15
1:10:00	387.240	0.15
1:20:00	389.545	0.15
1:30:00	391.985	0.15
1:40:00	394.460	0.15
1:50:00	396.928	0.15
2:00:00	399.362	0.15
2:10:00	401.875	0.15
2:20:00	404.345	0.15
2:30:00	406.777	0.15
2:38:39	408.877	
2:50:00		
3:00:00		
3:10:00		
3:20:00		
3:30:00		
3:40:00		
3:50:00		
4:00:00		

Module In Temp (°F)	Module Out Temp (°F)	Vacuum (in Hg)
64	64	1.0
64	64	1.0
66	64	1.0
67	65	1.0
69	66	1.0
71	67	1.0
72	69	1.0
73	70	1.0
73	70	1.0
73	71	1.0
74	71	1.0
74	72	1.0
75	72	1.0
75	72	1.0
75	73	1.0
74	73	1.0

Signature 

Quality Review 

ISS-2

		Filter Change 1	Filter Change 2	Filter Change 3	
Weight (lbs)					
Elapsed Time Paused (hh:mm:ss)		0:11:41			
Elapsed Time Resume (hh:mm:ss)		0:12:41			
Actual Time Pause (hh:mm:ss)		11:52:41	11:41:00	11:41:00	
Actual Time Resume (hh:mm:ss)		#VALUE!	11:41:00	11:41:00	
Test ID	CSL-00010	Filter Assemblies			
Date	3/5/18	A	FH #	FH-07, FH-06, FF-07	
Start Time (hh:mm:ss)	11:41		Front Filter #	G-18-0004	
End Time (hh:mm:ss)	14:19		Back Filter #	G-18-0005	
Y (DGM calibration factor)	1.0032	B	FH #	FH-09, FH-08, FF-17	
Pre test leak (A cfm @ B in Hg)	0.00 @ 15 in. Hg		Front Filter #	G-18-0006	
Post test leak (A cfm @ B in Hg)	0.00 @ 5 in. Hg		Back Filter #	G-18-0007	
		C	FH #		
			Front Filter #		
			Back Filter #		
Duration (hh:mm:ss)	DGM (ft ³)	ΔH (in H ₂ O)	Module In Temp (°F)	Module Out Temp (°F)	Vacuum (in Hg)
0:00:00	676.882	0.15	68	68	2.0
0:10:00	679.085	0.15	68	68	2.0
0:20:00	681.348	0.15	69	68	2.0
0:30:00	683.844	0.15	70	69	2.0
0:40:00	686.360	0.15	72	70	2.0
0:50:00	688.736	0.15	74	71	2.0
1:00:00	691.120	0.15	74	72	2.0
1:10:00	693.128	0.15	75	73	2.0
1:20:00	695.610	0.15	76	74	2.0
1:30:00	698.098	0.15	76	75	2.0
1:40:00	700.610	0.15	77	75	2.0
1:50:00	703.095	0.15	77	75	2.0
2:00:00	705.578	0.15	77	76	2.0
2:10:00	708.115	0.15	78	76	2.0
2:20:00	710.605	0.15	77	76	2.0
2:30:00	713.100	0.15	77	76	2.0
2:38:39	715.073				
2:50:00					
3:00:00					
3:10:00					

*Pre and Post leak checks should be 60 seconds in duration

PM Sampling Flow may be 0.15-.25 cfm



Handwritten signature

Signature

Handwritten signature: Kelli O'Brien

Quality Review

Test ID:		CSL-00010				
Date:		3/5/18				
ISS# / AS#	Filter / FH ID #	Pre-Weight Avg (g)	Post Weight Avg (g)	Total Catch (g)	Total Catch (mg)	
Ambient	AS-1	G-18-0001	0.1120	0.1122	0.0003	0.250
	AS-1	FF-01	63.6541	63.6538	-0.0003	0.000
ISS 1	ISS-1	G-18-0008	0.1117	0.1166	0.0049	4.900
	ISS-1	G-18-0003	0.1119	0.1116	-0.0003	0.000
	ISS-1	FF-12	63.4965	63.4963	-0.0002	0.000
ISS 2A	ISS-2	G-18-0004	0.1166	0.1209	0.0044	4.350
	ISS-2	G-18-0005	0.1131	0.1131	0.0000	0.000
	ISS-2	FF-7	63.9316	63.9315	-0.0002	0.000
ISS 2B	ISS-2	G-18-0006	0.1119	0.1127	0.0008	0.850
	ISS-2	G-18-0007	0.1170	0.1170	0.0000	0.000
	ISS-2	FF-17	64.2726	64.2726	-0.0001	0.000
n/a	ISS-2				0.0000	0.000
	ISS-2				0.0000	0.000
	ISS-2				0.0000	0.000

Signature 
 Quality Review 

Test ID: CO-00010
 Date: 1/15/18

IS-1										
Test Duration (Minutes)	T	V _{avg}	V _{max}	T _{avg}	T _{max}	V _{avg}	V _{max}	T	T _{avg}	PR
0:00-00										
0:10-00	10	0.077	11.57977	290.9	312.4	0.077	11.58168	311.4732	290.9278	96.83313
0:20-00	20	0.063	11.2571	291.1	311.778	0.142	11.4593	310.8061	291.2056	90.55001
0:30-00	30	0.060	11.09473	291.5	314.3722	0.213	10.93118	311.1	291.7631	100.7532
0:40-00	40	0.070	10.99917	291.7	313.63	0.281	10.94511	311.8939	292.4556	100.5883
0:50-00	50	0.070	11.10706	292.0	313.3722	0.351	11.48801	312.3556	293.2889	96.23176
1:00-00	60	0.060	11.11596	292.4	312.9831	0.420	11.74760	312.4423	294.1222	92.05050
1:10-00	70	0.057	11.18349	292.7	312.9556	0.477	11.74778	312.4497	294.8167	79.54
1:20-00	80	0.065	11.23735	293.0	312.4831	0.542	11.99948	312.399	295.0944	89.55
1:30-00	90	0.069	11.23083	293.2	313.2331	0.611	11.74503	312.3031	295.3331	96.57111
1:40-00	100	0.070	11.18024	293.4	312.13	0.681	11.22027	312.1644	295.5111	101.7524
1:50-00	110	0.070	11.13807	293.6	311.7611	0.751	10.94667	311.9828	295.7889	103.3774
2:00-00	120	0.069	11.05385	293.8	311.7611	0.820	10.66738	311.8472	296.0662	103.764
2:10-00	130	0.071	11.07283	294.0	311.5111	0.893	10.94986	311.6572	296.2956	104.1961
2:20-00	140	0.070	11.0806	294.2	311.2331	0.961	11.47248	311.5206	296.5444	97.56418
2:30-00	150	0.069	11.05534	294.3	310.9	1.030	11.20518	311.3256	296.8444	98.11033
2:38:59	159	0.050	INVALID	Error	311.7611	1.000	10.93280	311.194	Error	INVALID
2:50-00	170	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:00-00	180	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:10-00	190	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:20-00	200	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:30-00	210	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:40-00	220	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:50-00	230	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:00-00	240	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:10-00	250	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:20-00	260	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:30-00	270	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:40-00	280	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:50-00	290	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:00-00	300	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:10-00	310	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:20-00	320	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:30-00	330	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:40-00	340	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:50-00	350	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:00-00	360	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:10-00	370	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:20-00	380	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:30-00	390	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:40-00	400	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:50-00	410	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:00-00	420	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:10-00	430	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:20-00	440	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:30-00	450	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:40-00	460	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:50-00	470	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
8:00-00	480	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
8:10-00	490	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
8:20-00	500	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
8:30-00	510	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
8:40-00	520	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
8:50-00	530	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
9:00-00	540	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
9:10-00	550	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
9:20-00	560	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
9:30-00	570	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
9:40-00	580	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
9:50-00	590	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
10:00-00	600	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
10:10-00	610	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
10:20-00	620	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
10:30-00	630	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
10:40-00	640	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
10:50-00	650	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
11:00-00	660	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
11:10-00	670	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
11:20-00	680	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
11:30-00	690	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
11:40-00	700	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
11:50-00	710	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
12:00-00	720	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID

IS-2										
Test Duration (Minutes)	T	V _{avg}	V _{max}	T _{avg}	T _{max}	V _{avg}	V _{max}	T	T _{avg}	PR
0:00-00										
0:10-00	10	0.06282	11.57977	293.15	311.7056	0.06282	11.58168	311.4732	293.15	96.71772
0:20-00	20	0.064081	11.2571	293.2889	312.4	0.121643	11.4593	310.8061	293.2889	100.0058
0:30-00	30	0.070679	11.09473	293.7056	313.1778	0.197142	10.93118	311.1	293.7056	108.8936
0:40-00	40	0.071245	10.99917	294.4	314.3722	0.268387	10.94511	311.8939	294.4	107.555
0:50-00	50	0.067281	11.10706	295.2333	313.65	0.335568	11.48801	312.3556	295.2333	97.22644
1:00-00	60	0.067507	11.11596	295.7889	313.3722	0.403176	11.74760	312.4423	295.7889	95.5274
1:10-00	70	0.05686	11.18349	296.2056	312.9831	0.460035	11.74778	312.4497	296.2056	82.50485
1:20-00	80	0.07282	11.23735	296.7611	312.9556	0.530318	11.99948	312.399	296.7611	89.46612
1:30-00	90	0.070432	11.23083	297.1778	312.4831	0.60077	11.74503	312.3031	297.1778	100.8801
1:40-00	100	0.071132	11.18024	297.4556	312.2331	0.671902	11.22027	312.1644	297.4556	105.5121
1:50-00	110	0.070167	11.13807	297.5944	312.13	0.742169	10.94667	311.9828	297.5944	106.1624
2:00-00	120	0.070311	11.05385	297.7331	311.7611	0.81276	10.66738	311.8472	297.7331	107.6645
2:10-00	130	0.07184	11.07283	298.0111	311.7611	0.88442	10.94986	311.6572	298.0111	106.903
2:20-00	140	0.070509	11.0806	298.0111	311.5111	0.954929	11.47248	311.5206	298.0111	99.83767
2:30-00	150	0.070651	11.05534	297.8722	311.2331	1.02558	11.20518	311.3256	297.8722	103.9206
2:38:59	159	0.055889	INVALID	Error	310.9	1.081449	10.93280	311.194	Error	INVALID
2:50-00	170	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:00-00	180	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:10-00	190	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:20-00	200	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:30-00	210	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:40-00	220	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
3:50-00	230	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:00-00	240	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:10-00	250	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:20-00	260	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:30-00	270	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:40-00	280	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
4:50-00	290	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:00-00	300	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:10-00	310	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:20-00	320	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:30-00	330	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:40-00	340	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
5:50-00	350	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:00-00	360	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:10-00	370	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:20-00	380	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:30-00	390	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:40-00	400	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
6:50-00	410	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:00-00	420	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:10-00	430	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:20-00	440	Error	INVALID	Error	311.7611	Error	INVALID	311.194	Error	INVALID
7:30-00	450	Error	INVALID	Error	311.7611	Error	INVALID	311.194</		

Test ID	CSL-00010
Date	3/5/18

Module 2			
Variable	Description	Value	Units
	final volume module 2	691.120	cubic feet
	initial volume module 2	676.882	cubic feet
V _{m2}	total gas volume collected (module 2)	14.238	cubic feet
Average ΔH	average delta H over entirety of run	0.15	in water
T _m	average gas meter temperature	68	°F
P _{bar}	barometric pressure	29.7	in Hg
Y	DGM calibration factor	1.003	unitless
K ₁	volume corrected to standard conditions	17.64	°F/(in Hg)
V _{mstd}	volume gas sampled (corrected to standard conditions)	14.1869941	dscf
Total Catch	total catch (raw data)	4.35	mg
C _s	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00030662	g/dscf


Variable
V _{mR}
Average ΔH
T _m
P _{bar}
Y
K ₁
V _{mRstd}
Total Catch
C _R

Total Particulate Matter (based on ISS-2 and AS-1 data)			
C _s	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00030662	g/dscf
C _R	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00021266	g/dscf
Q _{std}	average gas flow rate through dilution tunnel	308.475696	dscf/min
B _{ws}	water vapor in gas stream (assumed) (proportion by volume)	0.02	unitless
v _s	average velocity of gas through dilution tunnel	16.0703576	ft/s
A	cross-sectional area of dilution tunnel	0.349	square ft
T _s	average gas temperature in dilution tunnel	560.32	R
T _{std}	absolute average gas temperature in dilution tunnel	528	R
P _s	average gas static pressure in dilution tunnel	29.7	in Hg
P _{std}	standard absolute pressure	29.92	in Hg
F _p	adjustment factor for center of tunnel pitot tube placement	0.96	unitless
V _{straw}	average gas velocity after multi point pitot traverse	321	ACFM
V _{scnt}	average gas velocity at center of dilution tunnel calculated after pitot tube traverse	334	ACFM
K _p	pitot tube constant	85.49	$\frac{10^6 \text{ sec}^2 (\text{ft})^2}{\text{mole} (\text{in Hg}) ((\text{R}) (\text{in$

Signature





C_p	pitot tube coefficient	0.99	unitless
ΔP_{avg}	average velocity pressure in dilution tunnel	0.06	in H ₂ O
M_s	dilution tunnel dry gas MW (assumed)	29	lb/(lb-mol)
Θ	total sampling time	60.00	min
E_T	total particulate emissions	5.08467369	g

Signature 

Quality Review 

Ambient		
Description	Value	Units
final volume ambient	90.9022	cubic meters
initial volume ambient	90.8896	cubic meters
total gas volume collected (ambient)	0.4450	cubic feet
average delta H over entirety of run	4.00	in water
average gas meter temperature	68.3	°F
barometric pressure	29.7	in Hg
DGM calibration factor	1.002	unitless
volume corrected to standard conditions	17.64	°F/(in Hg)
volume gas sampled (corrected to standard conditions)	0.44699797	dscf
total catch (raw data)	0.09505703	mg
concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00021266	g/dscf

Signature 

Quality Review 

Test ID	CSL-00010
Date	3/5/18

Module 1			
Variable	Description	Value	Units
	final volume module 1	408.877	cubic feet
	initial volume module 1	370.395	cubic feet
V_{col}	total gas volume collected (module 1)	38.482	cubic feet
Average ΔH	average delta H over entirety of run	0.15	in water
T_m	average gas meter temperature	70	°F
P_{bar}	barometric pressure	29.7	in Hg
Y	DGM calibration factor	1.004	unitless
K_1	volume corrected to standard conditions	17.64	R/(in Hg)
V_{total}	volume gas sampled (corrected to standard conditions)	38.2199792	dscf
Total Catch	total catch (raw data)	4.9	mg
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00012821	g/dscf

Module 2			
Variable	Description	Value	Units
	final volume module 2	715.073	cubic feet
	initial volume module 2	676.882	cubic feet
V_{col}	total gas volume collected (module 2)	38.191	cubic feet
Average ΔH	average delta H over entirety of run	0.15	in water
T_m	average gas meter temperature	73	°F
P_{bar}	barometric pressure	29.7	in Hg
Y	DGM calibration factor	1.003	unitless
K_1	volume corrected to standard conditions	17.64	°F/(in Hg)
V_{total}	volume gas sampled (corrected to standard conditions)	37.67267172	dscf
Total Catch	total catch (raw data)	5.2	mg
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.000138031	g/dscf


Ambient			
Variable	Description	Value	Units
	final volume ambient	91.2244	cubic meters
	initial volume ambient	90.8896	cubic meters
V_{col}	total gas volume collected (ambient)	11.8234	cubic feet
Average ΔH	average delta H over entirety of run	3.59	in water
T_m	average gas meter temperature	73.0	°F
P_{bar}	barometric pressure	29.7	in Hg
Y	DGM calibration factor	1.002	unitless
K_1	volume corrected to standard conditions	17.64	°F/(in Hg)
V_{total}	volume gas sampled (corrected to standard conditions)	11.76069129	dscf
Total Catch	total catch (raw data)	0.25	mg
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	2.12573E-05	g/dscf

Total Particulate Matter (based on ISS-2 and AS-1 data)			
Variable	Description	Value	Units
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00013312	g/dscf
C_2	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	2.1257E-05	g/dscf
Q_{dil}	average gas flow rate through dilution tunnel	293.509938	dscf/min
B_{dil}	water vapor in gas stream (assumed) (proportion by volume)	0.02	unitless
V_c	average velocity of gas through dilution tunnel	15.2183847	ft/s
A	cross-sectional area of dilution tunnel	0.349	square ft
T_c	average gas temperature in dilution tunnel	557.67	R
T_{dil}	absolute average gas temperature in dilution tunnel	528	R
P_1	average gas static pressure in dilution tunnel	29.7	in Hg
P_{std}	standard absolute pressure	29.92	in Hg
F_p	adjustment factor for center of tunnel pitot tube placement	0.96	unitless
V_{meas}	average gas velocity after multi-point pitot traverse	321	ACFM
V_{total}	average gas velocity at center of dilution tunnel calculated after pitot tube traverse	334	ACFM
K_p	pitot tube constant	85.49	$\frac{ft \cdot lb}{min \cdot in^2} \cdot \frac{min}{(ft \cdot lb)}$
C_p	pitot tube coefficient	0.99	unitless
ΔP_{vel}	average velocity pressure in dilution tunnel	0.0540625	in H ₂ O
M_c	dilution tunnel dry gas MW (assumed)	29	lb/(lb-mol)
θ	total sampling time	158.00	min
E_T	total particulate emissions	5.18750074	g

Signature 
 Quality Review 

Test ID:	CSL-00010
Date:	3/5/18

Q_{in}	Btu	#DIV/0!	
$Q_{in\ LHV}$		#DIV/0!	
$Q_{in\ Corrected}$	Btu	#DIV/0!	
Q_{Out}	Btu	#VALUE!	(3 sig figs)
Heat Output Rate	Btu/hr	#VALUE!	(3 sig figs)
Load Draw	Btu/hr		0
E_g/MJ	g/MJ	#VALUE!	
$E_{lb/MMBtu}$	lb/MMBtu	#VALUE!	
E_g/kg	g/kg	#REF!	
$E_{g/hr\ (1)}$	g/hr		1.96993699
Θ_1	min		11.68
Θ_2	min	#VALUE!	
Θ_3	min		158.00
Θ_4	hours		0
Θ	hours		2.63
η_{del}	%	#VALUE!	
$\eta_{del\ LHV}$	%	#VALUE!	


Signature 

Quality Review 

E ₁	g	5.08467
E ₂	g	#N/A
E ₃	g	-0.16683
E _{1_g/kg}	g/kg	#REF!
E _{2_g/kg}	g/kg	#N/A
E _{3_g/kg}	g/kg	#N/A
ET	g	5.18750074

Run #		1
Wood Weight	lbs	0.00
Wood Moisture	%DB	#DIV/0!
Min H ₂ O Temp (T2)	°F	157.60

CO ₁	Startup CO emission (g)
CO ₂	Steady State CO emission (g)
CO ₃	End CO emission (g)
COT	Total CO emission (g)

Signature 

Quality Review 

Fill in boxes in light red. Calculated values are yellow.

Measurement Uncertainty for Total Particulate Emissions

	Measured Value	Measurement Uncertainty (+/-)	Units
Sample Filter Catch Average ISS1 and ISS2 (Fc):	0.00505	0.000273205	g
Sample Flow Rate (Qsample):	0.24	0.0024	dscfm
Sampling Duration (theta):	158	0.1	minutes
Background Filter Catch (BGc):	0.00025	0.000273205	g
Background Filter Flow Rate (Qbg):	0.074	0.00074	dscfm
Tunnel Flow Rate (Qstd):	293.5	5.87	dscfm

Number of Total Weighings Required to Find Sample Filter Catch:	3
Number of Total Weighings Required to Find Background Filter Catch:	3

$E_t = (C_s - C_r)Q_{std}(\Theta)$
 $C_s = \text{sample filter catch} / (\text{sample flow rate} * \text{test duration}) \text{ g/dscf}$
 $C_r = \text{room background filter catch} / (\text{sample flow} * \text{test duration}) \text{ g/dscf}$
 $Q_{std} = \text{average dilution tunnel flow rate, dscf/min}$
 $\Theta = \text{sampling time, minutes}$

Calculating MU of Cs	
Cs	0.000133175
Delta Cs/Delta Fc	0.026371308
Delta Cs/Delta Qsample	-0.000554896
Delta Cs/Delta Theta	-8.4288E-07
MU of Cs	7.32731E-06 g

Calculating MU of Cr	
Cr	2.13821E-05
Delta Cr/DeltaBGc	0.085528567
Delta Cr/Delta Qbg	-0.000288948
Delta Cr/Delta Theta	-1.3533E-07
MU of Cr	2.33678E-05 g

Calculating MU of Et	
Et	5.184175113 g
Delta Et/Delta Cs	46373
Delta Et/Delta Cr	46373
Delta Et/Delta Qstd	0.017663288
Delta Et/Delta theta	0.032811235
MU of Et	1.140387964 g

ET =	5.184175113	grams
with a 95% Confidence Interval of:	1.140387964	(+/-) grams

Reporting Period: 03/05/2018 to 03/05/2018

Site Name: SAMPLE

Time of Report: 03/06/18 14:22

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	Z (none)	COND2OUI (Deg_F)	DIL_CO2 (%)	DILRATIO (RATIO)	FILT1OUT (Deg_F)	FILT2OUT (Deg_F)	ROOM_TMI (Deg_F)	TUNL_TMP (Deg_F)	UNIT_WT (lbs)	
3/5/18	9:55	1	60.9		-0.062	62.7	63.9	61.9	63	0.05	Pre burn
3/5/18	9:56	1	60.8		-0.46	62.7	63.8	61.8	62.5	0.04	
3/5/18	9:57	1	60.8		0.327	62.8	63.8	61.6	62.4	0.03	
3/5/18	9:58	1	60.8		-0.155	62.7	63.7	61.6	62.8	0.04	
3/5/18	9:59	1	60.7		-1.287	62.6	63.7	61.6	62.4	0.03	
3/5/18	10:00	1	60.8		0.594	62.6	63.7	61.6	62.5	0.04	
3/5/18	10:01	1	60.8		0.029	62.6	63.7	61.6	62.6	0.04	
3/5/18	10:02	1	61		0.024	62.6	63.7	61.7	63.3	0.05	
3/5/18	10:03	1	61.1		-0.133	62.6	63.7	61.7	63.2	0.04	
3/5/18	10:04	1	61.2		0.611	62.6	63.9	61.7	62.8	0.05	
3/5/18	10:05	1	61		0.687	62.6	63.7	61.7	62.7	0.06	
3/5/18	10:06	1	61		-0.481	62.6	63.7	61.5	64	0.07	
3/5/18	10:07	1	61.1		0.003	62.7	63.8	61.5	63	0.07	
3/5/18	10:08	1	61		0.131	62.7	63.7	61.6	62.1	0.5	
3/5/18	10:09	1	61.1		0.071	62.7	63.8	61.8	63	0.72	
3/5/18	10:10	1	61.1		0.227	62.7	63.7	62	62.8	1.11	
3/5/18	10:11	1	61.1		-0.111	62.7	63.7	62	63	1.49	
3/5/18	10:12	1	61.1		-0.229	62.7	63.8	62.1	62.7	1.42	
3/5/18	10:13	1	61.1		1.985	62.7	63.8	62.2	63	1.4	
3/5/18	10:14	1	60.9		0.036	62.6	63.7	62.2	66.8	1.37	
3/5/18	10:15	1	61.2		3.812	62.7	64	62	65.5	1.26	
3/5/18	10:16	1	61		2.577	62.7	64	62.5	75.2	1.12	
3/5/18	10:17	1	61.3		3.186	62.8	63.9	62.6	81.4	0.98	
3/5/18	10:18	1	61.2		3.281	62.9	64.1	62.8	87.5	3.31	
3/5/18	10:19	1	61.2		3.78	63	64.1	62.8	83.9	11.84	
3/5/18	10:20	1	61.1		4.39	63	64	62.7	79.2	11.88	
3/5/18	10:21	1	61		6.072	63.1	64.3	63	74.2	11.78	
3/5/18	10:22	1	61.3		6.18	63.1	64.2	62.8	75	11.52	
3/5/18	10:23	1	61.3		5.458	63.2	64.3	62.9	79.4	11.27	
3/5/18	10:24	1	61.1		3.918	63.1	64.2	63	90.7	11.08	
3/5/18	10:25	1	61.2		3.709	63.3	64.5	62.8	95.2	10.84	
3/5/18	10:26	1	61.4		6.447	63.3	64.5	63.1	82.9	10.65	
3/5/18	10:27	1	61.4		6.141	63.5	64.9	63.1	86.9	10.45	
3/5/18	10:28	1	61.5		3.551	63.6	64.8	63.4	102.6	10.23	
3/5/18	10:29	1	61.5		3.452	63.6	64.8	63.3	104.9	10.01	
3/5/18	10:30	1	61.5		3.559	63.7	64.8	63.3	105	9.8	
3/5/18	10:31	1	61.5		3.497	63.8	64.9	63.4	106.6	9.6	
3/5/18	10:32	1	61.6		3.608	63.8	64.9	63.6	105.5	9.44	
3/5/18	10:33	1	61.8		3.496	63.9	64.9	63.6	107.6	9.24	
3/5/18	10:34	1	61.8		3.537	64.1	65	63.9	107.6	9.05	
3/5/18	10:35	1	61.8		3.479	64.2	65.7	63.6	107.1	9.32	
3/5/18	10:36	1	62		3.379	64.3	66.1	63.7	107.7	8.61	
3/5/18	10:37	1	62.1		3.221	64.4	66.2	63.7	109.8	8.43	
3/5/18	10:38	1	62.1		3.274	64.4	66.2	64	109	8.26	
3/5/18	10:39	1	62.1		3.212	64.6	66.3	64.2	110	8.06	
3/5/18	10:40	1	62.3		3.292	64.6	66.3	64.2	110	7.86	
3/5/18	10:41	1	62.3		3.163	64.9	66.5	64.2	110.9	7.65	
3/5/18	10:42	1	62.4		3.027	65.1	66.5	64.6	112.9	7.49	
3/5/18	10:43	1	62.4		3.163	65.2	66.4	64.5	112	7.55	
3/5/18	10:44	1	62.6		3.205	65.3	66.6	64.6	109.8	7.1	
3/5/18	10:45	1	62.7		3.454	65.4	66.6	65	106.1	6.97	
3/5/18	10:46	1	62.7		3.402	65.4	66.6	65.3	107	6.95	
3/5/18	10:47	1	62.9		3.472	65.5	66.6	65.3	105.9	6.73	
3/5/18	10:48	1	62.9		3.426	65.7	66.6	65.5	106.1	6.57	
3/5/18	10:49	1	63		3.357	65.8	66.6	65.6	106.6	6.41	
3/5/18	10:50	1	63.1		3.298	65.8	66.7	65.7	107.1	6.29	
3/5/18	10:51	1	63.2		3.312	65.8	66.7	65.8	107.2	6.17	
3/5/18	10:52	1	63.3		3.452	66	66.7	65.8	105.3	6.06	
3/5/18	10:53	1	63.3		3.393	66.1	66.8	66	105.8	5.91	
3/5/18	10:54	1	63.4		3.184	66.1	66.8	66.1	110.5	6.1	
3/5/18	10:55	1	63.7		3.351	66.3	67	66.1	108.4	5.74	
3/5/18	10:56	1	63.8		3.39	66.5	67.1	65.9	105.6	5.5	
3/5/18	10:57	1	63.7		3.337	66.5	67.1	66.3	104.8	5.36	

3/5/18	10:58	1	63.9	3.372	66.5	67	66.7	103.8	5.23	
3/5/18	10:59	1	63.9	3.214	66.5	67	66.6	106.3	5.22	
3/5/18	11:00	1	64	3.113	66.6	67	66.3	111.7	5.17	
3/5/18	11:01	1	64	3.126	66.8	67.2	66.2	113	5.04	
3/5/18	11:02	1	64.1	3.016	66.9	67.2	66.3	116.1	4.92	
3/5/18	11:03	1	64.3	3.13	66.8	67.1	66.3	116.6	4.74	
3/5/18	11:04	1	64.3	3.09	66.9	67.1	66.4	117.5	5.18	
3/5/18	11:05	1	64.4	2.985	67.1	67.4	66.9	117.5	6.15	
3/5/18	11:06	1	64.4	2.972	67.1	67.3	66.9	118.1	6.24	
3/5/18	11:07	1	64.7	3.01	67.2	67.4	67	118.3	6.1	
3/5/18	11:08	1	64.5	3.1	67.2	67.5	66.8	116.7	5.8	
3/5/18	11:09	1	64.5	3.271	67.6	67.7	66.5	111.4	5.57	
3/5/18	11:10	1	64.6	3.133	67.5	67.5	67.1	114.9	5.07	
3/5/18	11:11	1	64.8	3.173	67.7	67.7	67.1	116.1	5.3	
3/5/18	11:12	1	64.7	3.048	67.7	67.7	66.9	117.9	5.11	
3/5/18	11:13	1	64.8	3.004	67.8	67.8	67.2	122.1	5.14	
3/5/18	11:14	1	64.9	3.036	67.8	67.9	67.1	121.4	3.1	
3/5/18	11:15	1	65.2	3.253	68	67.9	67.5	113.1	2.21	
3/5/18	11:16	1	65.3	3.231	68.1	68.1	67.9	111.4	2.94	
3/5/18	11:17	1	65.3	2.979	68.1	68	67.3	114	2.92	
3/5/18	11:18	1	65.3	2.94	68.3	68.1	67.3	116.1	3.22	
3/5/18	11:19	1	65.3	2.974	68.3	68.2	67.5	114.5	3.14	
3/5/18	11:20	1	65.4	2.948	68.2	68.3	66	111.6	2.32	
3/5/18	11:21	1	65.2	2.931	68	68.1	65.8	111.9	3.24	
3/5/18	11:22	1	65.3	3.108	67.8	67.9	65.5	106.5	3.77	
3/5/18	11:23	1	65.1	3.01	68.1	68.2	65.3	104.4	3.7	
3/5/18	11:24	1	65.4	2.944	67.7	67.9	65.4	106.4	4.54	
3/5/18	11:25	1	65.4	2.9	67.4	67.6	65.3	107.6	5.36	
3/5/18	11:26	1	65.3	2.931	67.2	67.4	65.1	110.3	5.2	
3/5/18	11:27	1	65.2	2.988	67.2	67.6	65.2	111.3	5	
3/5/18	11:28	1	65.2	3.013	67.1	67.6	65.4	112.6	4.77	
3/5/18	11:29	1	65	2.988	66.9	67.4	65.3	113.9	4.55	
3/5/18	11:30	1	64.9	2.902	66.9	67.2	65.2	118.4	4.72	
3/5/18	11:31	1	64.8	3.023	66.8	67.1	65.9	117.9	4	
3/5/18	11:32	1	64.6	3.054	67	67.5	66.4	117.1	3.95	
3/5/18	11:33	1	64.6	3.202	67	67.5	66	111.8	3.53	
3/5/18	11:34	1	64.5	3.141	67	67.5	65.2	108.8	3.44	
3/5/18	11:35	1	64.6	3.183	66.8	67.3	65.5	106	3.92	
3/5/18	11:36	1	64.9	3.139	66.9	67.5	65.2	105.2	3.36	
3/5/18	11:37	1	64.8	3.074	66.8	67.3	65.2	108.3	3.26	
3/5/18	11:38	1	64.8	3.117	66.6	67.2	65	108.2	3.2	
3/5/18	11:39	1	64.9	3.138	66.7	67.3	65.6	105.8	2.95	Test Start
3/5/18	11:40	1	63.5	3.22	66.9	68.1	65.1	103.6	2.86	Fuel Consumed, 2.6 lb coal bed
3/5/18	11:41	1	60.5	3.145	68	72.2	65.1	105.1	14.2	11.6
3/5/18	11:42	1	59.7	3.045	68.7	74.4	65.2	110.8	14.23	11.63
3/5/18	11:43	1	59.1	3.329	69.4	75.1	65.3	103.1	14.13	11.53
3/5/18	11:44	1	58.5	3.308	69.8	75.3	65.1	101.2	14.05	11.45
3/5/18	11:45	1	58	3.193	70.2	75.7	64.7	101.1	13.93	11.33
3/5/18	11:46	1	57.7	3.268	70.6	75.9	65.3	100.1	13.86	11.26
3/5/18	11:47	1	57.2	3.283	71.1	76.3	65.9	99.7	13.79	11.19
3/5/18	11:48	1	57.1	3.37	71.5	76.6	66.1	98.1	13.69	11.09
3/5/18	11:49	1	56.9	3.344	72	76.9	65.4	97.2	13.61	11.01
3/5/18	11:50	1	56.7	3.308	72.4	77.2	65.1	96.7	13.51	10.91
3/5/18	11:51	1	56.5	3.232	72.6	77.1	65.2	97.7	13.41	10.81
3/5/18	11:52	1	56.5	3.284	72.7	77.1	65.2	97	13.33	10.73
3/5/18	11:53	1	56.3	3.172	72.8	77.5	65.1	98.2	13.21	10.61
3/5/18	11:54	1	56.2	3.187	72.8	77.4	64.9	97.9	13.08	10.48
3/5/18	11:55	1	56	3.185	72.9	77.6	65.2	98.4	13.01	10.41
3/5/18	11:56	1	55.9	3.133	73.2	78	65.5	99.7	12.9	10.3
3/5/18	11:57	1	56	3.328	73.3	77.9	66.1	98	12.78	10.18
3/5/18	11:58	1	56	3.307	73.5	78.1	66	98	12.68	10.08
3/5/18	11:59	1	56	3.249	73.7	78.3	66.1	98.5	12.57	9.97
3/5/18	12:00	1	55.9	3.306	74.1	78.5	66.4	98.7	12.42	9.82
3/5/18	12:01	1	55.9	3.262	74.4	78.9	66.9	100.2	12.32	9.72
3/5/18	12:02	1	55.7	3.383	74.6	79.2	66.9	99.6	12.18	9.58
3/5/18	12:03	1	55.7	3.219	74.7	79.3	66.6	100.3	12.03	9.43
3/5/18	12:04	1	55.6	3.229	74.8	79.5	66.8	101	11.89	9.29
3/5/18	12:05	1	55.9	3.278	75.3	80	67.2	101.9	11.74	9.14
3/5/18	12:06	1	55.6	3.392	75.6	80.3	67.4	100.9	11.65	9.05
3/5/18	12:07	1	55.9	3.396	75.7	80.3	67.7	101.5	11.43	8.83
3/5/18	12:08	1	55.8	3.311	75.8	80.5	67.8	102.3	11.34	8.74

3/5/18	12:09	1	56.1	3.32	75.9	80.8	68	103.4	11.23	8.63
3/5/18	12:10	1	56.1	3.389	76.4	81.1	67.8	103	11.08	8.48
3/5/18	12:11	1	56.1	3.335	76.5	81.3	68.2	103.6	11.01	8.41
3/5/18	12:12	1	56.1	3.234	76.7	81.5	68.3	103.6	10.78	8.18
3/5/18	12:13	1	56.2	3.354	76.9	81.6	68.8	103.1	10.67	8.07
3/5/18	12:14	1	56	3.139	77.2	81.9	68.4	105.3	10.54	7.94
3/5/18	12:15	1	56.2	3.156	77.5	82.2	68.7	106.2	10.33	7.73
3/5/18	12:16	1	56.1	3.241	77.8	82.5	69	106.1	10.18	7.58
3/5/18	12:17	1	56	3.311	78	82.8	69.2	106.6	10	7.4
3/5/18	12:18	1	56.1	3.349	78	83.1	69.3	107.2	9.87	7.27
3/5/18	12:19	1	56.3	3.321	78.3	83.3	69.3	107.3	9.73	7.13
3/5/18	12:20	1	56.3	3.422	78.5	83.2	69.3	105.7	9.49	6.89
3/5/18	12:21	1	56.2	3.294	78.7	83.4	69.4	107.3	9.28	6.68
3/5/18	12:22	1	56.4	3.232	78.9	83.7	69.7	107.8	9.12	6.52
3/5/18	12:23	1	56.6	3.246	79	83.8	69.8	107.7	8.9	6.3
3/5/18	12:24	1	56.6	3.22	79.1	83.9	70	108.2	8.72	6.12
3/5/18	12:25	1	56.8	3.255	79.2	84	70.1	107.9	8.66	6.06
3/5/18	12:26	1	56.7	3.377	79.4	84	70.8	107	8.5	5.9
3/5/18	12:27	1	56.8	3.499	79.4	83.8	70.6	105.4	8.42	5.82
3/5/18	12:28	1	57	3.526	79.5	84	71.2	105	8.33	5.73
3/5/18	12:29	1	56.8	3.556	79.7	84	71.4	104.4	8.27	5.67
3/5/18	12:30	1	56.9	3.482	79.7	83.8	71.2	104.7	8.19	5.59
3/5/18	12:31	1	56.9	3.488	79.8	83.8	70.7	103.7	8.11	5.51
3/5/18	12:32	1	56.8	3.435	79.9	83.9	71.2	104.2	8.04	5.44
3/5/18	12:33	1	57	3.388	79.8	83.7	71.4	104.3	7.97	5.37
3/5/18	12:34	1	57.1	3.508	79.8	83.7	71.6	103.4	7.93	5.33
3/5/18	12:35	1	57.1	3.437	79.8	83.6	70.9	102.9	7.82	5.22
3/5/18	12:36	1	57.1	3.594	79.8	83.6	71.4	101.9	7.68	5.08
3/5/18	12:37	1	57.1	3.5	79.8	83.6	71.8	103.5	7.62	5.02
3/5/18	12:38	1	57.2	3.537	79.7	83.6	71.8	103.2	7.57	4.97
3/5/18	12:39	1	57.2	3.453	79.6	83.4	71.9	103.3	7.46	4.86
3/5/18	12:40	1	57.3	3.49	79.6	82.5	71.9	102.8	7.35	4.75
3/5/18	12:41	1	58.4	3.36	79	166.3	71.6	103.7	7.2	4.6
3/5/18	12:42	1	59.6	3.384	79	73.8	71.5	103.3	7.14	4.54
3/5/18	12:43	1	58.8	3.31	78.9	73.4	71	103.5	7.05	4.45
3/5/18	12:44	1	58.2	3.249	78.8	73.1	71	104.1	6.99	4.39
3/5/18	12:45	1	57.9	3.434	78.8	73.1	71.1	102.4	6.87	4.27
3/5/18	12:46	1	57.8	3.468	78.8	73.1	71.9	102.3	6.8	4.2
3/5/18	12:47	1	57.5	3.524	78.8	73.1	71.3	101.7	6.76	4.16
3/5/18	12:48	1	57.4	3.268	78.7	73.2	70.6	103.2	6.66	4.06
3/5/18	12:49	1	57.3	3.312	78.7	73.5	71	102.8	6.56	3.96
3/5/18	12:50	1	57.3	3.438	78.8	73.7	71.9	102.6	6.51	3.91
3/5/18	12:51	1	57.4	3.474	78.8	73.9	72.4	102.3	6.46	3.86
3/5/18	12:52	1	57.3	3.346	78.8	74.1	71.7	102.6	6.38	3.78
3/5/18	12:53	1	57.6	3.5	78.9	74.4	71.8	101.6	6.28	3.68
3/5/18	12:54	1	57.6	3.446	78.8	74.4	72	102.3	6.25	3.65
3/5/18	12:55	1	57.6	3.432	79	74.7	71.9	102.4	6.17	3.57
3/5/18	12:56	1	57.5	3.546	78.9	74.9	71.7	101.2	6.08	3.48
3/5/18	12:57	1	57.5	3.486	78.9	75.1	72.4	102.2	6.01	3.41
3/5/18	12:58	1	57.4	3.571	78.7	75.1	72.5	101.5	5.96	3.36
3/5/18	12:59	1	57.6	3.514	79	75.4	72.5	102	5.9	3.3
3/5/18	13:00	1	57.6	3.464	79	75.5	72.5	102	5.84	3.24
3/5/18	13:01	1	57.5	3.387	79.1	75.6	72.3	102.2	5.78	3.18
3/5/18	13:02	1	57.5	3.352	79	75.8	72	101.7	5.71	3.11
3/5/18	13:03	1	57.6	3.395	79	75.8	72.1	101.6	5.65	3.05
3/5/18	13:04	1	57.7	3.389	79.1	76	72.6	102.4	5.59	2.99
3/5/18	13:05	1	57.7	3.454	79.1	76.1	72.3	101.2	5.56	2.96
3/5/18	13:06	1	57.6	3.583	79.1	76	72.9	100.4	5.49	2.89
3/5/18	13:07	1	57.6	3.442	79.1	76.2	72.4	101.1	5.44	2.84
3/5/18	13:08	1	57.7	3.357	78.9	76	72.5	101.5	5.37	2.77
3/5/18	13:09	1	57.6	3.484	79.1	76.4	72.1	100.6	5.34	2.74
3/5/18	13:10	1	57.7	3.538	79.2	76.4	72	99.8	5.3	2.7
3/5/18	13:11	1	57.8	3.496	79.1	76.5	72.3	100.5	5.24	2.64
3/5/18	13:12	1	57.7	3.501	79	76.5	72.3	100.4	5.19	2.59
3/5/18	13:13	1	57.8	3.512	79	76.5	71.8	100.2	5.12	2.52
3/5/18	13:14	1	57.8	3.567	78.9	76.4	71.3	99.2	5.07	2.47
3/5/18	13:15	1	57.8	3.607	79	76.5	72	99.4	5.04	2.44
3/5/18	13:16	1	57.7	3.564	79	76.4	72.2	99.7	4.99	2.39
3/5/18	13:17	1	57.8	3.422	78.9	76.4	72.2	100.1	4.93	2.33
3/5/18	13:18	1	57.7	3.471	78.8	76.6	72.3	99.5	4.87	2.27
3/5/18	13:19	1	57.8	3.581	78.7	76.4	72.7	99.2	4.82	2.22

3/5/18	13:20	1	57.7	3.45	78.7	76.3	72.2	99.6	4.79	2.19
3/5/18	13:21	1	57.7	3.545	78.8	76.4	72.8	99.3	4.72	2.12
3/5/18	13:22	1	57.6	3.587	78.8	76.4	72.4	98.8	4.67	2.07
3/5/18	13:23	1	57.7	3.488	78.7	76.3	72	98.9	4.62	2.02
3/5/18	13:24	1	57.7	3.436	78.8	76.5	72.3	99.5	4.56	1.96
3/5/18	13:25	1	57.9	3.529	78.7	76.3	72.4	98.7	4.52	1.92
3/5/18	13:26	1	57.7	3.469	78.7	76.4	72.4	98.8	4.49	1.89
3/5/18	13:27	1	57.6	3.444	78.7	76.3	71.9	99.1	4.45	1.85
3/5/18	13:28	1	57.6	3.504	78.6	76.3	72.2	98.6	4.39	1.79
3/5/18	13:29	1	57.5	3.63	78.6	76.4	72.3	98	4.34	1.74
3/5/18	13:30	1	57.7	3.501	78.6	76.4	72.4	99.2	4.29	1.69
3/5/18	13:31	1	57.6	3.481	78.8	76.6	72.2	99.3	4.25	1.65
3/5/18	13:32	1	57.7	3.549	78.7	76.5	71.7	98.2	4.23	1.63
3/5/18	13:33	1	57.9	3.593	78.7	76.4	72.1	97.8	4.18	1.58
3/5/18	13:34	1	57.8	3.477	78.7	76.4	72	98.6	4.13	1.53
3/5/18	13:35	1	57.8	3.484	78.7	76.5	72.4	98.8	4.08	1.48
3/5/18	13:36	1	57.8	3.455	78.7	76.4	72.3	98.9	4.05	1.45
3/5/18	13:37	1	57.8	3.481	78.6	76.2	72.4	98.8	4.01	1.41
3/5/18	13:38	1	57.8	3.347	78.5	76.2	72.1	99.2	3.98	1.38
3/5/18	13:39	1	57.9	3.301	78.5	76.1	72.2	99.6	3.94	1.34
3/5/18	13:40	1	57.7	3.604	78.6	76.3	72.6	97.9	3.9	1.3
3/5/18	13:41	1	57.8	3.615	78.6	76.3	72.5	97.9	3.88	1.28
3/5/18	13:42	1	57.9	3.573	78.6	76.4	71.8	97.3	3.83	1.23
3/5/18	13:43	1	57.8	3.554	78.6	76.3	72.2	97.6	3.82	1.22
3/5/18	13:44	1	57.8	3.511	78.5	76.3	71.6	97.7	3.8	1.2
3/5/18	13:45	1	57.8	3.59	78.5	76.2	72.3	97.9	3.76	1.16
3/5/18	13:46	1	57.8	3.721	78.4	76.2	72.2	97	3.71	1.11
3/5/18	13:47	1	57.8	3.644	78.4	76.2	71.9	97.2	3.68	1.08
3/5/18	13:48	1	57.7	3.588	78.4	76.2	72.4	97.8	3.64	1.04
3/5/18	13:49	1	57.8	3.686	78.3	76.2	72.4	97	3.59	0.99
3/5/18	13:50	1	57.7	3.526	78.3	76.2	72.4	98.1	3.6	1
3/5/18	13:51	1	57.8	3.551	78.4	76.2	72.5	97.9	3.54	0.94
3/5/18	13:52	1	57.9	3.558	78.4	76.2	72.1	97.8	3.51	0.91
3/5/18	13:53	1	57.9	3.615	78.3	76.2	72.3	97.3	3.45	0.85
3/5/18	13:54	1	57.8	3.598	78.3	76.1	72.4	97.5	3.43	0.83
3/5/18	13:55	1	57.7	3.541	78.3	76.1	72.3	97.9	3.4	0.8
3/5/18	13:56	1	57.7	3.576	78.2	75.9	72.4	97.4	3.37	0.77
3/5/18	13:57	1	58	3.349	78.3	76.2	71.2	98.1	3.34	0.74
3/5/18	13:58	1	57.8	3.477	78.3	76.1	71	97.1	3.29	0.69
3/5/18	13:59	1	57.8	3.504	78.4	76.2	71.8	97.3	3.28	0.68
3/5/18	14:00	1	57.8	3.615	78.3	76.2	72.1	97	3.23	0.63
3/5/18	14:01	1	57.7	3.702	78.3	76.2	72.2	96.7	3.22	0.62
3/5/18	14:02	1	57.8	3.684	78.2	76.2	72.2	96.8	3.18	0.58
3/5/18	14:03	1	57.7	3.639	78.1	76.2	72.3	96.7	3.12	0.52
3/5/18	14:04	1	57.8	3.611	78.2	76.2	71.8	96.6	3.09	0.49
3/5/18	14:05	1	57.8	3.626	78.1	76.2	71.6	96.4	3.09	0.49
3/5/18	14:06	1	57.9	3.533	78.1	76.1	71	96.3	3.06	0.46
3/5/18	14:07	1	57.8	3.617	77.8	76	71.8	96	3.02	0.42
3/5/18	14:08	1	58	3.693	77.8	76.1	72	95.5	3.01	0.41
3/5/18	14:09	1	57.9	3.639	77.8	76.2	72	95.8	2.99	0.39
3/5/18	14:10	1	58	3.686	77.8	76	72.1	95.9	2.96	0.36
3/5/18	14:11	1	58	3.695	77.8	76	72.2	96	2.93	0.33
3/5/18	14:12	1	58	3.672	77.8	76.1	72	95.6	2.91	0.31
3/5/18	14:13	1	57.8	3.531	77.7	76	72.2	97.1	2.86	0.26
3/5/18	14:14	1	58	3.652	77.7	75.8	72	96.2	2.83	0.23
3/5/18	14:15	1	58	3.601	77.8	76	71.8	96	2.8	0.2
3/5/18	14:16	1	57.8	3.509	77.9	75.9	72.1	96.5	2.76	0.16
3/5/18	14:17	1	58	3.709	77.9	76	72.2	95.6	2.73	0.13
3/5/18	14:18	1	57.9	3.489	77.8	76	71.5	96.3	2.7	0.1
3/5/18	14:19	1	58.7	3.707	77.4	75.9	71.4	94.8	2.65	0

General Average Report

Reporting Period: 03/05/2018 to 03/05/2018

Site Name: UNIT

Time of Report: 03/06/18 14:22

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	CAT_POST (Deg_F)	CO (%)	CO2 (%)	O2 (%)	STK_CSA (Deg_F)	STK_TMP (Deg_F)	
3/5/18	9:55	61.4	0.02	0	22	61.95	61.3	Preburn
3/5/18	9:56	61.5	0.02	0	22	62.2	61.2	
3/5/18	9:57	61.4	0.02	0	22	62.33	61.2	
3/5/18	9:58	61.2	0.02	0	22	62.06	61.2	
3/5/18	9:59	61.4	0.02	0	22	62.06	61.1	
3/5/18	10:00	61.4	0.02	0	22	62.29	61.1	
3/5/18	10:01	61.1	0.02	0	22	62.55	61	
3/5/18	10:02	60.8	0.06	0.7	22	62.34	61	
3/5/18	10:03	61	0.03	-0.1	21.3	62.04	61	
3/5/18	10:04	61.1	0.03	-0.1	14.8	62.14	60.9	
3/5/18	10:05	61.1	0.03	-0.1	8.8	62.35	61	
3/5/18	10:06	60.6	0.02	0	5.4	62.36	61	
3/5/18	10:07	61.2	0	-0.1	8.3	62.11	61.2	
3/5/18	10:08	61.5	0	-0.1	9	62.1	61.3	
3/5/18	10:09	61.1	0	-0.1	5.5	62.52	61.2	
3/5/18	10:10	61	0	0	3.3	62.74	61.2	
3/5/18	10:11	61	0	0	5.2	62.43	61.3	
3/5/18	10:12	61.4	0	0	11.5	62.36	61.4	
3/5/18	10:13	64.4	0	0	15.7	62.62	61.3	
3/5/18	10:14	85.9	0.05	1.9	18.2	67.2	62.3	
3/5/18	10:15	181.7	0.07	2.6	19.5	87.29	71.5	
3/5/18	10:16	459.1	0.08	4.7	19.6	141.07	95.2	
3/5/18	10:17	655	0.16	6.2	19	207.15	122.5	
3/5/18	10:18	682.9	0.06	5.7	17.8	261.14	143.6	
3/5/18	10:19	463.6	0.18	1.8	16.6	254.24	140.6	
3/5/18	10:20	340.6	0.24	2	16.8	225.91	134.3	
3/5/18	10:21	357.5	0.18	2.1	18	217.52	129.2	
3/5/18	10:22	519	0.43	5.3	18.7	232.96	133.5	
3/5/18	10:23	724.6	0.36	8.2	18.6	282.51	151.3	
3/5/18	10:24	813.1	0.24	7.4	16.9	325.84	170.7	
3/5/18	10:25	764.3	0.25	7.5	15.3	352.24	181.8	
3/5/18	10:26	797	0.16	7.4	14.6	372.31	188.2	
3/5/18	10:27	866.4	0.11	7.5	14.2	388.91	196.8	
3/5/18	10:28	874.6	0.08	7.6	14	402.38	202.6	
3/5/18	10:29	847	0.08	6.8	13.8	407.2	206.9	
3/5/18	10:30	814.4	0.08	6.3	13.8	407.63	211.7	
3/5/18	10:31	792.4	0.09	6	14.1	405.62	214.1	
3/5/18	10:32	780	0.08	6.5	14.5	405.92	214.6	
3/5/18	10:33	797.8	0.07	7.1	14.7	411.61	217	
3/5/18	10:34	818	0.06	7.4	14.6	419.31	218.2	

3/5/18	10:35	841.5	0.06	7.4	14.3	426.09	214.5
3/5/18	10:36	831.6	0.07	6.2	14	427.4	211.9
3/5/18	10:37	834.2	0.05	6.8	14.1	427.32	212
3/5/18	10:38	856.5	0.04	7.7	14.3	430.62	210.9
3/5/18	10:39	864.3	0.05	7.1	14.2	435.02	211.3
3/5/18	10:40	859.8	0.05	6.8	13.9	437.25	214.9
3/5/18	10:41	865.3	0.05	6.8	14	437.82	211.8
3/5/18	10:42	879.1	0.05	7	14.1	440.87	210.8
3/5/18	10:43	887	0.05	7.4	14.2	443.1	214.7
3/5/18	10:44	880.2	0.04	7.1	14.1	431.47	209.2
3/5/18	10:45	843.4	0.03	6	13.9	418.67	206.8
3/5/18	10:46	814.1	0.04	5.4	14.2	411	206.5
3/5/18	10:47	814.6	0.05	6	14.7	408.4	206
3/5/18	10:48	847.1	0.05	5.9	15.1	411.03	204.6
3/5/18	10:49	818.5	0.05	5.4	15.1	408.25	203.2
3/5/18	10:50	801.6	0.03	5.8	15.3	403.41	202.2
3/5/18	10:51	802.2	0.03	5.9	15.4	400.67	202.9
3/5/18	10:52	804.4	0.03	5.9	15.3	399.98	202
3/5/18	10:53	802.6	0.02	5.8	15.3	398.97	201
3/5/18	10:54	791.5	0.02	5.5	15.3	403.1	207.2
3/5/18	10:55	868.8	0.03	8.2	15.3	405.09	207.5
3/5/18	10:56	932.6	0.02	8.1	15.1	405.49	200.4
3/5/18	10:57	838.3	-0.01	6.2	14.1	397.9	194.8
3/5/18	10:58	786.8	0	5.6	13.9	388.19	191.7
3/5/18	10:59	767.3	0	5.1	14.4	386.02	193.7
3/5/18	11:00	735	0.02	4.6	15	397.71	207.3
3/5/18	11:01	741.6	0.01	5.2	15.5	407.02	212.3
3/5/18	11:02	752.8	0.01	6	15.8	414.2	216.2
3/5/18	11:03	729.1	0.01	5.3	15.7	417.95	223.5
3/5/18	11:04	700.7	0	4.6	15.5	415.92	224
3/5/18	11:05	651.2	0.05	3.8	15.7	408.4	217.9
3/5/18	11:06	695.1	0.03	4.7	16.2	410.24	218.8
3/5/18	11:07	757.3	0.01	5.3	16.6	416.99	221.3
3/5/18	11:08	832.5	0	6.5	16.6	423.64	221.4
3/5/18	11:09	854.1	0	6.7	16.1	418.28	213.2
3/5/18	11:10	838.4	0	5.5	15.5	420.68	216.5
3/5/18	11:11	854.9	0	6	15.2	431.04	222.3
3/5/18	11:12	825.4	0	6.6	15.5	431.64	222.1
3/5/18	11:13	774.9	0	4.8	15.1	433.85	232.2
3/5/18	11:14	766.2	0	4.9	15.2	433.62	231.6
3/5/18	11:15	693.9	0	4.3	15.7	408.58	215.6
3/5/18	11:16	592.9	0	1.8	16.1	382.58	207.8
3/5/18	11:17	606.8	0	1.9	16.8	377.16	206.4
3/5/18	11:18	678.8	0	2.7	18	385.37	210.7
3/5/18	11:19	850.9	0	5.2	18.7	401.59	207.2
3/5/18	11:20	890.7	0	8	18.4	410.88	200.3
3/5/18	11:21	840.8	0	4.6	17	435.48	200.9
3/5/18	11:22	799.8	0	0	15.6	420.71	192.8

3/5/18	11:23	779.8	0	0	17.1	404.46	182.9
3/5/18	11:24	740.3	0	0	19.1	410.43	185.4
3/5/18	11:25	720.3	0	0.1	20.3	413.6	187.8
3/5/18	11:26	810.7	0	7	21	440.66	197.5
3/5/18	11:27	954.7	0	10.2	20.5	477.6	202.7
3/5/18	11:28	983.5	0	9.9	17.5	499.87	207.4
3/5/18	11:29	1017.5	0	10.4	14.8	513.21	210.3
3/5/18	11:30	1063.5	0	11.2	13.3	527.32	219.3
3/5/18	11:31	1053.3	0	10.3	12.1	529.24	223.1
3/5/18	11:32	957.3	0	7.8	11.2	517.23	221.1
3/5/18	11:33	913.3	0	7.6	11.5	484.2	212.4
3/5/18	11:34	879.2	0	6.2	12.4	458.34	202.1
3/5/18	11:35	843.4	0	5.8	13.1	440.61	194.4
3/5/18	11:36	830.9	0	5.2	13.9	429.91	190.7
3/5/18	11:37	842.2	0	6.3	14.6	449.57	197.7
3/5/18	11:38	882.2	0	7.3	15.1	451.65	199.6
3/5/18	11:39	872.8	0	6.4	14.8	436.8	191.6
3/5/18	11:40	838.8	0	5.8	14.6	426.87	189.1
3/5/18	11:41	824	0	5.6	14.8	427.25	190.1
							Test Start
3/5/18	11:42	824.9	0	6.1	15	449.41	203.5
3/5/18	11:43	884.8	0	5.5	15.3	432.52	191.3
3/5/18	11:44	871.2	0	4.6	15.2	422	184.5
3/5/18	11:45	830.3	0	3.7	15.5	411.96	180.7
3/5/18	11:46	815.4	0	3.7	16.1	405.69	179.1
3/5/18	11:47	806.5	0	3.2	16.8	402.19	176.6
3/5/18	11:48	778.5	0	3.4	17.2	394.12	173.6
3/5/18	11:49	772.6	0	3.5	17.6	388.97	171.4
3/5/18	11:50	776.6	0	4.2	17.7	387.52	169.5
3/5/18	11:51	788.2	0	4.8	17.7	389.28	170.1
3/5/18	11:52	797.9	0	5	17.3	391.85	169.7
3/5/18	11:53	799.8	0	5.1	16.9	393.77	169.7
3/5/18	11:54	781.3	0	4	16.6	390.29	170
3/5/18	11:55	771.5	0	4.1	16.6	387.89	170.8
3/5/18	11:56	774.6	0	4.2	16.9	387.21	172.4
3/5/18	11:57	782	0	5	17	385.67	172.1
3/5/18	11:58	797.6	0.02	5.5	16.9	385.25	171.5
3/5/18	11:59	827.2	0.02	6.6	16.6	388.46	171.2
3/5/18	12:00	868.8	0.03	7.2	16.1	394.34	172.9
3/5/18	12:01	912.2	0.05	7.7	15.4	403.62	175.4
3/5/18	12:02	928.5	0.01	7.4	14.7	411.1	177.3
3/5/18	12:03	933.1	0	7.4	14.3	413.7	175.1
3/5/18	12:04	926	0	7.3	14.1	412.91	177.1
3/5/18	12:05	930.1	0.01	7.5	14	415.39	180.7
3/5/18	12:06	937	0	7.4	13.9	418.2	181.1
3/5/18	12:07	940.3	0	7.5	13.8	419.83	182.4
3/5/18	12:08	949.8	0	7.9	13.8	420.8	182
3/5/18	12:09	968.7	0.02	8.1	13.7	425.21	185.3
3/5/18	12:10	981.9	0.03	8.2	13.6	429.65	187.1

3/5/18	12:11	992.1	0.05	8.4	13.4	430.82	186.2
3/5/18	12:12	1005.6	0.09	8.6	13.2	432.22	182.6
3/5/18	12:13	1029.7	0.15	9	13	435.96	183.9
3/5/18	12:14	1061	0.23	9.6	12.8	443.45	184.1
3/5/18	12:15	1100.6	0.45	10.5	12.4	451.64	186.9
3/5/18	12:16	1137.3	0.88	11.5	11.9	461.44	189.2
3/5/18	12:17	1154.3	0.75	11.5	11.1	469.91	192.9
3/5/18	12:18	1152.8	0.5	11.2	10.4	473.33	196.3
3/5/18	12:19	1146.1	0.35	11	10	474.25	195.4
3/5/18	12:20	1139	0.22	10.9	9.9	474.86	193.8
3/5/18	12:21	1128.2	0.16	10.7	10	474.52	193.9
3/5/18	12:22	1124.9	0.11	10.6	10.1	475.14	192.9
3/5/18	12:23	1114.8	0.07	10.2	10.2	473.43	192.9
3/5/18	12:24	1057.3	0	8.7	10.4	465.25	193
3/5/18	12:25	998.1	0	7.6	10.8	455.49	193.2
3/5/18	12:26	946.9	0	7	11.6	444.99	192.8
3/5/18	12:27	919.1	0	6.8	12.5	434.39	192.3
3/5/18	12:28	907.6	0	6.8	13.2	426.04	190.4
3/5/18	12:29	904.5	0	7.1	13.6	419.98	188.9
3/5/18	12:30	904.4	0	7.2	13.9	417.08	187.9
3/5/18	12:31	901.2	0	7.3	13.9	416.15	185.6
3/5/18	12:32	898.6	0	7.3	13.8	413.64	184.3
3/5/18	12:33	900.7	0	7.2	13.8	411.99	182.9
3/5/18	12:34	902.7	0	7.3	13.8	410.24	182.9
3/5/18	12:35	902.8	0	7.4	13.8	409.87	180.6
3/5/18	12:36	902.3	0	7.4	13.8	410.63	180.8
3/5/18	12:37	902.8	0	7.5	13.8	410.7	182.6
3/5/18	12:38	909.9	0	7.7	13.7	409.95	182.5
3/5/18	12:39	916.2	0	7.7	13.7	410.82	180.2
3/5/18	12:40	917.7	0	7.6	13.5	411.53	179.7
3/5/18	12:41	911.1	0	7.4	13.5	411.29	179.2
3/5/18	12:42	905.3	0	7.4	13.5	410.59	178.9
3/5/18	12:43	896.2	0	7.2	13.6	409.64	178.4
3/5/18	12:44	888.5	0	7	13.7	410.12	178.4
3/5/18	12:45	878.9	0	6.9	13.8	408.62	178.2
3/5/18	12:46	869.5	0	6.7	13.9	405.79	177.2
3/5/18	12:47	859	0	6.6	14.1	403.3	178.4
3/5/18	12:48	850.5	0	6.5	14.2	401.9	177
3/5/18	12:49	843.2	0	6.4	14.4	399.49	176.2
3/5/18	12:50	838.4	0	6.3	14.5	397.63	177.3
3/5/18	12:51	832.4	0	6.4	14.6	396.09	176.3
3/5/18	12:52	831.2	0	6.4	14.7	395.95	174.8
3/5/18	12:53	830.1	0	6.4	14.7	395.19	176.2
3/5/18	12:54	829.9	0	6.4	14.7	393.72	176.1
3/5/18	12:55	829.2	0	6.3	14.7	393.19	176.4
3/5/18	12:56	827	0	5.9	14.7	392.51	176.2
3/5/18	12:57	824.9	0	5.7	14.8	391.78	176.1
3/5/18	12:58	820.3	0	5.7	15	391.31	175.7

3/5/18	12:59	809.9	0	5.6	15.2	389.34	176
3/5/18	13:00	803.6	0	5.6	15.3	387.6	174.5
3/5/18	13:01	802.5	0	5.6	15.4	387.17	173.2
3/5/18	13:02	801.8	0	5.6	15.5	386.23	171.4
3/5/18	13:03	797.4	0	5.6	15.5	383.9	172.2
3/5/18	13:04	796	0	5.5	15.5	382.81	173.5
3/5/18	13:05	791.9	0	5.3	15.5	383.28	171.8
3/5/18	13:06	781.5	0	5.1	15.6	382.82	170.9
3/5/18	13:07	773.5	0	5.1	15.8	380.98	170.8
3/5/18	13:08	766.9	0	5	15.9	378.69	169.7
3/5/18	13:09	765.7	0	5	16	377.58	171.2
3/5/18	13:10	762.1	0	5	16.1	375.95	170.3
3/5/18	13:11	759	0	5	16.2	374.73	170.9
3/5/18	13:12	757.8	0	5	16.2	372.89	170.6
3/5/18	13:13	754.6	0	5	16.2	372.26	171.4
3/5/18	13:14	747.3	0	5	16.2	370.21	170.7
3/5/18	13:15	743.5	0	5	16.2	368.63	170.5
3/5/18	13:16	741.2	0	5.1	16.2	366.91	170
3/5/18	13:17	741	0	5	16.2	365.12	167.7
3/5/18	13:18	741.9	0	5.1	16.2	364.21	166.6
3/5/18	13:19	742.7	0	5.1	16.2	363.69	166.9
3/5/18	13:20	741.6	0	5.1	16.1	363.01	166.6
3/5/18	13:21	734.8	0	5.2	16.1	361.35	166.6
3/5/18	13:22	734.2	0	5.2	16.1	361.28	167.2
3/5/18	13:23	738.6	0	5.2	16.1	361.61	165.7
3/5/18	13:24	738.6	0	5.1	16	362.08	165.7
3/5/18	13:25	738.4	0	5	16	362.6	165.4
3/5/18	13:26	741.2	0	5.1	16	362.79	163.8
3/5/18	13:27	745.2	0	4.9	16.1	364.01	165.2
3/5/18	13:28	748.9	0	4.9	16.1	364.98	164.4
3/5/18	13:29	745.3	0	4.8	16.2	364.69	165.3
3/5/18	13:30	733.7	0	4.8	16.2	362.81	166.1
3/5/18	13:31	729.3	0	4.7	16.2	361.97	166.3
3/5/18	13:32	728.2	0	4.7	16.3	361.72	165.3
3/5/18	13:33	729.3	0	4.7	16.3	361.04	164.2
3/5/18	13:34	728.2	0	4.7	16.3	360.22	164.2
3/5/18	13:35	726.1	0	4.7	16.3	359.8	164.2
3/5/18	13:36	723.1	0	4.7	16.4	359.25	164.1
3/5/18	13:37	720.4	0	4.7	16.4	357.72	164
3/5/18	13:38	715.1	0	4.8	16.4	355.63	162.4
3/5/18	13:39	713.7	0	4.7	16.4	354.41	162.5
3/5/18	13:40	715.5	0	4.7	16.4	353.8	163.4
3/5/18	13:41	714.5	0	4.7	16.4	353.57	164
3/5/18	13:42	708.8	0	4.6	16.4	352.87	162.8
3/5/18	13:43	708.4	0	4.7	16.4	352.21	162.5
3/5/18	13:44	719.6	0	4.7	16.5	354.13	163.1
3/5/18	13:45	726.1	0	4.7	16.5	355.27	164.2
3/5/18	13:46	720.2	0	4.7	16.4	354.17	164.1

3/5/18	13:47	725.3	0	4.7	16.5	356.05	163.9
3/5/18	13:48	726.1	0	4.6	16.5	357.1	163.4
3/5/18	13:49	726.5	0	4.6	16.5	356.68	162.8
3/5/18	13:50	732.9	0	4.6	16.5	357.88	162.8
3/5/18	13:51	733.4	0	4.6	16.5	358.71	162.6
3/5/18	13:52	729.1	0	4.6	16.5	358.81	163.3
3/5/18	13:53	708.2	0	4.6	16.6	355.16	162.3
3/5/18	13:54	702.4	0	4.6	16.6	351.28	162.6
3/5/18	13:55	717.7	0	4.5	16.6	352.59	162.5
3/5/18	13:56	722.3	0	4.6	16.6	353.39	161.3
3/5/18	13:57	724.6	0	4.5	16.6	354.83	160.9
3/5/18	13:58	726.1	0	4.4	16.7	355.15	161.3
3/5/18	13:59	722.1	0	4.3	16.7	354.73	160.6
3/5/18	14:00	713.1	0	4.1	16.7	354.09	162.1
3/5/18	14:01	709.3	0	4.1	16.9	354.11	162.7
3/5/18	14:02	702.1	0	4.1	17	353.04	162.7
3/5/18	14:03	690.7	0	4.2	17	349.8	160.7
3/5/18	14:04	685.7	0	4.1	17.1	347.32	160.8
3/5/18	14:05	682.5	0	4.1	17.1	346.2	161
3/5/18	14:06	682.2	0	4.1	17.1	345.55	160.1
3/5/18	14:07	682.9	0	4.1	17.1	344.26	159
3/5/18	14:08	683.4	0	4.1	17.1	343.42	158.6
3/5/18	14:09	686.4	0	4.1	17.1	344.57	158.4
3/5/18	14:10	690.3	0	4.2	17.1	345.92	159.4
3/5/18	14:11	693.2	0	4.2	17.1	346.7	159.9
3/5/18	14:12	695.4	0	4.2	17.1	347.05	158.5
3/5/18	14:13	696.6	0	4.2	17.1	348.05	159.8
3/5/18	14:14	698.2	0	4.2	17.1	348.81	160.5
3/5/18	14:15	701	0	4.3	17	349.07	158.7
3/5/18	14:16	701	0	4.2	17	348.53	157.6
3/5/18	14:17	697.3	0	4.3	17	347.85	158.6
3/5/18	14:18	690.7	0	4.2	17	348.04	157.9
3/5/18	14:19	685.1	0	4.1	17	346.7	158

Test End

Reporting Period: 03/05/2018 to 03/05/2018

Site Name: UNIT

Time of Report: 03/06/18 14:21

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	Stove Side front left CAT_PRE (Deg_F)	Stove Bottom TEMP_10 (Deg_F)	Stove Back TEMP_11 (Deg_F)	Stove Side TEMP_12 (Deg_F)	Stove Top TEMP_13 (Deg_F)	
3/5/18	9:55	61.7	62.34	61.96	63.04	61.66	Preburn
3/5/18	9:56	61.5	62.48	62.22	62.86	61.55	
3/5/18	9:57	61.3	62.88	62.42	62.97	61.78	
3/5/18	9:58	61.3	62.7	62.07	63.3	61.88	
3/5/18	9:59	61.5	62.6	61.94	63.11	61.51	
3/5/18	10:00	61.5	62.62	62.11	62.87	61.47	
3/5/18	10:01	61.5	62.94	62.42	62.91	61.75	
3/5/18	10:02	61.3	63.13	62.17	63.27	61.71	
3/5/18	10:03	61.4	62.74	61.93	63.19	61.32	
3/5/18	10:04	61.4	62.67	62.08	62.92	61.68	
3/5/18	10:05	61.4	62.72	62.42	62.91	62.23	
3/5/18	10:06	61.6	63.1	62.28	63.24	62.12	
3/5/18	10:07	61.7	62.81	61.99	63.3	61.81	
3/5/18	10:08	61.6	62.56	62.01	62.98	61.82	
3/5/18	10:09	61.6	62.76	62.39	62.89	62.19	
3/5/18	10:10	61.5	63.07	62.34	63.12	62.17	
3/5/18	10:11	61.5	62.98	62.01	63.33	61.8	
3/5/18	10:12	61.7	62.72	62.01	63.03	61.79	
3/5/18	10:13	61.7	62.69	62.35	62.88	62.06	
3/5/18	10:14	61.2	62.64	63.14	63.19	62.34	
3/5/18	10:15	61.6	63.4	63.32	63.7	62.86	
3/5/18	10:16	61.8	63.06	64.36	63.71	66.83	
3/5/18	10:17	61.8	62.8	66.44	63.85	77.37	
3/5/18	10:18	62.3	62.87	69.55	64.75	93.19	
3/5/18	10:19	63	63.34	73.38	66.01	110.11	
3/5/18	10:20	64.1	63.74	77.78	67.51	123.27	
3/5/18	10:21	65.4	63.78	82.57	69.26	132.32	
3/5/18	10:22	66.5	63.82	86.48	71.51	138.43	
3/5/18	10:23	68	64.5	89.51	74.18	146.23	
3/5/18	10:24	69.9	65.73	92.63	76.23	160.07	
3/5/18	10:25	71.8	66.13	96.18	78.41	178.48	
3/5/18	10:26	73.5	66.47	100.98	81.39	197.5	
3/5/18	10:27	75.4	67.7	105.24	84.79	216.81	
3/5/18	10:28	77.1	69.01	109.6	88.35	236.82	
3/5/18	10:29	79.6	69.94	114.83	91.32	257.59	
3/5/18	10:30	82.5	71.08	120.11	94.76	276.58	
3/5/18	10:31	84.9	72.27	125.12	98.64	290.61	
3/5/18	10:32	87.4	73.95	130.21	102.42	303.85	
3/5/18	10:33	89.8	75.49	135.93	105.43	312.2	
3/5/18	10:34	92.5	76.44	142.14	109.06	322.14	
3/5/18	10:35	94.8	77.85	146.7	112.95	331.8	
3/5/18	10:36	98	79.68	149.55	117.12	338.13	
3/5/18	10:37	101.3	81.73	155.78	120.65	346.54	
3/5/18	10:38	104.1	83.48	161.14	123.97	354.05	
3/5/18	10:39	106.6	85.04	166.45	127.81	358.68	
3/5/18	10:40	108.8	86.81	171.28	132.1	369.65	
3/5/18	10:41	111.2	89.26	173.38	134.17	372.74	
3/5/18	10:42	114.2	91.16	176.99	136.84	378.81	
3/5/18	10:43	117.8	92.75	180.42	139.79	387.72	

3/5/18	10:44	120.4	94.46	179.33	143.6	396.88
3/5/18	10:45	122.9	96.81	181.42	146.21	402.31
3/5/18	10:46	125.6	99.65	185.06	148.47	403.37
3/5/18	10:47	128.9	101.43	188.36	150.84	405.24
3/5/18	10:48	131.6	103.81	188.24	154.21	407.76
3/5/18	10:49	134.1	106.77	187.82	157.16	406.9
3/5/18	10:50	137	109.87	189.26	160.3	406.28
3/5/18	10:51	139.7	112.28	191.19	162.7	404.39
3/5/18	10:52	142.7	114.82	191.81	165.39	398.05
3/5/18	10:53	145	117.62	192.42	167.61	397.21
3/5/18	10:54	147.6	120.72	196.46	168.93	397.44
3/5/18	10:55	151.3	123.93	197.15	171.65	398.02
3/5/18	10:56	153.7	126.48	194.92	174.06	398.84
3/5/18	10:57	180	129.5	193.7	184.99	404.27
3/5/18	10:58	196.7	132.58	194.79	193.11	402.65
3/5/18	10:59	201.4	136.1	197.47	195.18	401.28
3/5/18	11:00	205.2	140.79	205.39	197.45	402.3
3/5/18	11:01	208.8	144.76	208.02	199.61	396.49
3/5/18	11:02	211.9	148.81	210.59	201.28	395.07
3/5/18	11:03	215	152.09	214.87	203.37	401.19
3/5/18	11:04	218.6	155.04	218.26	205.6	400.75
3/5/18	11:05	222.1	158.32	222.93	208.73	402.69
3/5/18	11:06	225.6	162.56	225.86	210.58	401.91
3/5/18	11:07	228.2	167.54	228	212.83	399.56
3/5/18	11:08	231.2	170.3	228.62	215.87	398.61
3/5/18	11:09	234	172.39	224.37	218.39	401.39
3/5/18	11:10	236.1	175.57	229.34	220.79	402.9
3/5/18	11:11	239	179.54	232.14	223.42	409.1
3/5/18	11:12	241.7	183.73	231.83	226.2	408.82
3/5/18	11:13	244.1	188.08	236.39	229.64	417.65
3/5/18	11:14	246.7	190.42	239.11	232.26	418.47
3/5/18	11:15	248.8	192.55	234.66	234.81	420.92
3/5/18	11:16	251.1	195.72	237.52	237.15	421.22
3/5/18	11:17	253.3	199.59	243.14	240.31	414.81
3/5/18	11:18	255.3	202.64	246.65	243.82	410.09
3/5/18	11:19	256.6	205.31	243.94	245.28	404.52
3/5/18	11:20	255	199.92	231.62	242.92	396.82
3/5/18	11:21	253.4	199.11	228.27	243.27	401.79
3/5/18	11:22	255	202.5	227.33	245.28	405.67
3/5/18	11:23	256	203.36	227.02	245.93	404.83
3/5/18	11:24	257.4	206.36	231.94	246.93	403.23
3/5/18	11:25	258.9	208.1	232.64	248.39	401.82
3/5/18	11:26	260.4	209.29	234.17	249.99	392.17
3/5/18	11:27	260.7	213.17	235.55	252.71	391.87
3/5/18	11:28	260.3	213.93	233.54	254.11	398.31
3/5/18	11:29	261.6	214.05	234.02	255.57	410.72
3/5/18	11:30	264.8	219.62	241.53	259.19	424.55
3/5/18	11:31	270.1	226.53	248.87	263.96	448.98
3/5/18	11:32	274.1	230.75	252.94	266.51	462.93
3/5/18	11:33	274.1	228.11	247.34	266.74	463.87
3/5/18	11:34	272.8	227.37	242.49	267.13	467.3
3/5/18	11:35	273.8	227.61	242.47	269	467.78
3/5/18	11:36	276.1	229.68	246.38	269.43	461.13
3/5/18	11:37	278.7	230.83	250.15	271.84	456.66
3/5/18	11:38	280.7	232.82	252.93	275.06	454.69
3/5/18	11:39	282.5	232.09	251.57	277.63	453.03
3/5/18	11:40	284.4	234.24	249.74	279.26	445.66

3/5/18	11:41	286.4	237.58	253.61	280.47	443.55
3/5/18	11:42	288.2	239.94	260.63	283.74	446.28
3/5/18	11:43	289.9	235.22	254.77	284.92	441.61
3/5/18	11:44	290.8	234.94	252.79	285.7	439.19
3/5/18	11:45	293.1	238.04	254.04	287.03	435.8
3/5/18	11:46	297.9	245.55	263.49	294.14	445.67
3/5/18	11:47	302.1	249.86	262.51	298.44	449.52
3/5/18	11:48	303.5	249.13	256.89	298.45	444.64
3/5/18	11:49	299.4	244.49	246.22	294.4	427.33
3/5/18	11:50	299.6	245.67	243.36	295.77	422
3/5/18	11:51	298.7	242.97	239.25	295.33	413.87
3/5/18	11:52	298.7	241.44	236.14	293.02	405.1
3/5/18	11:53	297.6	242.22	233.58	291.71	403.98
3/5/18	11:54	296.3	245.51	231.9	292.62	403.7
3/5/18	11:55	298.1	253.53	232.73	294.87	414.9
3/5/18	11:56	299.5	256.61	232.01	295.13	416.51
3/5/18	11:57	299.6	257.98	231.6	295.03	411.79
3/5/18	11:58	298.7	259.84	230.42	294.49	409.04
3/5/18	11:59	298	261.33	228.15	294.85	411.23
3/5/18	12:00	298.1	261.72	226.7	294.9	413.72
3/5/18	12:01	297.5	262.7	226.31	293.94	412.78
3/5/18	12:02	296.9	263.93	225.23	292.89	412.31
3/5/18	12:03	295.7	265.28	222.04	292.36	417.31
3/5/18	12:04	296.2	267.01	222.82	292.38	428.73
3/5/18	12:05	295.9	267.49	221.74	291.68	431.22
3/5/18	12:06	295.6	268.75	221.59	291.5	437.01
3/5/18	12:07	295.2	269.66	220.62	291.37	439.39
3/5/18	12:08	295.6	270.28	219.97	291.26	443.53
3/5/18	12:09	296.2	271.07	220.61	290.34	449.77
3/5/18	12:10	296	272.36	220.64	289.82	455.01
3/5/18	12:11	296.5	273.52	220.42	289.83	456.97
3/5/18	12:12	297.3	273.4	220.52	289.94	456.14
3/5/18	12:13	297.6	273.78	222.21	289.68	465.16
3/5/18	12:14	297.6	274.32	221.88	288.96	467.44
3/5/18	12:15	298.3	275.56	222.29	289.01	479.04
3/5/18	12:16	298.6	276.42	222.47	289.86	491.04
3/5/18	12:17	300	277.45	223.9	289.54	503.51
3/5/18	12:18	301.5	277.42	225.83	289.12	513.94
3/5/18	12:19	302.2	278.14	227.72	289.75	527.13
3/5/18	12:20	302.7	279.46	228.16	290.18	537.62
3/5/18	12:21	304.2	279.95	228.65	290.25	545.18
3/5/18	12:22	305.7	280.62	229.72	290.69	550.63
3/5/18	12:23	307.9	281.77	231.48	291.82	552.86
3/5/18	12:24	309.8	283.28	231.18	292.97	557.93
3/5/18	12:25	311	283.34	233.46	294.11	554.84
3/5/18	12:26	312.5	283.59	234.96	294.71	556.44
3/5/18	12:27	313.9	284.03	235.8	296.24	552.65
3/5/18	12:28	314.3	285.55	236.65	297.83	541.94
3/5/18	12:29	316.3	286.35	237.46	299.12	534.12
3/5/18	12:30	318.1	287.04	238.06	300.02	525.03
3/5/18	12:31	319.4	287.55	237.57	301.35	513.42
3/5/18	12:32	320.3	288.2	239.05	302.56	507.25
3/5/18	12:33	321.4	289.15	239.22	303.75	501.31
3/5/18	12:34	322.5	289.1	240.66	304.67	500.18
3/5/18	12:35	323.4	289.62	240.98	305.07	492.38
3/5/18	12:36	324.5	290.24	242.31	306.97	490.3
3/5/18	12:37	326.2	291.34	242.7	308.17	490.2

3/5/18	12:38	327.2	291.8	242.83	308.28	485.27	
3/5/18	12:39	328.6	292.31	243.65	309.49	482.05	
3/5/18	12:40	329.5	292.78	245.11	310.77	483.68	Test Start
3/5/18	12:41	330.6	293.11	245.22	312.79	486.88	333.72 Average Surface temp
3/5/18	12:42	331.5	293.98	244.57	313.26	486.94	
3/5/18	12:43	332.9	294.04	247.43	313.95	486.05	
3/5/18	12:44	334.4	295.14	247.36	314.04	482.41	
3/5/18	12:45	336	296.58	247.54	314.63	483.04	
3/5/18	12:46	337.5	297.65	249.19	315.84	485.5	
3/5/18	12:47	338.6	297.12	249.09	316.04	481.84	
3/5/18	12:48	339	297.7	250.53	316.85	474.41	
3/5/18	12:49	340.6	298.19	250.24	318.47	474.59	
3/5/18	12:50	340.9	298.78	249.05	318.34	471.75	
3/5/18	12:51	342.2	298.9	250.42	318.35	465.82	
3/5/18	12:52	343.2	298.69	251.52	318.9	462.28	
3/5/18	12:53	344	299.6	252	320.08	466.38	
3/5/18	12:54	345	300.58	251.92	320.69	464.32	
3/5/18	12:55	346.1	301.06	252.55	321.18	463.17	
3/5/18	12:56	346.3	301.59	251.11	321.63	462.1	
3/5/18	12:57	347.4	301.8	252.62	322.76	460.69	
3/5/18	12:58	348.3	302.07	251.96	324.01	456.63	
3/5/18	12:59	349.1	302.77	252.92	324.42	455.35	
3/5/18	13:00	349.6	302.99	253.51	325.03	450.61	
3/5/18	13:01	349.7	303.47	251.92	325.86	446.79	
3/5/18	13:02	349.9	303.99	250.66	326.95	446.61	
3/5/18	13:03	350	304.3	248.85	327.14	445.62	
3/5/18	13:04	350.3	304.63	249.78	327.47	440.38	
3/5/18	13:05	350.4	304.71	250.83	328	438.68	
3/5/18	13:06	350.4	305.33	250.67	328.73	436.49	
3/5/18	13:07	350.6	306.12	250.84	329.16	435.02	
3/5/18	13:08	350.2	306.1	249.63	329.72	433.08	
3/5/18	13:09	350.1	305.87	250.32	329.92	429.38	
3/5/18	13:10	350.4	305.57	250	330.61	426.2	
3/5/18	13:11	350.6	305.92	248.88	330.67	425.02	
3/5/18	13:12	350.2	306.14	249.17	330.71	423.09	
3/5/18	13:13	350.1	306.17	249.64	330.95	420.23	
3/5/18	13:14	349.8	306.69	247.86	331.34	419.52	
3/5/18	13:15	350.7	307.59	247.92	331.26	417.41	
3/5/18	13:16	351	307.79	248.7	330.76	415	
3/5/18	13:17	351.2	307.31	248.49	330.78	414.52	
3/5/18	13:18	350.5	307.59	248.45	331.11	412.8	
3/5/18	13:19	350.4	308.29	248.38	330.55	410.88	
3/5/18	13:20	350.3	309.18	247.52	329.64	406.83	
3/5/18	13:21	350.2	309.4	248.63	329.24	405.52	
3/5/18	13:22	349.6	309.18	249.15	329.12	403.03	
3/5/18	13:23	349.4	309.05	249.32	329.45	401.54	
3/5/18	13:24	350.6	310.24	248.12	329.08	401.5	
3/5/18	13:25	350.1	310.34	248.97	328.94	399.03	
3/5/18	13:26	349.9	310.34	249.36	329.04	399.4	
3/5/18	13:27	349.7	310.94	248.54	329.01	396.78	
3/5/18	13:28	350	311.48	248.65	328.45	397.34	
3/5/18	13:29	349.9	311.88	248.15	327.91	398.24	
3/5/18	13:30	349.4	311.75	249.61	327.98	399.27	
3/5/18	13:31	349.3	312.2	250.05	328.4	396.74	
3/5/18	13:32	349.1	312.93	249.84	327.72	394.06	
3/5/18	13:33	349.1	313.4	248.85	327.56	395.6	
3/5/18	13:34	348.7	313.47	250.28	327.57	395.33	

3/5/18	13:35	349	313.97	250.29	327.28	392.4
3/5/18	13:36	348.3	314.4	250.1	326.64	390.46
3/5/18	13:37	348.6	315.12	251.02	326.52	389.65
3/5/18	13:38	348.4	315.21	252.3	327.09	388.66
3/5/18	13:39	347.9	316.37	252	326.68	386.82
3/5/18	13:40	346.8	316.72	251.61	325.75	384.8
3/5/18	13:41	347.1	317.54	251.41	325.09	383.28
3/5/18	13:42	347.1	318.03	252.16	325.27	379.22
3/5/18	13:43	347	318.09	252.92	326.16	381.94
3/5/18	13:44	346.9	319.39	252.97	325.67	380.82
3/5/18	13:45	346.8	320.41	253.36	324.93	381.16
3/5/18	13:46	347	320.95	252.26	324.46	379.52
3/5/18	13:47	346.9	321.09	253.42	324.76	375.07
3/5/18	13:48	346.2	321.7	252.12	324.74	376.04
3/5/18	13:49	346.1	322.74	252.9	324.64	376.78
3/5/18	13:50	346	323.91	254.08	323.92	373.8
3/5/18	13:51	346.1	323.99	254.41	324.38	372.54
3/5/18	13:52	346.2	324.39	254.58	324.7	373.03
3/5/18	13:53	345.5	325.45	254.3	323.91	374.72
3/5/18	13:54	345.2	326.68	255.5	323.75	373.27
3/5/18	13:55	345.2	326.95	254.53	324.02	372.18
3/5/18	13:56	345.1	327.15	254.69	323.96	370.21
3/5/18	13:57	344.4	327.24	255.75	323.64	368.41
3/5/18	13:58	343.3	328.53	255.61	323.71	369.87
3/5/18	13:59	343.1	328.83	256.02	324.32	372.07
3/5/18	14:00	342.9	329.06	255.27	324.19	369.6
3/5/18	14:01	342.6	330	255.79	323.32	368.49
3/5/18	14:02	342.3	330.69	256.71	323.08	364.95
3/5/18	14:03	342.1	331.58	257.07	323.64	366.73
3/5/18	14:04	342.5	331.51	257.87	324.06	365.67
3/5/18	14:05	342.2	331.84	255.39	323.68	363.4
3/5/18	14:06	340.8	332.89	255.8	323.88	360.66
3/5/18	14:07	340.9	333.43	256.19	324.4	360.34
3/5/18	14:08	339.9	333.49	254.99	323.94	359.11
3/5/18	14:09	339.6	333.94	256.27	323.29	356.97
3/5/18	14:10	339.2	334.57	256.31	322.67	355.64
3/5/18	14:11	338.9	335.01	256.88	323.25	354.57
3/5/18	14:12	338.2	335.37	256.58	323.65	352.91
3/5/18	14:13	337.7	335.57	256.06	323.27	352.71
3/5/18	14:14	337.2	335.88	256.86	322.61	352.86
3/5/18	14:15	336.8	336.02	259.03	322.56	351.67
3/5/18	14:16	335.7	337.03	258.37	322.97	350.22
3/5/18	14:17	335.1	337.1	258.05	322.94	350.6
3/5/18	14:18	333.5	336.67	259.28	322.67	350.01
3/5/18	14:19	333.4	337.83	258.82	322.8	351.08

Test End

320.786 Average Surface temp

3/5/18	10:35	1	61.8	3.479	64.2	65.7	63.6
3/5/18	10:36	1	62	3.379	64.3	66.1	63.7
3/5/18	10:37	1	62.1	3.221	64.4	66.2	63.7
3/5/18	10:38	1	62.1	3.274	64.4	66.2	64
3/5/18	10:39	1	62.1	3.212	64.6	66.3	64.2
3/5/18	10:40	1	62.3	3.292	64.6	66.3	64.2
3/5/18	10:41	1	62.3	3.163	64.9	66.5	64.2
3/5/18	10:42	1	62.4	3.027	65.1	66.5	64.6
3/5/18	10:43	1	62.4	3.163	65.2	66.4	64.5
3/5/18	10:44	1	62.6	3.205	65.3	66.6	64.6
3/5/18	10:45	1	62.7	3.454	65.4	66.6	65
3/5/18	10:46	1	62.7	3.402	65.4	66.6	65.3
3/5/18	10:47	1	62.9	3.472	65.5	66.6	65.3
3/5/18	10:48	1	62.9	3.426	65.7	66.6	65.5
3/5/18	10:49	1	63	3.357	65.8	66.6	65.6
3/5/18	10:50	1	63.1	3.298	65.8	66.7	65.7
3/5/18	10:51	1	63.2	3.312	65.8	66.7	65.8
3/5/18	10:52	1	63.3	3.452	66	66.7	65.8
3/5/18	10:53	1	63.3	3.393	66.1	66.8	66
3/5/18	10:54	1	63.4	3.184	66.1	66.8	66.1
3/5/18	10:55	1	63.7	3.351	66.3	67	66.1
3/5/18	10:56	1	63.8	3.39	66.5	67.1	65.9
3/5/18	10:57	1	63.7	3.337	66.5	67.1	66.3
3/5/18	10:58	1	63.9	3.372	66.5	67	66.7
3/5/18	10:59	1	63.9	3.214	66.5	67	66.6
3/5/18	11:00	1	64	3.113	66.6	67	66.3
3/5/18	11:01	1	64	3.126	66.8	67.2	66.2
3/5/18	11:02	1	64.1	3.016	66.9	67.2	66.3
3/5/18	11:03	1	64.3	3.13	66.8	67.1	66.3
3/5/18	11:04	1	64.3	3.09	66.9	67.1	66.4
3/5/18	11:05	1	64.4	2.985	67.1	67.4	66.9
3/5/18	11:06	1	64.4	2.972	67.1	67.3	66.9
3/5/18	11:07	1	64.7	3.01	67.2	67.4	67
3/5/18	11:08	1	64.5	3.1	67.2	67.5	66.8
3/5/18	11:09	1	64.5	3.271	67.6	67.7	66.5
3/5/18	11:10	1	64.6	3.133	67.5	67.5	67.1
3/5/18	11:11	1	64.8	3.173	67.7	67.7	67.1
3/5/18	11:12	1	64.7	3.048	67.7	67.7	66.9
3/5/18	11:13	1	64.8	3.004	67.8	67.8	67.2
3/5/18	11:14	1	64.9	3.036	67.8	67.9	67.1
3/5/18	11:15	1	65.2	3.253	68	67.9	67.5
3/5/18	11:16	1	65.3	3.231	68.1	68.1	67.9
3/5/18	11:17	1	65.3	2.979	68.1	68	67.3
3/5/18	11:18	1	65.3	2.94	68.3	68.1	67.3
3/5/18	11:19	1	65.3	2.974	68.3	68.2	67.5
3/5/18	11:20	1	65.4	2.948	68.2	68.3	66
3/5/18	11:21	1	65.2	2.931	68	68.1	65.8
3/5/18	11:22	1	65.3	3.108	67.8	67.9	65.5

3/5/18	11:23	1	65.1	3.01	68.1	68.2	65.3
3/5/18	11:24	1	65.4	2.944	67.7	67.9	65.4
3/5/18	11:25	1	65.4	2.9	67.4	67.6	65.3
3/5/18	11:26	1	65.3	2.931	67.2	67.4	65.1
3/5/18	11:27	1	65.2	2.988	67.2	67.6	65.2
3/5/18	11:28	1	65.2	3.013	67.1	67.6	65.4
3/5/18	11:29	1	65	2.988	66.9	67.4	65.3
3/5/18	11:30	1	64.9	2.902	66.9	67.2	65.2
3/5/18	11:31	1	64.8	3.023	66.8	67.1	65.9
3/5/18	11:32	1	64.6	3.054	67	67.5	66.4
3/5/18	11:33	1	64.6	3.202	67	67.5	66
3/5/18	11:34	1	64.5	3.141	67	67.5	65.2
3/5/18	11:35	1	64.6	3.183	66.8	67.3	65.5
3/5/18	11:36	1	64.9	3.139	66.9	67.5	65.2
3/5/18	11:37	1	64.8	3.074	66.8	67.3	65.2
3/5/18	11:38	1	64.8	3.117	66.6	67.2	65
3/5/18	11:39	1	64.9	3.138	66.7	67.3	65.6
3/5/18	11:40	1	63.5	3.22	66.9	68.1	65.1
3/5/18	11:41	1	60.5	3.145	68	72.2	65.1
3/5/18	11:42	1	59.7	3.045	68.7	74.4	65.2
3/5/18	11:43	1	59.1	3.329	69.4	75.1	65.3
3/5/18	11:44	1	58.5	3.308	69.8	75.3	65.1
3/5/18	11:45	1	58	3.193	70.2	75.7	64.7
3/5/18	11:46	1	57.7	3.268	70.6	75.9	65.3
3/5/18	11:47	1	57.2	3.283	71.1	76.3	65.9
3/5/18	11:48	1	57.1	3.37	71.5	76.6	66.1
3/5/18	11:49	1	56.9	3.344	72	76.9	65.4
3/5/18	11:50	1	56.7	3.308	72.4	77.2	65.1
3/5/18	11:51	1	56.5	3.232	72.6	77.1	65.2
3/5/18	11:52	1	56.5	3.284	72.7	77.1	65.2
3/5/18	11:53	1	56.3	3.172	72.8	77.5	65.1
3/5/18	11:54	1	56.2	3.187	72.8	77.4	64.9
3/5/18	11:55	1	56	3.185	72.9	77.6	65.2
3/5/18	11:56	1	55.9	3.133	73.2	78	65.5
3/5/18	11:57	1	56	3.328	73.3	77.9	66.1
3/5/18	11:58	1	56	3.307	73.5	78.1	66
3/5/18	11:59	1	56	3.249	73.7	78.3	66.1
3/5/18	12:00	1	55.9	3.306	74.1	78.5	66.4
3/5/18	12:01	1	55.9	3.262	74.4	78.9	66.9
3/5/18	12:02	1	55.7	3.383	74.6	79.2	66.9
3/5/18	12:03	1	55.7	3.219	74.7	79.3	66.6
3/5/18	12:04	1	55.6	3.229	74.8	79.5	66.8
3/5/18	12:05	1	55.9	3.278	75.3	80	67.2
3/5/18	12:06	1	55.6	3.392	75.6	80.3	67.4
3/5/18	12:07	1	55.9	3.396	75.7	80.3	67.7
3/5/18	12:08	1	55.8	3.311	75.8	80.5	67.8
3/5/18	12:09	1	56.1	3.32	75.9	80.8	68
3/5/18	12:10	1	56.1	3.389	76.4	81.1	67.8

3/5/18	12:11	1	56.1	3.335	76.5	81.3	68.2
3/5/18	12:12	1	56.1	3.234	76.7	81.5	68.3
3/5/18	12:13	1	56.2	3.354	76.9	81.6	68.8
3/5/18	12:14	1	56	3.139	77.2	81.9	68.4
3/5/18	12:15	1	56.2	3.156	77.5	82.2	68.7
3/5/18	12:16	1	56.1	3.241	77.8	82.5	69
3/5/18	12:17	1	56	3.311	78	82.8	69.2
3/5/18	12:18	1	56.1	3.349	78	83.1	69.3
3/5/18	12:19	1	56.3	3.321	78.3	83.3	69.3
3/5/18	12:20	1	56.3	3.422	78.5	83.2	69.3
3/5/18	12:21	1	56.2	3.294	78.7	83.4	69.4
3/5/18	12:22	1	56.4	3.232	78.9	83.7	69.7
3/5/18	12:23	1	56.6	3.246	79	83.8	69.8
3/5/18	12:24	1	56.6	3.22	79.1	83.9	70
3/5/18	12:25	1	56.8	3.255	79.2	84	70.1
3/5/18	12:26	1	56.7	3.377	79.4	84	70.8
3/5/18	12:27	1	56.8	3.499	79.4	83.8	70.6
3/5/18	12:28	1	57	3.526	79.5	84	71.2
3/5/18	12:29	1	56.8	3.556	79.7	84	71.4
3/5/18	12:30	1	56.9	3.482	79.7	83.8	71.2
3/5/18	12:31	1	56.9	3.488	79.8	83.8	70.7
3/5/18	12:32	1	56.8	3.435	79.9	83.9	71.2
3/5/18	12:33	1	57	3.388	79.8	83.7	71.4
3/5/18	12:34	1	57.1	3.508	79.8	83.7	71.6
3/5/18	12:35	1	57.1	3.437	79.8	83.6	70.9
3/5/18	12:36	1	57.1	3.594	79.8	83.6	71.4
3/5/18	12:37	1	57.1	3.5	79.8	83.6	71.8
3/5/18	12:38	1	57.2	3.537	79.7	83.6	71.8
3/5/18	12:39	1	57.2	3.453	79.6	83.4	71.9
3/5/18	12:40	1	57.3	3.49	79.6	82.5	71.9
3/5/18	12:41	1	58.4	3.36	79	166.3	71.6
3/5/18	12:42	1	59.6	3.384	79	73.8	71.5
3/5/18	12:43	1	58.8	3.31	78.9	73.4	71
3/5/18	12:44	1	58.2	3.249	78.8	73.1	71
3/5/18	12:45	1	57.9	3.434	78.8	73.1	71.1
3/5/18	12:46	1	57.8	3.468	78.8	73.1	71.9
3/5/18	12:47	1	57.5	3.524	78.8	73.1	71.3
3/5/18	12:48	1	57.4	3.268	78.7	73.2	70.6
3/5/18	12:49	1	57.3	3.312	78.7	73.5	71
3/5/18	12:50	1	57.3	3.438	78.8	73.7	71.9
3/5/18	12:51	1	57.4	3.474	78.8	73.9	72.4
3/5/18	12:52	1	57.3	3.346	78.8	74.1	71.7
3/5/18	12:53	1	57.6	3.5	78.9	74.4	71.8
3/5/18	12:54	1	57.6	3.446	78.8	74.4	72
3/5/18	12:55	1	57.6	3.432	79	74.7	71.9
3/5/18	12:56	1	57.5	3.546	78.9	74.9	71.7
3/5/18	12:57	1	57.5	3.486	78.9	75.1	72.4
3/5/18	12:58	1	57.4	3.571	78.7	75.1	72.5

3/5/18	12:59	1	57.6	3.514	79	75.4	72.5
3/5/18	13:00	1	57.6	3.464	79	75.5	72.5
3/5/18	13:01	1	57.5	3.387	79.1	75.6	72.3
3/5/18	13:02	1	57.5	3.352	79	75.8	72
3/5/18	13:03	1	57.6	3.395	79	75.8	72.1
3/5/18	13:04	1	57.7	3.389	79.1	76	72.6
3/5/18	13:05	1	57.7	3.454	79.1	76.1	72.3
3/5/18	13:06	1	57.6	3.583	79.1	76	72.9
3/5/18	13:07	1	57.6	3.442	79.1	76.2	72.4
3/5/18	13:08	1	57.7	3.357	78.9	76	72.5
3/5/18	13:09	1	57.6	3.484	79.1	76.4	72.1
3/5/18	13:10	1	57.7	3.538	79.2	76.4	72
3/5/18	13:11	1	57.8	3.496	79.1	76.5	72.3
3/5/18	13:12	1	57.7	3.501	79	76.5	72.3
3/5/18	13:13	1	57.8	3.512	79	76.5	71.8
3/5/18	13:14	1	57.8	3.567	78.9	76.4	71.3
3/5/18	13:15	1	57.8	3.607	79	76.5	72
3/5/18	13:16	1	57.7	3.564	79	76.4	72.2
3/5/18	13:17	1	57.8	3.422	78.9	76.4	72.2
3/5/18	13:18	1	57.7	3.471	78.8	76.6	72.3
3/5/18	13:19	1	57.8	3.581	78.7	76.4	72.7
3/5/18	13:20	1	57.7	3.45	78.7	76.3	72.2
3/5/18	13:21	1	57.7	3.545	78.8	76.4	72.8
3/5/18	13:22	1	57.6	3.587	78.8	76.4	72.4
3/5/18	13:23	1	57.7	3.488	78.7	76.3	72
3/5/18	13:24	1	57.7	3.436	78.8	76.5	72.3
3/5/18	13:25	1	57.9	3.529	78.7	76.3	72.4
3/5/18	13:26	1	57.7	3.469	78.7	76.4	72.4
3/5/18	13:27	1	57.6	3.444	78.7	76.3	71.9
3/5/18	13:28	1	57.6	3.504	78.6	76.3	72.2
3/5/18	13:29	1	57.5	3.63	78.6	76.4	72.3
3/5/18	13:30	1	57.7	3.501	78.6	76.4	72.4
3/5/18	13:31	1	57.6	3.481	78.8	76.6	72.2
3/5/18	13:32	1	57.7	3.549	78.7	76.5	71.7
3/5/18	13:33	1	57.9	3.593	78.7	76.4	72.1
3/5/18	13:34	1	57.8	3.477	78.7	76.4	72
3/5/18	13:35	1	57.8	3.484	78.7	76.5	72.4
3/5/18	13:36	1	57.8	3.455	78.7	76.4	72.3
3/5/18	13:37	1	57.8	3.481	78.6	76.2	72.4
3/5/18	13:38	1	57.8	3.347	78.5	76.2	72.1
3/5/18	13:39	1	57.9	3.301	78.5	76.1	72.2
3/5/18	13:40	1	57.7	3.604	78.6	76.3	72.6
3/5/18	13:41	1	57.8	3.615	78.6	76.3	72.5
3/5/18	13:42	1	57.9	3.573	78.6	76.4	71.8
3/5/18	13:43	1	57.8	3.554	78.6	76.3	72.2
3/5/18	13:44	1	57.8	3.511	78.5	76.3	71.6
3/5/18	13:45	1	57.8	3.59	78.5	76.2	72.3
3/5/18	13:46	1	57.8	3.721	78.4	76.2	72.2

3/5/18	13:47	1	57.8	3.644	78.4	76.2	71.9
3/5/18	13:48	1	57.7	3.588	78.4	76.2	72.4
3/5/18	13:49	1	57.8	3.686	78.3	76.2	72.4
3/5/18	13:50	1	57.7	3.526	78.3	76.2	72.4
3/5/18	13:51	1	57.8	3.551	78.4	76.2	72.5
3/5/18	13:52	1	57.9	3.558	78.4	76.2	72.1
3/5/18	13:53	1	57.9	3.615	78.3	76.2	72.3
3/5/18	13:54	1	57.8	3.598	78.3	76.1	72.4
3/5/18	13:55	1	57.7	3.541	78.3	76.1	72.3
3/5/18	13:56	1	57.7	3.576	78.2	75.9	72.4
3/5/18	13:57	1	58	3.349	78.3	76.2	71.2
3/5/18	13:58	1	57.8	3.477	78.3	76.1	71
3/5/18	13:59	1	57.8	3.504	78.4	76.2	71.8
3/5/18	14:00	1	57.8	3.615	78.3	76.2	72.1
3/5/18	14:01	1	57.7	3.702	78.3	76.2	72.2
3/5/18	14:02	1	57.8	3.684	78.2	76.2	72.2
3/5/18	14:03	1	57.7	3.639	78.1	76.2	72.3
3/5/18	14:04	1	57.8	3.611	78.2	76.2	71.8
3/5/18	14:05	1	57.8	3.626	78.1	76.2	71.6
3/5/18	14:06	1	57.9	3.533	78.1	76.1	71
3/5/18	14:07	1	57.8	3.617	77.8	76	71.8
3/5/18	14:08	1	58	3.693	77.8	76.1	72
3/5/18	14:09	1	57.9	3.639	77.8	76.2	72
3/5/18	14:10	1	58	3.686	77.8	76	72.1
3/5/18	14:11	1	58	3.695	77.8	76	72.2
3/5/18	14:12	1	58	3.672	77.8	76.1	72
3/5/18	14:13	1	57.8	3.531	77.7	76	72.2
3/5/18	14:14	1	58	3.652	77.7	75.8	72
3/5/18	14:15	1	58	3.601	77.8	76	71.8
3/5/18	14:16	1	57.8	3.509	77.9	75.9	72.1
3/5/18	14:17	1	58	3.709	77.9	76	72.2
3/5/18	14:18	1	57.9	3.489	77.8	76	71.5
3/5/18	14:19	1	58.7	3.707	77.4	75.9	71.4

TUNL_TMP (Deg_F)	UNIT_WT (lbs)
63	0.05
62.5	0.04
62.4	0.03
62.8	0.04
62.4	0.03
62.5	0.04
62.6	0.04
63.3	0.05
63.2	0.04
62.8	0.05
62.7	0.06
64	0.07
63	0.07
62.1	0.5
63	0.72
62.8	1.11
63	1.49
62.7	1.42
63	1.4
66.8	1.37
65.5	1.26
75.2	1.12
81.4	0.98
87.5	3.31
83.9	11.84
79.2	11.88
74.2	11.78
75	11.52
79.4	11.27
90.7	11.08
95.2	10.84
82.9	10.65
86.9	10.45
102.6	10.23
104.9	10.01
105	9.8
106.6	9.6
105.5	9.44
107.6	9.24
107.6	9.05

107.1	9.32
107.7	8.61
109.8	8.43
109	8.26
110	8.06
110	7.86
110.9	7.65
112.9	7.49
112	7.55
109.8	7.1
106.1	6.97
107	6.95
105.9	6.73
106.1	6.57
106.6	6.41
107.1	6.29
107.2	6.17
105.3	6.06
105.8	5.91
110.5	6.1
108.4	5.74
105.6	5.5
104.8	5.36
103.8	5.23
106.3	5.22
111.7	5.17
113	5.04
116.1	4.92
116.6	4.74
117.5	5.18
117.5	6.15
118.1	6.24
118.3	6.1
116.7	5.8
111.4	5.57
114.9	5.07
116.1	5.3
117.9	5.11
122.1	5.14
121.4	3.1
113.1	2.21
111.4	2.94
114	2.92
116.1	3.22
114.5	3.14
111.6	2.32
111.9	3.24
106.5	3.77

104.4	3.7	
106.4	4.54	
107.6	5.36	
110.3	5.2	
111.3	5	
112.6	4.77	
113.9	4.55	
118.4	4.72	
117.9	4	
117.1	3.95	
111.8	3.53	
108.8	3.44	
106	3.92	
105.2	3.36	
108.3	3.26	
108.2	3.2	
105.8	2.95	
103.6	2.86	Fuel Consumed, 2.6 lb coal bed
105.1	14.2	11.6
110.8	14.23	11.63
103.1	14.13	11.53
101.2	14.05	11.45
101.1	13.93	11.33
100.1	13.86	11.26
99.7	13.79	11.19
98.1	13.69	11.09
97.2	13.61	11.01
96.7	13.51	10.91
97.7	13.41	10.81
97	13.33	10.73
98.2	13.21	10.61
97.9	13.08	10.48
98.4	13.01	10.41
99.7	12.9	10.3
98	12.78	10.18
98	12.68	10.08
98.5	12.57	9.97
98.7	12.42	9.82
100.2	12.32	9.72
99.6	12.18	9.58
100.3	12.03	9.43
101	11.89	9.29
101.9	11.74	9.14
100.9	11.65	9.05
101.5	11.43	8.83
102.3	11.34	8.74
103.4	11.23	8.63
103	11.08	8.48

103.6	11.01	8.41
103.6	10.78	8.18
103.1	10.67	8.07
105.3	10.54	7.94
106.2	10.33	7.73
106.1	10.18	7.58
106.6	10	7.4
107.2	9.87	7.27
107.3	9.73	7.13
105.7	9.49	6.89
107.3	9.28	6.68
107.8	9.12	6.52
107.7	8.9	6.3
108.2	8.72	6.12
107.9	8.66	6.06
107	8.5	5.9
105.4	8.42	5.82
105	8.33	5.73
104.4	8.27	5.67
104.7	8.19	5.59
103.7	8.11	5.51
104.2	8.04	5.44
104.3	7.97	5.37
103.4	7.93	5.33
102.9	7.82	5.22
101.9	7.68	5.08
103.5	7.62	5.02
103.2	7.57	4.97
103.3	7.46	4.86
102.8	7.35	4.75
103.7	7.2	4.6
103.3	7.14	4.54
103.5	7.05	4.45
104.1	6.99	4.39
102.4	6.87	4.27
102.3	6.8	4.2
101.7	6.76	4.16
103.2	6.66	4.06
102.8	6.56	3.96
102.6	6.51	3.91
102.3	6.46	3.86
102.6	6.38	3.78
101.6	6.28	3.68
102.3	6.25	3.65
102.4	6.17	3.57
101.2	6.08	3.48
102.2	6.01	3.41
101.5	5.96	3.36

102	5.9	3.3
102	5.84	3.24
102.2	5.78	3.18
101.7	5.71	3.11
101.6	5.65	3.05
102.4	5.59	2.99
101.2	5.56	2.96
100.4	5.49	2.89
101.1	5.44	2.84
101.5	5.37	2.77
100.6	5.34	2.74
99.8	5.3	2.7
100.5	5.24	2.64
100.4	5.19	2.59
100.2	5.12	2.52
99.2	5.07	2.47
99.4	5.04	2.44
99.7	4.99	2.39
100.1	4.93	2.33
99.5	4.87	2.27
99.2	4.82	2.22
99.6	4.79	2.19
99.3	4.72	2.12
98.8	4.67	2.07
98.9	4.62	2.02
99.5	4.56	1.96
98.7	4.52	1.92
98.8	4.49	1.89
99.1	4.45	1.85
98.6	4.39	1.79
98	4.34	1.74
99.2	4.29	1.69
99.3	4.25	1.65
98.2	4.23	1.63
97.8	4.18	1.58
98.6	4.13	1.53
98.8	4.08	1.48
98.9	4.05	1.45
98.8	4.01	1.41
99.2	3.98	1.38
99.6	3.94	1.34
97.9	3.9	1.3
97.9	3.88	1.28
97.3	3.83	1.23
97.6	3.82	1.22
97.7	3.8	1.2
97.9	3.76	1.16
97	3.71	1.11

97.2	3.68	1.08
97.8	3.64	1.04
97	3.59	0.99
98.1	3.6	1
97.9	3.54	0.94
97.8	3.51	0.91
97.3	3.45	0.85
97.5	3.43	0.83
97.9	3.4	0.8
97.4	3.37	0.77
98.1	3.34	0.74
97.1	3.29	0.69
97.3	3.28	0.68
97	3.23	0.63
96.7	3.22	0.62
96.8	3.18	0.58
96.7	3.12	0.52
96.6	3.09	0.49
96.4	3.09	0.49
96.3	3.06	0.46
96	3.02	0.42
95.5	3.01	0.41
95.8	2.99	0.39
95.9	2.96	0.36
96	2.93	0.33
95.6	2.91	0.31
97.1	2.86	0.26
96.2	2.83	0.23
96	2.8	0.2
96.5	2.76	0.16
95.6	2.73	0.13
96.3	2.7	0.1
94.8	2.65	0

General Average Report

Reporting Period: 03/05/2018 to 03/05/2018

Site Name: UNIT

Time of Report: 03/06/18 14:22

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	CAT_POST (Deg_F)	CO (%)	CO2 (%)	O2 (%)	STK_CSA (Deg_F)	STK_TMP (Deg_F)
3/5/18	9:55	61.4	0.02	0	22	61.95	61.3
3/5/18	9:56	61.5	0.02	0	22	62.2	61.2
3/5/18	9:57	61.4	0.02	0	22	62.33	61.2
3/5/18	9:58	61.2	0.02	0	22	62.06	61.2
3/5/18	9:59	61.4	0.02	0	22	62.06	61.1
3/5/18	10:00	61.4	0.02	0	22	62.29	61.1
3/5/18	10:01	61.1	0.02	0	22	62.55	61
3/5/18	10:02	60.8	0.06	0.7	22	62.34	61
3/5/18	10:03	61	0.03	-0.1	21.3	62.04	61
3/5/18	10:04	61.1	0.03	-0.1	14.8	62.14	60.9
3/5/18	10:05	61.1	0.03	-0.1	8.8	62.35	61
3/5/18	10:06	60.6	0.02	0	5.4	62.36	61
3/5/18	10:07	61.2	0	-0.1	8.3	62.11	61.2
3/5/18	10:08	61.5	0	-0.1	9	62.1	61.3
3/5/18	10:09	61.1	0	-0.1	5.5	62.52	61.2
3/5/18	10:10	61	0	0	3.3	62.74	61.2
3/5/18	10:11	61	0	0	5.2	62.43	61.3
3/5/18	10:12	61.4	0	0	11.5	62.36	61.4
3/5/18	10:13	64.4	0	0	15.7	62.62	61.3
3/5/18	10:14	85.9	0.05	1.9	18.2	67.2	62.3
3/5/18	10:15	181.7	0.07	2.6	19.5	87.29	71.5
3/5/18	10:16	459.1	0.08	4.7	19.6	141.07	95.2
3/5/18	10:17	655	0.16	6.2	19	207.15	122.5
3/5/18	10:18	682.9	0.06	5.7	17.8	261.14	143.6
3/5/18	10:19	463.6	0.18	1.8	16.6	254.24	140.6
3/5/18	10:20	340.6	0.24	2	16.8	225.91	134.3
3/5/18	10:21	357.5	0.18	2.1	18	217.52	129.2
3/5/18	10:22	519	0.43	5.3	18.7	232.96	133.5
3/5/18	10:23	724.6	0.36	8.2	18.6	282.51	151.3
3/5/18	10:24	813.1	0.24	7.4	16.9	325.84	170.7
3/5/18	10:25	764.3	0.25	7.5	15.3	352.24	181.8
3/5/18	10:26	797	0.16	7.4	14.6	372.31	188.2
3/5/18	10:27	866.4	0.11	7.5	14.2	388.91	196.8
3/5/18	10:28	874.6	0.08	7.6	14	402.38	202.6
3/5/18	10:29	847	0.08	6.8	13.8	407.2	206.9
3/5/18	10:30	814.4	0.08	6.3	13.8	407.63	211.7
3/5/18	10:31	792.4	0.09	6	14.1	405.62	214.1
3/5/18	10:32	780	0.08	6.5	14.5	405.92	214.6
3/5/18	10:33	797.8	0.07	7.1	14.7	411.61	217
3/5/18	10:34	818	0.06	7.4	14.6	419.31	218.2

3/5/18	10:35	841.5	0.06	7.4	14.3	426.09	214.5
3/5/18	10:36	831.6	0.07	6.2	14	427.4	211.9
3/5/18	10:37	834.2	0.05	6.8	14.1	427.32	212
3/5/18	10:38	856.5	0.04	7.7	14.3	430.62	210.9
3/5/18	10:39	864.3	0.05	7.1	14.2	435.02	211.3
3/5/18	10:40	859.8	0.05	6.8	13.9	437.25	214.9
3/5/18	10:41	865.3	0.05	6.8	14	437.82	211.8
3/5/18	10:42	879.1	0.05	7	14.1	440.87	210.8
3/5/18	10:43	887	0.05	7.4	14.2	443.1	214.7
3/5/18	10:44	880.2	0.04	7.1	14.1	431.47	209.2
3/5/18	10:45	843.4	0.03	6	13.9	418.67	206.8
3/5/18	10:46	814.1	0.04	5.4	14.2	411	206.5
3/5/18	10:47	814.6	0.05	6	14.7	408.4	206
3/5/18	10:48	847.1	0.05	5.9	15.1	411.03	204.6
3/5/18	10:49	818.5	0.05	5.4	15.1	408.25	203.2
3/5/18	10:50	801.6	0.03	5.8	15.3	403.41	202.2
3/5/18	10:51	802.2	0.03	5.9	15.4	400.67	202.9
3/5/18	10:52	804.4	0.03	5.9	15.3	399.98	202
3/5/18	10:53	802.6	0.02	5.8	15.3	398.97	201
3/5/18	10:54	791.5	0.02	5.5	15.3	403.1	207.2
3/5/18	10:55	868.8	0.03	8.2	15.3	405.09	207.5
3/5/18	10:56	932.6	0.02	8.1	15.1	405.49	200.4
3/5/18	10:57	838.3	-0.01	6.2	14.1	397.9	194.8
3/5/18	10:58	786.8	0	5.6	13.9	388.19	191.7
3/5/18	10:59	767.3	0	5.1	14.4	386.02	193.7
3/5/18	11:00	735	0.02	4.6	15	397.71	207.3
3/5/18	11:01	741.6	0.01	5.2	15.5	407.02	212.3
3/5/18	11:02	752.8	0.01	6	15.8	414.2	216.2
3/5/18	11:03	729.1	0.01	5.3	15.7	417.95	223.5
3/5/18	11:04	700.7	0	4.6	15.5	415.92	224
3/5/18	11:05	651.2	0.05	3.8	15.7	408.4	217.9
3/5/18	11:06	695.1	0.03	4.7	16.2	410.24	218.8
3/5/18	11:07	757.3	0.01	5.3	16.6	416.99	221.3
3/5/18	11:08	832.5	0	6.5	16.6	423.64	221.4
3/5/18	11:09	854.1	0	6.7	16.1	418.28	213.2
3/5/18	11:10	838.4	0	5.5	15.5	420.68	216.5
3/5/18	11:11	854.9	0	6	15.2	431.04	222.3
3/5/18	11:12	825.4	0	6.6	15.5	431.64	222.1
3/5/18	11:13	774.9	0	4.8	15.1	433.85	232.2
3/5/18	11:14	766.2	0	4.9	15.2	433.62	231.6
3/5/18	11:15	693.9	0	4.3	15.7	408.58	215.6
3/5/18	11:16	592.9	0	1.8	16.1	382.58	207.8
3/5/18	11:17	606.8	0	1.9	16.8	377.16	206.4
3/5/18	11:18	678.8	0	2.7	18	385.37	210.7
3/5/18	11:19	850.9	0	5.2	18.7	401.59	207.2
3/5/18	11:20	890.7	0	8	18.4	410.88	200.3
3/5/18	11:21	840.8	0	4.6	17	435.48	200.9
3/5/18	11:22	799.8	0	0	15.6	420.71	192.8

3/5/18	11:23	779.8	0	0	17.1	404.46	182.9	
3/5/18	11:24	740.3	0	0	19.1	410.43	185.4	
3/5/18	11:25	720.3	0	0.1	20.3	413.6	187.8	
3/5/18	11:26	810.7	0	7	21	440.66	197.5	
3/5/18	11:27	954.7	0	10.2	20.5	477.6	202.7	
3/5/18	11:28	983.5	0	9.9	17.5	499.87	207.4	
3/5/18	11:29	1017.5	0	10.4	14.8	513.21	210.3	
3/5/18	11:30	1063.5	0	11.2	13.3	527.32	219.3	
3/5/18	11:31	1053.3	0	10.3	12.1	529.24	223.1	
3/5/18	11:32	957.3	0	7.8	11.2	517.23	221.1	
3/5/18	11:33	913.3	0	7.6	11.5	484.2	212.4	
3/5/18	11:34	879.2	0	6.2	12.4	458.34	202.1	
3/5/18	11:35	843.4	0	5.8	13.1	440.61	194.4	
3/5/18	11:36	830.9	0	5.2	13.9	429.91	190.7	
3/5/18	11:37	842.2	0	6.3	14.6	449.57	197.7	
3/5/18	11:38	882.2	0	7.3	15.1	451.65	199.6	
3/5/18	11:39	872.8	0	6.4	14.8	436.8	191.6	
3/5/18	11:40	838.8	0	5.8	14.6	426.87	189.1	
3/5/18	11:41	824	0	5.6	14.8	427.25	190.1	Test Start
3/5/18	11:42	824.9	0	6.1	15	449.41	203.5	
3/5/18	11:43	884.8	0	5.5	15.3	432.52	191.3	
3/5/18	11:44	871.2	0	4.6	15.2	422	184.5	
3/5/18	11:45	830.3	0	3.7	15.5	411.96	180.7	
3/5/18	11:46	815.4	0	3.7	16.1	405.69	179.1	
3/5/18	11:47	806.5	0	3.2	16.8	402.19	176.6	
3/5/18	11:48	778.5	0	3.4	17.2	394.12	173.6	
3/5/18	11:49	772.6	0	3.5	17.6	388.97	171.4	
3/5/18	11:50	776.6	0	4.2	17.7	387.52	169.5	
3/5/18	11:51	788.2	0	4.8	17.7	389.28	170.1	
3/5/18	11:52	797.9	0	5	17.3	391.85	169.7	
3/5/18	11:53	799.8	0	5.1	16.9	393.77	169.7	
3/5/18	11:54	781.3	0	4	16.6	390.29	170	
3/5/18	11:55	771.5	0	4.1	16.6	387.89	170.8	
3/5/18	11:56	774.6	0	4.2	16.9	387.21	172.4	
3/5/18	11:57	782	0	5	17	385.67	172.1	
3/5/18	11:58	797.6	0.02	5.5	16.9	385.25	171.5	
3/5/18	11:59	827.2	0.02	6.6	16.6	388.46	171.2	
3/5/18	12:00	868.8	0.03	7.2	16.1	394.34	172.9	
3/5/18	12:01	912.2	0.05	7.7	15.4	403.62	175.4	
3/5/18	12:02	928.5	0.01	7.4	14.7	411.1	177.3	
3/5/18	12:03	933.1	0	7.4	14.3	413.7	175.1	
3/5/18	12:04	926	0	7.3	14.1	412.91	177.1	
3/5/18	12:05	930.1	0.01	7.5	14	415.39	180.7	
3/5/18	12:06	937	0	7.4	13.9	418.2	181.1	
3/5/18	12:07	940.3	0	7.5	13.8	419.83	182.4	
3/5/18	12:08	949.8	0	7.9	13.8	420.8	182	
3/5/18	12:09	968.7	0.02	8.1	13.7	425.21	185.3	
3/5/18	12:10	981.9	0.03	8.2	13.6	429.65	187.1	

3/5/18	12:11	992.1	0.05	8.4	13.4	430.82	186.2
3/5/18	12:12	1005.6	0.09	8.6	13.2	432.22	182.6
3/5/18	12:13	1029.7	0.15	9	13	435.96	183.9
3/5/18	12:14	1061	0.23	9.6	12.8	443.45	184.1
3/5/18	12:15	1100.6	0.45	10.5	12.4	451.64	186.9
3/5/18	12:16	1137.3	0.88	11.5	11.9	461.44	189.2
3/5/18	12:17	1154.3	0.75	11.5	11.1	469.91	192.9
3/5/18	12:18	1152.8	0.5	11.2	10.4	473.33	196.3
3/5/18	12:19	1146.1	0.35	11	10	474.25	195.4
3/5/18	12:20	1139	0.22	10.9	9.9	474.86	193.8
3/5/18	12:21	1128.2	0.16	10.7	10	474.52	193.9
3/5/18	12:22	1124.9	0.11	10.6	10.1	475.14	192.9
3/5/18	12:23	1114.8	0.07	10.2	10.2	473.43	192.9
3/5/18	12:24	1057.3	0	8.7	10.4	465.25	193
3/5/18	12:25	998.1	0	7.6	10.8	455.49	193.2
3/5/18	12:26	946.9	0	7	11.6	444.99	192.8
3/5/18	12:27	919.1	0	6.8	12.5	434.39	192.3
3/5/18	12:28	907.6	0	6.8	13.2	426.04	190.4
3/5/18	12:29	904.5	0	7.1	13.6	419.98	188.9
3/5/18	12:30	904.4	0	7.2	13.9	417.08	187.9
3/5/18	12:31	901.2	0	7.3	13.9	416.15	185.6
3/5/18	12:32	898.6	0	7.3	13.8	413.64	184.3
3/5/18	12:33	900.7	0	7.2	13.8	411.99	182.9
3/5/18	12:34	902.7	0	7.3	13.8	410.24	182.9
3/5/18	12:35	902.8	0	7.4	13.8	409.87	180.6
3/5/18	12:36	902.3	0	7.4	13.8	410.63	180.8
3/5/18	12:37	902.8	0	7.5	13.8	410.7	182.6
3/5/18	12:38	909.9	0	7.7	13.7	409.95	182.5
3/5/18	12:39	916.2	0	7.7	13.7	410.82	180.2
3/5/18	12:40	917.7	0	7.6	13.5	411.53	179.7
3/5/18	12:41	911.1	0	7.4	13.5	411.29	179.2
3/5/18	12:42	905.3	0	7.4	13.5	410.59	178.9
3/5/18	12:43	896.2	0	7.2	13.6	409.64	178.4
3/5/18	12:44	888.5	0	7	13.7	410.12	178.4
3/5/18	12:45	878.9	0	6.9	13.8	408.62	178.2
3/5/18	12:46	869.5	0	6.7	13.9	405.79	177.2
3/5/18	12:47	859	0	6.6	14.1	403.3	178.4
3/5/18	12:48	850.5	0	6.5	14.2	401.9	177
3/5/18	12:49	843.2	0	6.4	14.4	399.49	176.2
3/5/18	12:50	838.4	0	6.3	14.5	397.63	177.3
3/5/18	12:51	832.4	0	6.4	14.6	396.09	176.3
3/5/18	12:52	831.2	0	6.4	14.7	395.95	174.8
3/5/18	12:53	830.1	0	6.4	14.7	395.19	176.2
3/5/18	12:54	829.9	0	6.4	14.7	393.72	176.1
3/5/18	12:55	829.2	0	6.3	14.7	393.19	176.4
3/5/18	12:56	827	0	5.9	14.7	392.51	176.2
3/5/18	12:57	824.9	0	5.7	14.8	391.78	176.1
3/5/18	12:58	820.3	0	5.7	15	391.31	175.7

3/5/18	12:59	809.9	0	5.6	15.2	389.34	176
3/5/18	13:00	803.6	0	5.6	15.3	387.6	174.5
3/5/18	13:01	802.5	0	5.6	15.4	387.17	173.2
3/5/18	13:02	801.8	0	5.6	15.5	386.23	171.4
3/5/18	13:03	797.4	0	5.6	15.5	383.9	172.2
3/5/18	13:04	796	0	5.5	15.5	382.81	173.5
3/5/18	13:05	791.9	0	5.3	15.5	383.28	171.8
3/5/18	13:06	781.5	0	5.1	15.6	382.82	170.9
3/5/18	13:07	773.5	0	5.1	15.8	380.98	170.8
3/5/18	13:08	766.9	0	5	15.9	378.69	169.7
3/5/18	13:09	765.7	0	5	16	377.58	171.2
3/5/18	13:10	762.1	0	5	16.1	375.95	170.3
3/5/18	13:11	759	0	5	16.2	374.73	170.9
3/5/18	13:12	757.8	0	5	16.2	372.89	170.6
3/5/18	13:13	754.6	0	5	16.2	372.26	171.4
3/5/18	13:14	747.3	0	5	16.2	370.21	170.7
3/5/18	13:15	743.5	0	5	16.2	368.63	170.5
3/5/18	13:16	741.2	0	5.1	16.2	366.91	170
3/5/18	13:17	741	0	5	16.2	365.12	167.7
3/5/18	13:18	741.9	0	5.1	16.2	364.21	166.6
3/5/18	13:19	742.7	0	5.1	16.2	363.69	166.9
3/5/18	13:20	741.6	0	5.1	16.1	363.01	166.6
3/5/18	13:21	734.8	0	5.2	16.1	361.35	166.6
3/5/18	13:22	734.2	0	5.2	16.1	361.28	167.2
3/5/18	13:23	738.6	0	5.2	16.1	361.61	165.7
3/5/18	13:24	738.6	0	5.1	16	362.08	165.7
3/5/18	13:25	738.4	0	5	16	362.6	165.4
3/5/18	13:26	741.2	0	5.1	16	362.79	163.8
3/5/18	13:27	745.2	0	4.9	16.1	364.01	165.2
3/5/18	13:28	748.9	0	4.9	16.1	364.98	164.4
3/5/18	13:29	745.3	0	4.8	16.2	364.69	165.3
3/5/18	13:30	733.7	0	4.8	16.2	362.81	166.1
3/5/18	13:31	729.3	0	4.7	16.2	361.97	166.3
3/5/18	13:32	728.2	0	4.7	16.3	361.72	165.3
3/5/18	13:33	729.3	0	4.7	16.3	361.04	164.2
3/5/18	13:34	728.2	0	4.7	16.3	360.22	164.2
3/5/18	13:35	726.1	0	4.7	16.3	359.8	164.2
3/5/18	13:36	723.1	0	4.7	16.4	359.25	164.1
3/5/18	13:37	720.4	0	4.7	16.4	357.72	164
3/5/18	13:38	715.1	0	4.8	16.4	355.63	162.4
3/5/18	13:39	713.7	0	4.7	16.4	354.41	162.5
3/5/18	13:40	715.5	0	4.7	16.4	353.8	163.4
3/5/18	13:41	714.5	0	4.7	16.4	353.57	164
3/5/18	13:42	708.8	0	4.6	16.4	352.87	162.8
3/5/18	13:43	708.4	0	4.7	16.4	352.21	162.5
3/5/18	13:44	719.6	0	4.7	16.5	354.13	163.1
3/5/18	13:45	726.1	0	4.7	16.5	355.27	164.2
3/5/18	13:46	720.2	0	4.7	16.4	354.17	164.1

3/5/18	13:47	725.3	0	4.7	16.5	356.05	163.9
3/5/18	13:48	726.1	0	4.6	16.5	357.1	163.4
3/5/18	13:49	726.5	0	4.6	16.5	356.68	162.8
3/5/18	13:50	732.9	0	4.6	16.5	357.88	162.8
3/5/18	13:51	733.4	0	4.6	16.5	358.71	162.6
3/5/18	13:52	729.1	0	4.6	16.5	358.81	163.3
3/5/18	13:53	708.2	0	4.6	16.6	355.16	162.3
3/5/18	13:54	702.4	0	4.6	16.6	351.28	162.6
3/5/18	13:55	717.7	0	4.5	16.6	352.59	162.5
3/5/18	13:56	722.3	0	4.6	16.6	353.39	161.3
3/5/18	13:57	724.6	0	4.5	16.6	354.83	160.9
3/5/18	13:58	726.1	0	4.4	16.7	355.15	161.3
3/5/18	13:59	722.1	0	4.3	16.7	354.73	160.6
3/5/18	14:00	713.1	0	4.1	16.7	354.09	162.1
3/5/18	14:01	709.3	0	4.1	16.9	354.11	162.7
3/5/18	14:02	702.1	0	4.1	17	353.04	162.7
3/5/18	14:03	690.7	0	4.2	17	349.8	160.7
3/5/18	14:04	685.7	0	4.1	17.1	347.32	160.8
3/5/18	14:05	682.5	0	4.1	17.1	346.2	161
3/5/18	14:06	682.2	0	4.1	17.1	345.55	160.1
3/5/18	14:07	682.9	0	4.1	17.1	344.26	159
3/5/18	14:08	683.4	0	4.1	17.1	343.42	158.6
3/5/18	14:09	686.4	0	4.1	17.1	344.57	158.4
3/5/18	14:10	690.3	0	4.2	17.1	345.92	159.4
3/5/18	14:11	693.2	0	4.2	17.1	346.7	159.9
3/5/18	14:12	695.4	0	4.2	17.1	347.05	158.5
3/5/18	14:13	696.6	0	4.2	17.1	348.05	159.8
3/5/18	14:14	698.2	0	4.2	17.1	348.81	160.5
3/5/18	14:15	701	0	4.3	17	349.07	158.7
3/5/18	14:16	701	0	4.2	17	348.53	157.6
3/5/18	14:17	697.3	0	4.3	17	347.85	158.6
3/5/18	14:18	690.7	0	4.2	17	348.04	157.9
3/5/18	14:19	685.1	0	4.1	17	346.7	158

Test End

General Average Report

Reporting Period: 03/05/2018 to 03/05/2018

Site Name: UNIT

Time of Report: 03/06/18 14:21

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	Stove Side fr	Stove Botto	Stove Back	Stove Side	Stove Top
		CAT_PRE (Deg_F)	TEMP_10 (Deg_F)	TEMP_11 (Deg_F)	TEMP_12 (Deg_F)	TEMP_13 (Deg_F)
3/5/18	9:55	61.7	62.34	61.96	63.04	61.66
3/5/18	9:56	61.5	62.48	62.22	62.86	61.55
3/5/18	9:57	61.3	62.88	62.42	62.97	61.78
3/5/18	9:58	61.3	62.7	62.07	63.3	61.88
3/5/18	9:59	61.5	62.6	61.94	63.11	61.51
3/5/18	10:00	61.5	62.62	62.11	62.87	61.47
3/5/18	10:01	61.5	62.94	62.42	62.91	61.75
3/5/18	10:02	61.3	63.13	62.17	63.27	61.71
3/5/18	10:03	61.4	62.74	61.93	63.19	61.32
3/5/18	10:04	61.4	62.67	62.08	62.92	61.68
3/5/18	10:05	61.4	62.72	62.42	62.91	62.23
3/5/18	10:06	61.6	63.1	62.28	63.24	62.12
3/5/18	10:07	61.7	62.81	61.99	63.3	61.81
3/5/18	10:08	61.6	62.56	62.01	62.98	61.82
3/5/18	10:09	61.6	62.76	62.39	62.89	62.19
3/5/18	10:10	61.5	63.07	62.34	63.12	62.17
3/5/18	10:11	61.5	62.98	62.01	63.33	61.8
3/5/18	10:12	61.7	62.72	62.01	63.03	61.79
3/5/18	10:13	61.7	62.69	62.35	62.88	62.06
3/5/18	10:14	61.2	62.64	63.14	63.19	62.34
3/5/18	10:15	61.6	63.4	63.32	63.7	62.86
3/5/18	10:16	61.8	63.06	64.36	63.71	66.83
3/5/18	10:17	61.8	62.8	66.44	63.85	77.37
3/5/18	10:18	62.3	62.87	69.55	64.75	93.19
3/5/18	10:19	63	63.34	73.38	66.01	110.11
3/5/18	10:20	64.1	63.74	77.78	67.51	123.27
3/5/18	10:21	65.4	63.78	82.57	69.26	132.32
3/5/18	10:22	66.5	63.82	86.48	71.51	138.43
3/5/18	10:23	68	64.5	89.51	74.18	146.23
3/5/18	10:24	69.9	65.73	92.63	76.23	160.07
3/5/18	10:25	71.8	66.13	96.18	78.41	178.48
3/5/18	10:26	73.5	66.47	100.98	81.39	197.5
3/5/18	10:27	75.4	67.7	105.24	84.79	216.81
3/5/18	10:28	77.1	69.01	109.6	88.35	236.82
3/5/18	10:29	79.6	69.94	114.83	91.32	257.59
3/5/18	10:30	82.5	71.08	120.11	94.76	276.58
3/5/18	10:31	84.9	72.27	125.12	98.64	290.61
3/5/18	10:32	87.4	73.95	130.21	102.42	303.85
3/5/18	10:33	89.8	75.49	135.93	105.43	312.2
3/5/18	10:34	92.5	76.44	142.14	109.06	322.14

3/5/18	10:35	94.8	77.85	146.7	112.95	331.8
3/5/18	10:36	98	79.68	149.55	117.12	338.13
3/5/18	10:37	101.3	81.73	155.78	120.65	346.54
3/5/18	10:38	104.1	83.48	161.14	123.97	354.05
3/5/18	10:39	106.6	85.04	166.45	127.81	358.68
3/5/18	10:40	108.8	86.81	171.28	132.1	369.65
3/5/18	10:41	111.2	89.26	173.38	134.17	372.74
3/5/18	10:42	114.2	91.16	176.99	136.84	378.81
3/5/18	10:43	117.8	92.75	180.42	139.79	387.72
3/5/18	10:44	120.4	94.46	179.33	143.6	396.88
3/5/18	10:45	122.9	96.81	181.42	146.21	402.31
3/5/18	10:46	125.6	99.65	185.06	148.47	403.37
3/5/18	10:47	128.9	101.43	188.36	150.84	405.24
3/5/18	10:48	131.6	103.81	188.24	154.21	407.76
3/5/18	10:49	134.1	106.77	187.82	157.16	406.9
3/5/18	10:50	137	109.87	189.26	160.3	406.28
3/5/18	10:51	139.7	112.28	191.19	162.7	404.39
3/5/18	10:52	142.7	114.82	191.81	165.39	398.05
3/5/18	10:53	145	117.62	192.42	167.61	397.21
3/5/18	10:54	147.6	120.72	196.46	168.93	397.44
3/5/18	10:55	151.3	123.93	197.15	171.65	398.02
3/5/18	10:56	153.7	126.48	194.92	174.06	398.84
3/5/18	10:57	180	129.5	193.7	184.99	404.27
3/5/18	10:58	196.7	132.58	194.79	193.11	402.65
3/5/18	10:59	201.4	136.1	197.47	195.18	401.28
3/5/18	11:00	205.2	140.79	205.39	197.45	402.3
3/5/18	11:01	208.8	144.76	208.02	199.61	396.49
3/5/18	11:02	211.9	148.81	210.59	201.28	395.07
3/5/18	11:03	215	152.09	214.87	203.37	401.19
3/5/18	11:04	218.6	155.04	218.26	205.6	400.75
3/5/18	11:05	222.1	158.32	222.93	208.73	402.69
3/5/18	11:06	225.6	162.56	225.86	210.58	401.91
3/5/18	11:07	228.2	167.54	228	212.83	399.56
3/5/18	11:08	231.2	170.3	228.62	215.87	398.61
3/5/18	11:09	234	172.39	224.37	218.39	401.39
3/5/18	11:10	236.1	175.57	229.34	220.79	402.9
3/5/18	11:11	239	179.54	232.14	223.42	409.1
3/5/18	11:12	241.7	183.73	231.83	226.2	408.82
3/5/18	11:13	244.1	188.08	236.39	229.64	417.65
3/5/18	11:14	246.7	190.42	239.11	232.26	418.47
3/5/18	11:15	248.8	192.55	234.66	234.81	420.92
3/5/18	11:16	251.1	195.72	237.52	237.15	421.22
3/5/18	11:17	253.3	199.59	243.14	240.31	414.81
3/5/18	11:18	255.3	202.64	246.65	243.82	410.09
3/5/18	11:19	256.6	205.31	243.94	245.28	404.52
3/5/18	11:20	255	199.92	231.62	242.92	396.82
3/5/18	11:21	253.4	199.11	228.27	243.27	401.79
3/5/18	11:22	255	202.5	227.33	245.28	405.67

3/5/18	11:23	256	203.36	227.02	245.93	404.83
3/5/18	11:24	257.4	206.36	231.94	246.93	403.23
3/5/18	11:25	258.9	208.1	232.64	248.39	401.82
3/5/18	11:26	260.4	209.29	234.17	249.99	392.17
3/5/18	11:27	260.7	213.17	235.55	252.71	391.87
3/5/18	11:28	260.3	213.93	233.54	254.11	398.31
3/5/18	11:29	261.6	214.05	234.02	255.57	410.72
3/5/18	11:30	264.8	219.62	241.53	259.19	424.55
3/5/18	11:31	270.1	226.53	248.87	263.96	448.98
3/5/18	11:32	274.1	230.75	252.94	266.51	462.93
3/5/18	11:33	274.1	228.11	247.34	266.74	463.87
3/5/18	11:34	272.8	227.37	242.49	267.13	467.3
3/5/18	11:35	273.8	227.61	242.47	269	467.78
3/5/18	11:36	276.1	229.68	246.38	269.43	461.13
3/5/18	11:37	278.7	230.83	250.15	271.84	456.66
3/5/18	11:38	280.7	232.82	252.93	275.06	454.69
3/5/18	11:39	282.5	232.09	251.57	277.63	453.03
3/5/18	11:40	284.4	234.24	249.74	279.26	445.66
3/5/18	11:41	286.4	237.58	253.61	280.47	443.55
3/5/18	11:42	288.2	239.94	260.63	283.74	446.28
3/5/18	11:43	289.9	235.22	254.77	284.92	441.61
3/5/18	11:44	290.8	234.94	252.79	285.7	439.19
3/5/18	11:45	293.1	238.04	254.04	287.03	435.8
3/5/18	11:46	297.9	245.55	263.49	294.14	445.67
3/5/18	11:47	302.1	249.86	262.51	298.44	449.52
3/5/18	11:48	303.5	249.13	256.89	298.45	444.64
3/5/18	11:49	299.4	244.49	246.22	294.4	427.33
3/5/18	11:50	299.6	245.67	243.36	295.77	422
3/5/18	11:51	298.7	242.97	239.25	295.33	413.87
3/5/18	11:52	298.7	241.44	236.14	293.02	405.1
3/5/18	11:53	297.6	242.22	233.58	291.71	403.98
3/5/18	11:54	296.3	245.51	231.9	292.62	403.7
3/5/18	11:55	298.1	253.53	232.73	294.87	414.9
3/5/18	11:56	299.5	256.61	232.01	295.13	416.51
3/5/18	11:57	299.6	257.98	231.6	295.03	411.79
3/5/18	11:58	298.7	259.84	230.42	294.49	409.04
3/5/18	11:59	298	261.33	228.15	294.85	411.23
3/5/18	12:00	298.1	261.72	226.7	294.9	413.72
3/5/18	12:01	297.5	262.7	226.31	293.94	412.78
3/5/18	12:02	296.9	263.93	225.23	292.89	412.31
3/5/18	12:03	295.7	265.28	222.04	292.36	417.31
3/5/18	12:04	296.2	267.01	222.82	292.38	428.73
3/5/18	12:05	295.9	267.49	221.74	291.68	431.22
3/5/18	12:06	295.6	268.75	221.59	291.5	437.01
3/5/18	12:07	295.2	269.66	220.62	291.37	439.39
3/5/18	12:08	295.6	270.28	219.97	291.26	443.53
3/5/18	12:09	296.2	271.07	220.61	290.34	449.77
3/5/18	12:10	296	272.36	220.64	289.82	455.01

3/5/18	12:11	296.5	273.52	220.42	289.83	456.97
3/5/18	12:12	297.3	273.4	220.52	289.94	456.14
3/5/18	12:13	297.6	273.78	222.21	289.68	465.16
3/5/18	12:14	297.6	274.32	221.88	288.96	467.44
3/5/18	12:15	298.3	275.56	222.29	289.01	479.04
3/5/18	12:16	298.6	276.42	222.47	289.86	491.04
3/5/18	12:17	300	277.45	223.9	289.54	503.51
3/5/18	12:18	301.5	277.42	225.83	289.12	513.94
3/5/18	12:19	302.2	278.14	227.72	289.75	527.13
3/5/18	12:20	302.7	279.46	228.16	290.18	537.62
3/5/18	12:21	304.2	279.95	228.65	290.25	545.18
3/5/18	12:22	305.7	280.62	229.72	290.69	550.63
3/5/18	12:23	307.9	281.77	231.48	291.82	552.86
3/5/18	12:24	309.8	283.28	231.18	292.97	557.93
3/5/18	12:25	311	283.34	233.46	294.11	554.84
3/5/18	12:26	312.5	283.59	234.96	294.71	556.44
3/5/18	12:27	313.9	284.03	235.8	296.24	552.65
3/5/18	12:28	314.3	285.55	236.65	297.83	541.94
3/5/18	12:29	316.3	286.35	237.46	299.12	534.12
3/5/18	12:30	318.1	287.04	238.06	300.02	525.03
3/5/18	12:31	319.4	287.55	237.57	301.35	513.42
3/5/18	12:32	320.3	288.2	239.05	302.56	507.25
3/5/18	12:33	321.4	289.15	239.22	303.75	501.31
3/5/18	12:34	322.5	289.1	240.66	304.67	500.18
3/5/18	12:35	323.4	289.62	240.98	305.07	492.38
3/5/18	12:36	324.5	290.24	242.31	306.97	490.3
3/5/18	12:37	326.2	291.34	242.7	308.17	490.2
3/5/18	12:38	327.2	291.8	242.83	308.28	485.27
3/5/18	12:39	328.6	292.31	243.65	309.49	482.05
3/5/18	12:40	329.5	292.78	245.11	310.77	483.68
3/5/18	12:41	330.6	293.11	245.22	312.79	486.88
3/5/18	12:42	331.5	293.98	244.57	313.26	486.94
3/5/18	12:43	332.9	294.04	247.43	313.95	486.05
3/5/18	12:44	334.4	295.14	247.36	314.04	482.41
3/5/18	12:45	336	296.58	247.54	314.63	483.04
3/5/18	12:46	337.5	297.65	249.19	315.84	485.5
3/5/18	12:47	338.6	297.12	249.09	316.04	481.84
3/5/18	12:48	339	297.7	250.53	316.85	474.41
3/5/18	12:49	340.6	298.19	250.24	318.47	474.59
3/5/18	12:50	340.9	298.78	249.05	318.34	471.75
3/5/18	12:51	342.2	298.9	250.42	318.35	465.82
3/5/18	12:52	343.2	298.69	251.52	318.9	462.28
3/5/18	12:53	344	299.6	252	320.08	466.38
3/5/18	12:54	345	300.58	251.92	320.69	464.32
3/5/18	12:55	346.1	301.06	252.55	321.18	463.17
3/5/18	12:56	346.3	301.59	251.11	321.63	462.1
3/5/18	12:57	347.4	301.8	252.62	322.76	460.69
3/5/18	12:58	348.3	302.07	251.96	324.01	456.63

333.72 Average Sur

3/5/18	12:59	349.1	302.77	252.92	324.42	455.35
3/5/18	13:00	349.6	302.99	253.51	325.03	450.61
3/5/18	13:01	349.7	303.47	251.92	325.86	446.79
3/5/18	13:02	349.9	303.99	250.66	326.95	446.61
3/5/18	13:03	350	304.3	248.85	327.14	445.62
3/5/18	13:04	350.3	304.63	249.78	327.47	440.38
3/5/18	13:05	350.4	304.71	250.83	328	438.68
3/5/18	13:06	350.4	305.33	250.67	328.73	436.49
3/5/18	13:07	350.6	306.12	250.84	329.16	435.02
3/5/18	13:08	350.2	306.1	249.63	329.72	433.08
3/5/18	13:09	350.1	305.87	250.32	329.92	429.38
3/5/18	13:10	350.4	305.57	250	330.61	426.2
3/5/18	13:11	350.6	305.92	248.88	330.67	425.02
3/5/18	13:12	350.2	306.14	249.17	330.71	423.09
3/5/18	13:13	350.1	306.17	249.64	330.95	420.23
3/5/18	13:14	349.8	306.69	247.86	331.34	419.52
3/5/18	13:15	350.7	307.59	247.92	331.26	417.41
3/5/18	13:16	351	307.79	248.7	330.76	415
3/5/18	13:17	351.2	307.31	248.49	330.78	414.52
3/5/18	13:18	350.5	307.59	248.45	331.11	412.8
3/5/18	13:19	350.4	308.29	248.38	330.55	410.88
3/5/18	13:20	350.3	309.18	247.52	329.64	406.83
3/5/18	13:21	350.2	309.4	248.63	329.24	405.52
3/5/18	13:22	349.6	309.18	249.15	329.12	403.03
3/5/18	13:23	349.4	309.05	249.32	329.45	401.54
3/5/18	13:24	350.6	310.24	248.12	329.08	401.5
3/5/18	13:25	350.1	310.34	248.97	328.94	399.03
3/5/18	13:26	349.9	310.34	249.36	329.04	399.4
3/5/18	13:27	349.7	310.94	248.54	329.01	396.78
3/5/18	13:28	350	311.48	248.65	328.45	397.34
3/5/18	13:29	349.9	311.88	248.15	327.91	398.24
3/5/18	13:30	349.4	311.75	249.61	327.98	399.27
3/5/18	13:31	349.3	312.2	250.05	328.4	396.74
3/5/18	13:32	349.1	312.93	249.84	327.72	394.06
3/5/18	13:33	349.1	313.4	248.85	327.56	395.6
3/5/18	13:34	348.7	313.47	250.28	327.57	395.33
3/5/18	13:35	349	313.97	250.29	327.28	392.4
3/5/18	13:36	348.3	314.4	250.1	326.64	390.46
3/5/18	13:37	348.6	315.12	251.02	326.52	389.65
3/5/18	13:38	348.4	315.21	252.3	327.09	388.66
3/5/18	13:39	347.9	316.37	252	326.68	386.82
3/5/18	13:40	346.8	316.72	251.61	325.75	384.8
3/5/18	13:41	347.1	317.54	251.41	325.09	383.28
3/5/18	13:42	347.1	318.03	252.16	325.27	379.22
3/5/18	13:43	347	318.09	252.92	326.16	381.94
3/5/18	13:44	346.9	319.39	252.97	325.67	380.82
3/5/18	13:45	346.8	320.41	253.36	324.93	381.16
3/5/18	13:46	347	320.95	252.26	324.46	379.52

3/5/18	13:47	346.9	321.09	253.42	324.76	375.07
3/5/18	13:48	346.2	321.7	252.12	324.74	376.04
3/5/18	13:49	346.1	322.74	252.9	324.64	376.78
3/5/18	13:50	346	323.91	254.08	323.92	373.8
3/5/18	13:51	346.1	323.99	254.41	324.38	372.54
3/5/18	13:52	346.2	324.39	254.58	324.7	373.03
3/5/18	13:53	345.5	325.45	254.3	323.91	374.72
3/5/18	13:54	345.2	326.68	255.5	323.75	373.27
3/5/18	13:55	345.2	326.95	254.53	324.02	372.18
3/5/18	13:56	345.1	327.15	254.69	323.96	370.21
3/5/18	13:57	344.4	327.24	255.75	323.64	368.41
3/5/18	13:58	343.3	328.53	255.61	323.71	369.87
3/5/18	13:59	343.1	328.83	256.02	324.32	372.07
3/5/18	14:00	342.9	329.06	255.27	324.19	369.6
3/5/18	14:01	342.6	330	255.79	323.32	368.49
3/5/18	14:02	342.3	330.69	256.71	323.08	364.95
3/5/18	14:03	342.1	331.58	257.07	323.64	366.73
3/5/18	14:04	342.5	331.51	257.87	324.06	365.67
3/5/18	14:05	342.2	331.84	255.39	323.68	363.4
3/5/18	14:06	340.8	332.89	255.8	323.88	360.66
3/5/18	14:07	340.9	333.43	256.19	324.4	360.34
3/5/18	14:08	339.9	333.49	254.99	323.94	359.11
3/5/18	14:09	339.6	333.94	256.27	323.29	356.97
3/5/18	14:10	339.2	334.57	256.31	322.67	355.64
3/5/18	14:11	338.9	335.01	256.88	323.25	354.57
3/5/18	14:12	338.2	335.37	256.58	323.65	352.91
3/5/18	14:13	337.7	335.57	256.06	323.27	352.71
3/5/18	14:14	337.2	335.88	256.86	322.61	352.86
3/5/18	14:15	336.8	336.02	259.03	322.56	351.67
3/5/18	14:16	335.7	337.03	258.37	322.97	350.22
3/5/18	14:17	335.1	337.1	258.05	322.94	350.6
3/5/18	14:18	333.5	336.67	259.28	322.67	350.01
3/5/18	14:19	333.4	337.83	258.82	322.8	351.08

320.786 Average Sur

	A	B	C	D	E	F	G	H
1	Test ID	CSL-00010						
2	Technician	BV, KO'B						
3	Date	3/6/18						
4	Start Time	10:15						
5	End Time	10:30						
6	Barometric Pressure	29.8	in Hg					
7	Room Temperature	64	F					
8	Relative Humidity	36	%					
9	Saturation Pressure	0.395	psia					
10	Actual Fan Speed for Test (Hz)	16	Hz					
11	PreTest Pitot		in. water					
12	Leak Rate (15 seconds)	0	in. water	<--Must be 0				
13	Static Pressure in Appliance (no DT)	0	in. water	Static Pressure in Appliance must be taken within 1 ft of top of appliance				
14	Static Pressure in Appliance (DT)	0	in.					
15	Difference	0	in. water	"Difference" must be less than 0.005 in WC				
16	Diameter of Tunnel (in)	8	in.					
17	Static Pressure in Dilution Tunnel (beginning)	0	in. water					
18	Point			Port A		Port B		
19		% of Diameter	Distance (inches)	Δp (in water)	Temperature (F)	Δp (in water)	Temperature (F)	
20	1	n/a	n/a	n/a	n/a	n/a	n/a	
21	2	6.7	0.536	0.03	65	0.04	65	
22	3	25	2.0	0.035	65	0.045	65	
23	Center	50	4.0	0.05	65	0.055	65	
24	4	77	6.0	0.055	65	0.06	65	
25	5	93.3	7.46	0.06	65	0.06	65	
26	6	n/a	n/a	n/a	n/a	n/a	n/a	
27	PostTest Pitot							
28	Static Pressure (after test)	0	in. water					
29	Leak Rate (15 seconds)	0	in. water					

ISS-1 ΔH@	
ISS-2 ΔH@	

Signature _____

PRELIMINARY VELOCITY DETERMINATION

Test ID	CSL-00010
Date	3/6/18

Static Pressure (Pg)	0.000 in W.C.
Pitot Coefficient	0.99 unitless
Gas Molecular Weight (MW) wet	29.0 lb/lb-mole
Diameter of Tunnel	8.000 inches
Dilution Tunnel Cross Sectional Area	0.349 FT ²

POINT	% of Diameter	Distance (inches)	Port A				Port B			
			Δp (in W.C.)	√Δp (in W.C.)	Temp (F)	Temp (R)	Δp (in water)	√Δp (in W.C.)	Temp (F)	Temp (R)
1	n/a	n/a	n/a	#VALUE!	n/a	#VALUE!	n/a	#VALUE!	n/a	#VALUE!
2	6.7	0.54	0.030	0.17	65.0	525	0.040	0.20	65.0	525
3	25.0	2.00	0.035	0.19	65.0	525	0.045	0.21	65.0	525
Center	50.0	4.00	0.050	0.22	65.0	525	0.055	0.23	65.0	525
4	77.0	6.00	0.055	0.23	65.0	525	0.060	0.24	65.0	525
5	93.3	7.46	0.060	0.24	65.0	525	0.060	0.24	65.0	525
6	n/a	n/a	n/a	#VALUE!	n/a	#VALUE!	n/a	#VALUE!	n/a	#VALUE!
			AVERAGE	0.22	AVERAGE	525				

DILUTION TUNNEL CALCULATIONS

Absolute Gas Temperature; $Tst = Ts + 459.67^{\circ}$	Tst = 525 °R
Absolute Gas Pressure; $Ps = Pb + Pg/13.6$	Ps = 29.8 inches Hg
Gas Velocity; $Vs = (85.49) \times Cp \times (avg \sqrt{\Delta P}) \times \sqrt{(Tst \text{ avg}/(Ps \times Mw))}$	Vs = 14.51 FT/sec
Gas Flow Rate; $Qa = Vs \times 60 \times \text{cross sectional area}$	Qa = 304 ACFM
	870 FT/min

V_{trav} CALCULATIONS

Absolute Gas Temperature; $Tst = Ts + 459.67^{\circ}$	Tst = 525 °R
Absolute Gas Pressure; $Ps = Pb + Pg/13.6$	Ps = 29.8 inches Hg
Gas Velocity; $Vs = (85.49) \times Cp \times (avg \sqrt{\Delta P}) \times \sqrt{(Tst \text{ avg}/(Ps \times Mw))}$	Vs = 14.36 FT/sec
Gas Flow Rate; $Qa = Vs \times 60 \times \text{cross sectional area}$	Qa = 301 ACFM
	861 FT/min

0.950 Fp

V_{scen} CALCULATIONS

Absolute Gas Temperature; $Tst = Ts + 459.67^{\circ}$	Tst = 525 °R
Absolute Gas Pressure; $Ps = Pb + Pg/13.6$	Ps = 29.8 inches Hg
Gas Velocity; $Vs = (85.49) \times Cp \times (avg \sqrt{\Delta P}) \times \sqrt{(Tst \text{ avg}/(Ps \times Mw))}$	Vs = 15.11 FT/sec
Gas Flow Rate; $Qa = Vs \times 60 \times \text{cross sectional area}$	Qa = 316 ACFM
	906 FT/min

METER BOX CALCULATIONS

Proposed Proportional Sampling Rate; PR	1.00
Sample Probe Inside Diameter	.175 inches
Sample Probe Cross Sectional Area	.00017 FT ²

	277 SCFM
Pstd	14.696 psia
Pact	14.4 psia
Psat	0.395 psia
Humidity	0.36 %/100
Tact	523.67 R
Tstd	491.67 R

Signature _____

Test ID:	CSL-00010
Date:	3.6.18

Fuel Type	
Preburn or Test Fuel Charge	

Test Fuel Pieces Weight (lbs)	Total Spacer Weight (lbs)	Total Test Fuel Charge Weight
10.74	0.78	11.52

Average Test Fuel MC%	Test Fuel Density	Dry Basis Weight (lbs)	Charcoal Bed Loading Range (lbs)
22.61	25	8.31	2.30 to 2.88

***Test Fuel Loading Density must be between 25-36 lb/ft³ dimension of the firebox length*

Piece Number	Piece Size (in):			Weight (lbs):	Moisture Content			Average MC (%)	Volume		Avg. MC% x Dry Basis Weight
	Length	Width	Height		Moisture #1 (%)	Moisture #2 (%)	Moisture #3 (%)		Cubic Inches	ft ³	
1								#DIV/0!	0	0	0.00000
2								#DIV/0!	0	0	0.00000
3	14.50	3.50	1.50	1.26	22.8	23.8	21.8	22.80	76.125	76.125	0.00000
4	14.50	3.50	3.50	3.38	23.7	22.9	24.7	23.77	177.625	177.625	0.00000
5	14.50	3.50	3.50	3.42	23.4	22.7	24.6	23.57	177.625	177.625	0.00000
6	14.50	3.50	1.50	1.42	21.4	23.0	20.5	21.63	76.125	76.125	0.00000
7	14.50	3.50	1.50	1.26	21.0	20.2	22.6	21.27	76.125	76.125	0.00000
8								#DIV/0!	0	0	0.00000
9								#DIV/0!	0	0	0.00000
10								#DIV/0!	0	0	0.00000
11								#DIV/0!	0	0	0.00000
12								#DIV/0!	0	0	0.00000
13								#DIV/0!	0	0	0.00000
14								#DIV/0!	0	0	0.00000
15								#DIV/0!	0	0	0.00000
16								#DIV/0!	0	0	0.00000
17								#DIV/0!	0	0	0.00000
18								#DIV/0!	0	0	0.00000
19								#DIV/0!	0	0	0.00000
20								#DIV/0!	0	0	0.00000
21								#DIV/0!	0	0	0.00000
22								#DIV/0!	0	0	0.00000
23								#DIV/0!	0	0	0.00000
24								#DIV/0!	0	0	0.00000
25								#DIV/0!	0	0	0.00000

Total Test Fuel Volume (in³):	583.625
Total Test Fuel Volume (ft³):	0.3377

Technician Signature: *RB-22*
 Quality Review: *Kelli O'Brien*

Number of Spacers	10
Total Spacer Weight (lbs)	0.78
Average Spacer Moisture (%)	16.88

Spacer Number	Piece Size (in)			Moisture Content (%)
	Length	Width	Height	
1	5.00	1.50	0.75	16.8
2	5.00	1.50	0.75	16.4
3	5.00	1.50	0.75	16.2
4	5.00	1.50	0.75	19.6
5	5.00	1.50	0.75	12.6
6	5.00	1.50	0.75	14.7
7	5.00	1.50	0.75	20.1
8	5.00	1.50	0.75	17.4
9	5.00	1.50	0.75	23.0
10	5.00	1.50	0.75	12.0
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

RB-26
Kelli O'Brien

Test ID:	CSL-00010
Date:	3.6.18

Fuel Type	Doug. Fir Crib
Preburn or Test Fuel Charge	Test Fuel


Test Fuel Pieces Weight (lbs)	Total Spacer Weight (lbs)	Total Test Fuel Charge Weight
11.06	0.92	11.98

Average Test Fuel MC%	Test Fuel Density	Dry Basis Weight (lbs)	Charcoal Bed Loading Range (lbs)
22.33	25	8.59	2.40 to 3.00

***must be between 19-25% **Test Fuel Loading Density must be between 25-36 lb/ft³ ***Invariable piece length snail closely approximate 5/16 the dimension of the firebox length*

Piece Number	Piece Size (in):		Weight (lbs):	Moisture Content		Average MC (%)	Volume		Avg. MC% x Dry Basis Weight
	Length	Width		Height	Moisture #1 (%)		Moisture #2 (%)	Moisture #3 (%)	
1						#DIV/0!		0	0.00000
2	14.50	3.50	1.50	20.9	20.7	22.0	76.125	76.125	0.00000
3	14.50	3.50	1.50	22.9	23.9	21.3	76.125	76.125	0.00000
4	14.50	3.50	3.50	22.0	22.5	23.2	177.625	177.625	0.00000
5	14.50	3.50	3.50	23.4	23.5	22.6	177.625	177.625	0.00000
6	14.50	3.50	1.50	22.0	22.0	22.0	76.125	76.125	0.00000
7						#DIV/0!	0	0	0.00000
8						#DIV/0!	0	0	0.00000
9						#DIV/0!	0	0	0.00000
10						#DIV/0!	0	0	0.00000
11						#DIV/0!	0	0	0.00000
12						#DIV/0!	0	0	0.00000
13						#DIV/0!	0	0	0.00000
14						#DIV/0!	0	0	0.00000
15						#DIV/0!	0	0	0.00000
16						#DIV/0!	0	0	0.00000
17						#DIV/0!	0	0	0.00000
18						#DIV/0!	0	0	0.00000
19						#DIV/0!	0	0	0.00000
20						#DIV/0!	0	0	0.00000
21						#DIV/0!	0	0	0.00000
22						#DIV/0!	0	0	0.00000
23						#DIV/0!	0	0	0.00000
24						#DIV/0!	0	0	0.00000
25						#DIV/0!	0	0	0.00000

Total Test Fuel Volume (in³):	583.625
Total Test Fuel Volume (ft³):	0.3377


 Technician Signature
 Quality Review

Number of Spacers	10
Total Spacer Weight (lbs)	0.92
Average Spacer Moisture (%)	15.90

Spacer Number	Piece Size (in)			Moisture Content (%)
	Length	Width	Height	
1	5.00	1.50	0.75	20.2
2	5.00	1.50	0.75	11.5
3	5.00	1.50	0.75	17.9
4	5.00	1.50	0.75	14.3
5	5.00	1.50	0.75	17.0
6	5.00	1.50	0.75	13.2
7	5.00	1.50	0.75	15.1
8	5.00	1.50	0.75	16.6
9	5.00	1.50	0.75	14.2
10	5.00	1.50	0.75	19.0
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

23-24

Kelli Oberlin

Method 28 Data Collection	
Date	3/6/18
Operator	BV, KO'B
Test Type	Method 28R
Run #	2
Wood Heater Information	
Manufacturer/Model	MF Fire, Nova
Test ID	CSL-00010
Volume of water in Appliance (gal)	n/a
Weight of Appliance (empty) (lbs)	303.2
Volume of water in Storage (gal)	n/a
Weight of Storage Tank(s) (empty) (lbs)	n/a
Primary Air Setting (Hz)	n/a single burnrate stove
Secondary Air Setting (Hz)	n/a single burnrate stove
Thermostat Setting (F)	n/a
Fuel Type	Doug Fir crib wood

Velocity Traverse	
Static Pressure (in WC)	0
Vstrav (ACFM)	301
Vscent (ACFM)	316
Pre-Test Conditions	
Desired Flow Rate (load Side) (GPM)	n/a
Pre-test destratification volume pumped (need 2x) (gal)	n/a
Pre-test temperature difference (post destratification) (F)	n/a
Test facility temp at test start (F)	70
Room air velocity (FPM)	5,9,12
Ambient relative humidity (%)	34
Ambient barometric pressure (in Hg)	29.8
Adjustments to pre-test fuel	See Kelvin
Coal-bed weight prior to test start (lbs)	2.5

Post-Test Conditions	
Time of TFS ₂₀ (nh:mm) (leave blank if Cat. III or IV)	n/a
room air velocity immediately following run (FPM)	8,12,8
test facility temperature after run (F)	73
ambient relative humidity after run (%)	30
ambient barometric pressure after run (in Hg)	29.75
Weight of unburnt fuel (lbs)	n/a

Note** When inputting data from the logger, the start time of the input must coincide with the start time of the test.

Signature _____

Ambient

Test ID	CSL-00010
Date	3/6/18
Start Time (hh:mm:ss)	11:49
End Time (hh:mm:ss)	14:32
Y (DGM calibration factor)	1.00243
Pre test leak (A cfm @ B in Hg)	0.00 @20 in. WC
Post test leak (A cfm @ B in Hg)	0.00 @ 20 in. WC

Filter Assemblies		
A	FH #	FH-01, FF-18
	Front Filter #	G-18-0009
	Back Filter #	n/a
B	FH #	
	Front Filter #	
	Back Filter #	

*Pre and Post leak checks should be 60 seconds in duration

Duration (hh:mm:ss)	DGM (m ³)	ΔH (in H ₂ O)
0:00:00	91.2246	4.0
0:10:00	91.2452	3.5
0:20:00	91.2676	3.5
0:30:00	91.2892	3.5
0:40:00	91.3109	3.5
0:50:00	91.3324	3.5
1:00:00	91.3538	3.5
1:10:00	91.3686	3.5
1:20:00	91.3900	3.5
1:30:00	91.4114	3.5
1:40:00	91.4328	3.5
1:50:00	91.4544	3.5
2:00:00	91.4758	3.5
2:10:00	91.4978	3.5
2:20:00	91.5196	3.5
2:30:00	91.5408	3.5
2:40:00	91.5624	3.5
2:44:54	91.5730	
3:00:00		
3:10:00		
3:20:00		
3:30:00		
3:40:00		
3:50:00		
4:00:00		

Flow (l/min)	ΔP (in H ₂ O)
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.065
2.0	0.060
2.0	0.060
2.0	0.060
2.0	0.055
2.0	0.050
2.0	0.050
2.0	0.055
2.0	0.060

Signature _____

ISS-2

		Filter Change 1	Filter Change 2	Filter Change 3	
Weight (lbs)					
Elapsed Time Paused (hh:mm:ss)					
Elapsed Time Resume (hh:mm:ss)					
Actual Time Pause (hh:mm:ss)		11:49:00	11:49:00	11:49:00	
Actual Time Resume (hh:mm:ss)		11:49:00	11:49:00	11:49:00	
Test ID	CSL-00010	Filter Assemblies			
Date	3/6/18	A	FH #	FH-07, FH-6, FF-3	
Start Time (hh:mm:ss)	11:49		Front Filter #	G-18-0012	
End Time (hh:mm:ss)	14:32		Back Filter #	G-18-0013	
Y (DGM calibration factor)	1.0032	B	FH #	FH-09, FH-08, FF-21	
Pre test leak (A cfm @ B in Hg)	0.00 @ 15 in. Hg		Front Filter #	G-18-0014	
Post test leak (A cfm @ B in Hg)	0.00 @ 5 in. Hg		Back Filter #	G-18-0015	
		C	FH #		
			Front Filter #		
			Back Filter #		
Duration (hh:mm:ss)	DGM (ft ³)	ΔH (in H ₂ O)	Module In Temp (°F)	Module Out Temp (°F)	Vacuum (in Hg)
0:00:00	715.535	0.15	70	70	3.0
0:10:00	717.998	0.15	70	69	2.0
0:20:00	720.428	0.15	70	70	2.0
0:30:00	722.865	0.15	71	70	2.0
0:40:00	725.349	0.15	72	71	2.0
0:50:00	727.767	0.15	73	71	2.0
1:00:00	730.102	0.15	73	72	2.0
1:10:00	732.024	0.15	74	72	2.0
1:20:00	734.378	0.15	74	73	2.0
1:30:00	736.785	0.15	74	73	2.0
1:40:00	739.238	0.15	74	73	2.0
1:50:00	741.795	0.15	75	74	2.0
2:00:00	744.175	0.15	75	74	2.0
2:10:00	746.695	0.15	75	74	2.5
2:20:00	749.173	0.15	75	74	2.5
2:30:00	751.549	0.15	75	74	2.0
2:40:00	753.897	0.15	75	74	2.0
2:44:54	755.033				
3:00:00					
3:10:00					

*Pre and Post leak checks should be 60 seconds in duration

PM Sampling Flow may be 0.15-.25 cfm

Signature _____

Test ID:		CSL-00010				
Date:		3/6/18				
ISS# / AS#	Filter / FH ID #	Pre-Weight Avg (g)	Post Weight Avg (g)	Total Catch (g)	Total Catch (mg)	
Ambient	AS-1	G-18-0009	0.1122	0.1122	0.0000	0.000
	AS-1	FF-18	63.9361	63.9362	0.0001	0.100
ISS 1	ISS-1	G-18-0010	0.1122	0.1203	0.0081	8.100
	ISS-1	G-18-0011	0.1167	0.1180	0.0013	1.300
	ISS-1	FF-20	63.9669	63.9668	-0.0001	0.000
ISS 2A	ISS-2	G-18-0012	0.1120	0.1200	0.0080	8.000
	ISS-2	G-18-0013	0.1130	0.1141	0.0011	1.100
	ISS-2	FF-03	64.2317	64.2314	-0.0003	0.000
ISS 2B	ISS-2	G-18-0014	0.1173	0.1179	0.0006	0.600
	ISS-2	G-18-0015	0.1114	0.1115	0.0000	0.050
	ISS-2	FF-21	63.9452	63.9453	0.0001	0.100
n/a	ISS-2				0.0000	0.000
	ISS-2				0.0000	0.000
	ISS-2				0.0000	0.000

Signature _____

Test ID	CSL-00010
Date	3/6/18

Module 1			
Variable	Description	Value	Units
	final volume module 1	449.578	cubic feet
	initial volume module 1	408.940	cubic feet
V_{col}	total gas volume collected (module 1)	40.638	cubic feet
Average ΔH	average delta H over entirety of run	0.15	in water
T_m	average gas meter temperature	70	°F
P_{bar}	barometric pressure	29.8	in Hg
Y	DGM calibration factor	1.004	unitless
K_1	volume corrected to standard conditions	17.64	R/(in Hg)
V_{total}	volume gas sampled (corrected to standard conditions)	40.4749538	dsf
Total Catch	total catch (raw data)	9.4	mg
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00023224	g/dscf

Module 2			
Variable	Description	Value	Units
	final volume module 2	755.033	cubic feet
	initial volume module 2	715.535	cubic feet
V_{col}	total gas volume collected (module 2)	39.498	cubic feet
Average ΔH	average delta H over entirety of run	0.15	in water
T_m	average gas meter temperature	73	°F
P_{bar}	barometric pressure	29.8	in Hg
Y	DGM calibration factor	1.003	unitless
K_1	volume corrected to standard conditions	17.64	°F/(in Hg)
V_{total}	volume gas sampled (corrected to standard conditions)	39.13774663	dsf
Total Catch	total catch (raw data)	9.85	mg
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.000251675	g/dscf

Ambient			
Variable	Description	Value	Units
	final volume ambient	91.5730	cubic meters
	initial volume ambient	91.2246	cubic meters
V_{col}	total gas volume collected (ambient)	12.3036	cubic feet
Average ΔH	average delta H over entirety of run	3.53	in water
T_m	average gas meter temperature	69.6	°F
P_{bar}	barometric pressure	29.8	in Hg
Y	DGM calibration factor	1.002	unitless
K_1	volume corrected to standard conditions	17.64	°F/(in Hg)
V_{total}	volume gas sampled (corrected to standard conditions)	12.35637281	dsf
Total Catch	total catch (raw data)	0.1	mg
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	8.09299E-06	g/dscf

Total Particulate Matter (based on ISS-2 and AS-1 data)			
Variable	Description	Value	Units
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00024196	g/dscf
C_2	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	8.093E-06	g/dscf
Q_{dil}	average gas flow rate through dilution tunnel	302.182338	dscf/min
B_{dil}	water vapor in gas stream (assumed) (proportion by volume)	0.02	unitless
v_a	average velocity of gas through dilution tunnel	15.7196192	ft/s
A	cross-sectional area of dilution tunnel	0.349	square ft
T_c	average gas temperature in dilution tunnel	561.389512	R
T_{dil}	absolute average gas temperature in dilution tunnel	528	R
P_1	average gas static pressure in dilution tunnel	29.8	in Hg
P_{std}	standard absolute pressure	29.92	in Hg
F_p	adjustment factor for center of tunnel pitot tube placement	0.95	unitless
V_{meas}	average gas velocity after multi-point pitot traverse	301	ACFM
V_{total}	average gas velocity at center of dilution tunnel calculated after pitot tube traverse	316	ACFM
K_p	pitot tube constant	85.49	$\frac{ft \cdot lb}{min \cdot in^2} = \frac{ft \cdot lb}{min \cdot in^2}$
C_p	pitot tube coefficient	0.99	unitless
ΔP_{meas}	average velocity pressure in dilution tunnel	0.05852941	in H ₂ O
M_d	dilution tunnel dry gas MW (assumed)	29	lb/(lb-mol)
θ	total sampling time	163.00	min
E_T	total particulate emissions	11.5192287	g

Signature _____

Test ID:	CSL-00010
Date:	3/5/18

Q_{in}	Btu	#DIV/0!	
$Q_{in,UVV}$		#DIV/0!	
$Q_{in,Controlled}$	Btu	#DIV/0!	
Q_{out}	Btu	#VALUE!	(3 sig figs)
Heat Output Rate	Btu/hr	#VALUE!	(3 sig figs)
Load Draw	Btu/hr		0
$E_{p,MJ}$	g/MJ	#VALUE!	
$E_{in/MMBtu}$	lb/MMBtu	#VALUE!	
$E_{p/kg}$	g/kg	#REF!	
$E_{p/hr}$	g/hr		4.240206889
Θ_1	min		0.00
Θ_2	min		0.00
Θ_3	min		163.00
Θ_4	hours		0
Θ	hours		2.72
η_{out}	%	#VALUE!	
$\eta_{out,UVV}$	%	#VALUE!	

E_1	g	#DIV/0!
E_2	g	#DIV/0!
E_3	g	-0.17914
$E_{1,air}$	g/kg	#DIV/0!
$E_{2,air}$	g/kg	#DIV/0!
$E_{3,air}$	g/kg	#N/A
ET	g	11.51922872

Run #		2
Wood Weight	lbs	0.00
Wood Moisture	%DB	#DIV/0!
Min H ₂ O Temp (T ₂)	°F	#N/A

CO _{out}	Startup CO emission (g)	#N/A
CO _{out}	Steady State CO emission (g)	#N/A
CO _{out}	End CO emission (g)	#N/A
COT	Total CO emission (g)	#N/A

Signature _____

Reporting Period: 03/06/2018 to 03/06/2018

Site Name: SAMPLE

Time of Report: 03/06/18 14:51

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	Z (none)	COND2OUI (Deg_F)	DIL_CO2 (%)	DILRATIO (RATIO)	FILT1OUT (Deg_F)	FILT2OUT (Deg_F)	ROOM_TMI (Deg_F)	TUNL_TMP (Deg_F)	UNIT_WT (lbs)	
3/6/18	10:30	1	63.3		0.112	65.1	65.5	64.5	67.9	1.55	Preburn
3/6/18	10:31	1	63.4		-0.324	65.1	65.6	64.5	67	1.41	
3/6/18	10:32	1	63.3		0.255	65	65.5	64.8	71.8	1.44	
3/6/18	10:33	1	63.5		1.598	65.2	65.6	64.8	77.2	1.27	
3/6/18	10:34	1	63.4		2.241	65.2	65.7	64.7	83.6	1.07	
3/6/18	10:35	1	63.5		2.764	65.2	65.7	64.8	85.4	0.9	
3/6/18	10:36	1	63.5		2.981	65.3	65.7	65	88	0.72	
3/6/18	10:37	1	63.6		3.257	65.3	65.9	64.9	86	0.61	
3/6/18	10:38	1	63.4		3.188	65.3	65.9	65.3	85.9	0.85	
3/6/18	10:39	1	63.6		3.209	65.4	66	65.1	86.8	11.01	
3/6/18	10:40	1	63.8		3.437	65.5	66.2	65.2	84.8	11.96	
3/6/18	10:41	1	63.9		3.306	65.5	66.2	65.3	84.5	11.94	
3/6/18	10:42	1	63.9		3.262	65.5	66.3	65.3	85.5	11.89	
3/6/18	10:43	1	64		3.077	65.7	66.5	65.3	89.3	11.81	
3/6/18	10:44	1	64.1		3.163	65.6	66.4	65.5	90.3	11.74	
3/6/18	10:45	1	64		3.215	65.6	66.4	65.7	90.6	11.65	
3/6/18	10:46	1	64.1		3.008	65.7	66.5	65.6	96.2	11.42	
3/6/18	10:47	1	64.1		2.991	65.9	66.7	65.5	101.4	11.19	
3/6/18	10:48	1	64.2		3.089	66	66.9	65.5	103.8	11.02	
3/6/18	10:49	1	64.2		3.185	66.1	66.8	65.6	102.9	10.78	
3/6/18	10:50	1	64.2		3.15	66.1	67	65.6	102.4	10.52	
3/6/18	10:51	1	64.2		2.964	66.2	67.1	65.8	105.1	10.48	
3/6/18	10:52	1	64.4		2.925	66.3	67.3	65.9	108.5	10.33	
3/6/18	10:53	1	64.6		2.927	66.4	67.4	65.9	111.9	10.11	
3/6/18	10:54	1	64.6		2.901	66.5	67.5	65.8	115.2	9.87	
3/6/18	10:55	1	64.6		2.956	66.6	67.5	66	116.4	9.6	
3/6/18	10:56	1	64.7		3.021	66.5	67.4	66.1	116.2	9.59	
3/6/18	10:57	1	65.1		3.085	66.9	67.8	66	113.9	8.95	
3/6/18	10:58	1	65		3.069	67	67.8	66.4	113.8	8.79	
3/6/18	10:59	1	64.9		3.06	67.2	68.1	66.3	112.9	8.63	
3/6/18	11:00	1	65.2		3.018	67.2	68	66.6	113.6	8.45	
3/6/18	11:01	1	65.1		2.937	67.2	68.1	66.6	114.1	8.33	
3/6/18	11:02	1	65.3		2.989	67.4	68.2	66.8	114.7	8.22	
3/6/18	11:03	1	65.4		3.023	67.5	68.4	66.9	115	8.11	
3/6/18	11:04	1	65.6		3.06	67.6	68.4	66.7	114.7	7.92	
3/6/18	11:05	1	65.7		3.036	67.6	68.5	66.8	115.7	8.01	
3/6/18	11:06	1	65.8		2.98	67.7	68.7	67.1	116.6	7.51	
3/6/18	11:07	1	65.3		2.782	67.9	68.8	67	119.6	7.4	
3/6/18	11:08	1	65.8		2.843	68	68.8	67.2	119	7.25	
3/6/18	11:09	1	66		2.849	68.1	69	67.5	123.1	7.02	
3/6/18	11:10	1	66.1		2.986	68.3	69.2	67.6	123.3	6.75	
3/6/18	11:11	1	66		2.964	68.2	69.1	67.7	122.8	6.46	
3/6/18	11:12	1	66.3		2.86	68.5	69.4	67.6	123.7	6.16	
3/6/18	11:13	1	66.4		2.847	68.5	69.3	67.7	123.7	5.99	
3/6/18	11:14	1	66.3		2.855	68.7	69.5	67.9	123.8	5.82	
3/6/18	11:15	1	66.6		2.791	68.8	69.6	67.9	125.2	5.66	
3/6/18	11:16	1	66.5		2.81	68.9	69.6	67.8	124.6	5.71	
3/6/18	11:17	1	66.6		2.884	69	69.7	68	122.5	5.49	
3/6/18	11:18	1	66.7		2.908	69.1	69.8	68.1	123.6	5.35	
3/6/18	11:19	1	66.8		2.902	69.3	69.9	68.4	123.8	5.13	
3/6/18	11:20	1	67		2.912	69.3	69.9	68.2	122.6	4.97	
3/6/18	11:21	1	67		2.853	69.4	70	68.2	123.9	6.52	
3/6/18	11:22	1	67.3		2.876	69.7	70.3	68.5	123.8	6.46	
3/6/18	11:23	1	67.2		3.027	69.8	70.3	68.5	120.1	3.19	
3/6/18	11:24	1	67.3		2.89	69.8	70.4	68.8	122.2	4.75	
3/6/18	11:25	1	67.5		2.817	70	70.5	68.2	122.2	4.87	
3/6/18	11:26	1	67.5		2.851	69.9	70.4	67.5	124.3	4.58	
3/6/18	11:27	1	67.6		2.851	69.9	70.4	67.7	125.9	4.32	
3/6/18	11:28	1	67.6		2.79	69.8	70.3	67.8	127.6	4.04	
3/6/18	11:29	1	67.7		2.836	69.9	70.2	67.6	125.7	3.96	
3/6/18	11:30	1	67.7		2.906	69.9	70.2	67.2	120.5	4.13	
3/6/18	11:31	1	67.9		2.89	70	70.3	67.7	122.6	3.46	
3/6/18	11:32	1	67.8		2.803	69.8	70.1	67.7	121.7	3.18	

3/6/18	11:33	1	68	2.798	69.6	69.8	67.8	121.6	3.05	
3/6/18	11:34	1	67.6	2.782	69.9	70.1	67.7	124.1	3.27	
3/6/18	11:35	1	67.7	2.788	69.8	70.1	68.1	127.9	3.83	
3/6/18	11:36	1	67.9	2.72	69.8	70.1	68	130.5	4.98	
3/6/18	11:37	1	67.6	2.785	69.9	70.3	68.2	128.1	4.51	
3/6/18	11:38	1	67.7	2.809	70	70.3	68	124.9	4.64	
3/6/18	11:39	1	67.7	2.76	69.9	70.3	67.7	123.6	4.06	
3/6/18	11:40	1	67.6	2.789	69.9	70.2	67.9	122.1	3.89	
3/6/18	11:41	1	67.4	2.834	69.8	70.2	67.8	121.8	4.03	
3/6/18	11:42	1	67.5	2.884	69.8	70.2	67.9	119.9	3.46	
3/6/18	11:43	1	67.6	2.872	69.8	70.2	67.5	119.6	3.29	
3/6/18	11:44	1	67.7	2.813	69.8	70.2	67.7	120.9	3.2	
3/6/18	11:45	1	67.6	2.868	69.6	70.1	67.7	119.3	3	
3/6/18	11:46	1	67.5	3.011	69.6	70.1	67.8	114.8	2.86	
3/6/18	11:47	1	67	2.988	69.6	70.5	67.7	113.2	2.89	Test Start
3/6/18	11:48	1	66.4	2.791	70.4	73.5	67.8	121.6	8.31	Fuel consumed, 2.5 lb coal bed
3/6/18	11:49	1	65.7	3.042	71.6	77.3	68	117	14.5	12
3/6/18	11:50	1	65.3	3.073	72.4	78.5	68	112	14.4	11.9
3/6/18	11:51	1	64.9	2.996	73.2	79.4	67.8	110.4	14.31	11.81
3/6/18	11:52	1	64.8	3.002	73.9	79.9	67.9	109.1	14.19	11.69
3/6/18	11:53	1	64.6	2.977	74.5	80.5	68.2	108.4	14.07	11.57
3/6/18	11:54	1	64.4	2.906	74.9	80.8	67.8	107.6	13.97	11.47
3/6/18	11:55	1	64.4	2.935	75.5	81.3	68	107.1	13.87	11.37
3/6/18	11:56	1	64.5	2.917	75.9	81.4	68.4	106.9	13.76	11.26
3/6/18	11:57	1	64.4	2.919	76.1	81.6	67.8	106.1	13.7	11.2
3/6/18	11:58	1	64.2	3.013	76.5	81.7	67.3	104.7	13.62	11.12
3/6/18	11:59	1	64.1	3.013	76.6	81.8	67.2	104.1	13.53	11.03
3/6/18	12:00	1	63.7	3.011	76.6	81.8	67.8	103.7	13.43	10.93
3/6/18	12:01	1	63.5	2.992	76.9	82	67.9	103.1	13.35	10.85
3/6/18	12:02	1	63.2	2.936	77	82	68	103.1	13.27	10.77
3/6/18	12:03	1	62.7	2.966	77.2	82.1	68	102	13.2	10.7
3/6/18	12:04	1	62.2	2.939	77.3	82.1	68	101.9	13.11	10.61
3/6/18	12:05	1	61.8	2.9	77.2	82	67.6	101.9	13.06	10.56
3/6/18	12:06	1	61.5	3.024	77.3	81.9	67.5	100.6	12.98	10.48
3/6/18	12:07	1	61	3.075	77.5	82.1	67.9	100.8	12.89	10.39
3/6/18	12:08	1	60.5	2.968	77.5	82	67.6	101.6	12.8	10.3
3/6/18	12:09	1	60.2	3.047	77.4	82	67.9	100.5	12.72	10.22
3/6/18	12:10	1	59.9	3.054	77.4	81.8	68.1	100.4	12.64	10.14
3/6/18	12:11	1	59.5	3.066	77.4	82	68.1	100.1	12.59	10.09
3/6/18	12:12	1	59.2	3.02	77.5	81.9	67.7	100.1	12.52	10.02
3/6/18	12:13	1	59	2.998	77.5	82	67.9	100.8	12.37	9.87
3/6/18	12:14	1	58.7	3.031	77.4	82	68	100.8	12.26	9.76
3/6/18	12:15	1	58.6	3.068	77.4	81.9	67.8	100.8	12.16	9.66
3/6/18	12:16	1	58.3	3.026	77.4	81.9	67.6	101.2	12.09	9.59
3/6/18	12:17	1	58.1	3.026	77.4	81.9	67.9	101.4	11.99	9.49
3/6/18	12:18	1	57.8	3.006	77.5	82	67.7	101.2	11.85	9.35
3/6/18	12:19	1	57.9	3.033	77.6	82.1	68	101.4	11.75	9.25
3/6/18	12:20	1	57.4	3.077	77.4	82	68.2	101.8	11.65	9.15
3/6/18	12:21	1	57.2	3.162	77.5	82.1	67.7	100.4	11.58	9.08
3/6/18	12:22	1	57	3.101	77.5	82.1	68	101	11.45	8.95
3/6/18	12:23	1	56.9	3.053	77.5	82	67.8	101.4	11.33	8.83
3/6/18	12:24	1	56.7	3.036	77.5	82.2	67.8	101.9	11.19	8.69
3/6/18	12:25	1	56.6	3.044	77.6	82.3	67.7	102.1	11.1	8.6
3/6/18	12:26	1	56.5	3.118	77.7	82.4	68.1	102	10.93	8.43
3/6/18	12:27	1	56.3	3.111	77.8	82.7	68.6	102.9	10.84	8.34
3/6/18	12:28	1	56.5	3.084	77.7	82.7	68.2	102.5	10.73	8.23
3/6/18	12:29	1	56.1	3.04	77.7	82.6	68.1	102.6	10.61	8.11
3/6/18	12:30	1	56.1	3.14	77.7	82.7	68.3	102.8	10.45	7.95
3/6/18	12:31	1	56	3.076	77.7	82.7	68.3	102.8	10.29	7.79
3/6/18	12:32	1	55.9	3.035	77.7	82.7	68.4	103.3	10.18	7.68
3/6/18	12:33	1	56.2	3.026	77.9	83	67.8	102.8	10.11	7.61
3/6/18	12:34	1	56	3.038	77.9	82.8	67.9	102.4	9.99	7.49
3/6/18	12:35	1	55.9	3.093	78.1	83.1	68.2	103	9.87	7.37
3/6/18	12:36	1	55.9	3.088	78.2	83.1	68.2	103.2	9.76	7.26
3/6/18	12:37	1	55.8	3.044	78.3	83.1	68	103.2	9.64	7.14
3/6/18	12:38	1	55.8	2.899	78.3	83.2	67.5	103.6	9.53	7.03
3/6/18	12:39	1	55.7	2.972	78.3	83.2	68.1	103.1	9.43	6.93
3/6/18	12:40	1	55.6	3.053	78.2	83.1	68.2	103	9.33	6.83
3/6/18	12:41	1	55.7	3.062	78.3	83	68.4	103.3	9.21	6.71
3/6/18	12:42	1	55.7	3.016	78.4	83.2	68.2	103.3	9.14	6.64
3/6/18	12:43	1	55.5	3.035	78.5	83.1	68.5	103	9.06	6.56

3/6/18	12:44	1	55.4	3.012	78.4	83.2	68.5	103.6	8.96	6.46
3/6/18	12:45	1	55.4	3.081	78.4	83.2	68.2	103.3	8.85	6.35
3/6/18	12:46	1	55.4	3.052	78.5	83.3	68.4	103.6	8.73	6.23
3/6/18	12:47	1	56.2	3.063	78	81.2	68.4	103.8	8.59	6.09
3/6/18	12:48	1	57.6	3.006	77.4	153.3	68.3	104	8.44	5.94
3/6/18	12:49	1	58.6	3.054	77.4	76.1	68.7	103.6	8.34	5.84
3/6/18	12:50	1	57.9	3.02	77.4	76	68.8	103.7	8.24	5.74
3/6/18	12:51	1	56.9	3.002	77.5	77.8	68.6	103.8	8.14	5.64
3/6/18	12:52	1	56.4	3.012	77.3	78.3	68.4	103.6	8.05	5.55
3/6/18	12:53	1	56	2.998	77.5	79.1	68.6	103.8	7.96	5.46
3/6/18	12:54	1	55.6	3.002	77.5	79.6	68.7	104	7.86	5.36
3/6/18	12:55	1	55.6	3.03	77.6	80	68.7	103.7	7.74	5.24
3/6/18	12:56	1	55.4	2.987	77.7	80.4	68.6	104.1	7.61	5.11
3/6/18	12:57	1	55.4	3.007	77.8	80.6	68.8	103.7	7.5	5
3/6/18	12:58	1	55.6	2.971	78.1	81.2	68.9	104	7.36	4.86
3/6/18	12:59	1	55.6	2.942	78.2	81.4	68.5	104	7.26	4.76
3/6/18	13:00	1	55.3	2.967	78.3	81.6	69	104	7.16	4.66
3/6/18	13:01	1	55.3	2.984	78.4	81.8	69.2	104	7.04	4.54
3/6/18	13:02	1	55.4	3.03	78.5	81.9	69.3	103.2	6.94	4.44
3/6/18	13:03	1	55.5	3.017	78.5	82	69.4	103.1	6.85	4.35
3/6/18	13:04	1	55.5	3.047	78.6	82.4	69.2	103.2	6.76	4.26
3/6/18	13:05	1	55.4	3.118	78.6	82.4	69.4	103.1	6.67	4.17
3/6/18	13:06	1	55.5	3.101	78.7	82.6	69.3	103.2	6.6	4.1
3/6/18	13:07	1	55.5	3.049	78.7	82.6	69.4	103.4	6.5	4
3/6/18	13:08	1	55.5	3.021	78.8	82.8	69.4	103.3	6.41	3.91
3/6/18	13:09	1	55.5	3.096	78.7	82.8	69.5	103.2	6.34	3.84
3/6/18	13:10	1	55.5	3.079	78.7	82.8	69.5	103.3	6.25	3.75
3/6/18	13:11	1	55.5	3.019	78.8	83	69.3	103.3	6.17	3.67
3/6/18	13:12	1	55.4	3.068	78.8	83	69.5	103.2	6.11	3.61
3/6/18	13:13	1	55.5	3.033	78.9	83.1	69.2	103.4	6.03	3.53
3/6/18	13:14	1	55.6	3.057	78.9	83.1	68.9	103.3	5.93	3.43
3/6/18	13:15	1	55.2	3.086	79	83.3	69.1	103.1	5.85	3.35
3/6/18	13:16	1	55.6	3.079	79	83.2	69.3	102.8	5.76	3.26
3/6/18	13:17	1	55.7	3.05	78.9	83.3	69	103.2	5.68	3.18
3/6/18	13:18	1	55.5	3.028	79	83.3	69.2	103.4	5.62	3.12
3/6/18	13:19	1	55.5	2.991	79	83.4	69.6	103.5	5.56	3.06
3/6/18	13:20	1	55.4	3.055	79	83.4	69.5	103.1	5.5	3
3/6/18	13:21	1	55.5	3.089	79	83.4	69.8	103	5.39	2.89
3/6/18	13:22	1	55.4	3.056	78.9	83.5	69.6	102.6	5.31	2.81
3/6/18	13:23	1	55.3	3.133	78.8	83.3	69.9	102.4	5.25	2.75
3/6/18	13:24	1	55.5	3.108	78.9	83.4	69.5	102.4	5.17	2.67
3/6/18	13:25	1	55.4	3.124	78.8	83.2	69.7	102.3	5.11	2.61
3/6/18	13:26	1	55.6	3.166	78.8	83.2	69.7	102.3	5.05	2.55
3/6/18	13:27	1	55.4	3.185	78.9	83.2	69.7	102.1	4.99	2.49
3/6/18	13:28	1	55.6	3.112	78.8	83.3	69.7	102	4.92	2.42
3/6/18	13:29	1	55.7	3.13	78.8	83.2	69.6	101.8	4.88	2.38
3/6/18	13:30	1	55.7	3.093	78.7	83.1	69.6	101.9	4.82	2.32
3/6/18	13:31	1	55.7	3.198	78.7	83.1	69.6	101.2	4.73	2.23
3/6/18	13:32	1	55.7	3.206	78.7	83.1	69.2	100.5	4.67	2.17
3/6/18	13:33	1	55.6	3.137	78.6	83	69.3	101.8	4.62	2.12
3/6/18	13:34	1	56	3.144	78.7	83.2	69.3	102.1	4.55	2.05
3/6/18	13:35	1	55.6	3.14	78.7	83	69.1	101.2	4.51	2.01
3/6/18	13:36	1	55.7	3.146	78.6	82.8	69.3	101.3	4.43	1.93
3/6/18	13:37	1	55.6	3.154	78.6	82.8	69.2	101.1	4.38	1.88
3/6/18	13:38	1	55.8	3.219	78.6	82.8	69.6	100.8	4.32	1.82
3/6/18	13:39	1	55.7	3.27	78.6	82.9	70.1	100.8	4.25	1.75
3/6/18	13:40	1	55.7	3.217	78.5	82.7	69.5	101.1	4.2	1.7
3/6/18	13:41	1	55.6	3.247	78.5	82.7	69.7	100.8	4.13	1.63
3/6/18	13:42	1	55.7	3.227	78.6	82.9	69.5	101	4.07	1.57
3/6/18	13:43	1	55.6	3.16	78.5	82.8	69.5	101	4.03	1.53
3/6/18	13:44	1	55.7	3.19	78.4	82.6	70.3	101.1	3.97	1.47
3/6/18	13:45	1	55.7	3.189	78.4	82.6	70	100.8	3.91	1.41
3/6/18	13:46	1	55.7	3.235	78.6	82.8	70.4	100.9	3.84	1.34
3/6/18	13:47	1	55.8	3.235	78.6	82.7	70.5	100.9	3.78	1.28
3/6/18	13:48	1	55.6	3.225	78.3	82.5	70.6	100.6	3.73	1.23
3/6/18	13:49	1	55.5	3.208	78.2	82.4	70.8	100.7	3.67	1.17
3/6/18	13:50	1	55.7	3.181	78.3	82.5	71	101.1	3.62	1.12
3/6/18	13:51	1	55.8	3.204	78.4	82.7	71	101.2	3.55	1.05
3/6/18	13:52	1	55.8	3.214	78.5	82.9	70.8	101.4	3.51	1.01
3/6/18	13:53	1	55.7	3.267	78.5	83	70.9	101.1	3.48	0.98
3/6/18	13:54	1	55.6	3.174	78.5	82.9	70.8	101.3	3.47	0.97

3/6/18	13:55	1	55.6	3.189	78.6	82.9	70.7	101	3.42	0.92
3/6/18	13:56	1	55.7	3.228	78.7	82.9	70.9	100.8	3.37	0.87
3/6/18	13:57	1	55.7	3.233	78.7	82.9	70.4	100.7	3.33	0.83
3/6/18	13:58	1	55.6	3.205	78.6	83	70	100.5	3.3	0.8
3/6/18	13:59	1	55.5	3.198	78.6	82.8	70.3	100.5	3.27	0.77
3/6/18	14:00	1	55.6	3.233	78.4	82.7	70.2	100.1	3.25	0.75
3/6/18	14:01	1	55.6	3.222	78.4	82.6	70.3	100	3.21	0.71
3/6/18	14:02	1	55.6	3.238	78.3	82.5	70.7	99.7	3.19	0.69
3/6/18	14:03	1	55.6	3.248	78.2	82.4	70.5	99.6	3.14	0.64
3/6/18	14:04	1	55.4	3.236	78.4	82.5	70.1	99.6	3.12	0.62
3/6/18	14:05	1	55.4	3.212	78.4	82.4	70.1	99.4	3.1	0.6
3/6/18	14:06	1	55.2	3.253	78.4	82.4	70.4	98.9	3.08	0.58
3/6/18	14:07	1	55.3	3.331	78	82.1	70.4	98.3	3.06	0.56
3/6/18	14:08	1	55.4	3.254	78.1	82.3	70	98.2	3.06	0.56
3/6/18	14:09	1	55.2	3.29	78	82	70.2	97.8	3.04	0.54
3/6/18	14:10	1	55.4	3.277	77.9	81.9	69.9	97.6	3.01	0.51
3/6/18	14:11	1	55.4	3.41	77.8	81.7	70.7	96.9	2.97	0.47
3/6/18	14:12	1	55.4	3.251	77.7	81.7	69.8	97	2.96	0.46
3/6/18	14:13	1	55.2	3.259	77.7	81.6	69.3	97	2.94	0.44
3/6/18	14:14	1	55.4	3.308	77.6	81.4	69.7	97.1	2.93	0.43
3/6/18	14:15	1	55.3	3.292	77.5	81.3	70	97.4	2.92	0.42
3/6/18	14:16	1	55.4	3.355	77.7	81.3	70	97.5	2.88	0.38
3/6/18	14:17	1	55.3	3.382	77.7	81.5	70.2	96.8	2.88	0.38
3/6/18	14:18	1	55.3	3.324	77.7	81.5	70.3	96.9	2.84	0.34
3/6/18	14:19	1	55.5	3.297	77.6	81.3	70.3	96.8	2.82	0.32
3/6/18	14:20	1	55.5	3.242	77.6	81.4	70.2	97	2.81	0.31
3/6/18	14:21	1	55.6	3.322	77.7	81.6	69.8	96.3	2.78	0.28
3/6/18	14:22	1	55.6	3.369	77.6	81.4	70	95.9	2.77	0.27
3/6/18	14:23	1	55.7	3.305	77.7	81.5	70	96.5	2.72	0.22
3/6/18	14:24	1	55.6	3.293	77.6	81.2	70.1	96.7	2.71	0.21
3/6/18	14:25	1	55.5	3.349	77.6	81.4	69.9	96.4	2.71	0.21
3/6/18	14:26	1	55.6	3.355	77.6	81.4	70.2	96.8	2.68	0.18
3/6/18	14:27	1	55.6	3.346	77.7	81.4	70.1	96.5	2.66	0.16
3/6/18	14:28	1	55.5	3.255	77.6	81.3	70	97.2	2.63	0.13
3/6/18	14:29	1	55.6	3.285	77.6	81.3	69.9	96.6	2.61	0.11
3/6/18	14:30	1	55.6	3.262	77.6	81.3	70.1	96.7	2.59	0.09
3/6/18	14:31	1	55.5	3.295	77.6	81.2	69.9	96.4	2.55	0.05
3/6/18	14:32	1	56.8	3.253	77	79.2	69.6	96.5	2.54	0.04 Test End

General Average Report

Reporting Period: 03/06/2018 to 03/06/2018

Site Name: UNIT

Time of Report: 03/06/18 14:52

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	CAT_POST (Deg_F)	CO (%)	CO2 (%)	O2 (%)	STK_CSA (Deg_F)	STK_TMP (Deg_F)	
3/6/18	10:30	64.8	-0.04	0	22.1	65.01	64.6	Preburn
3/6/18	10:31	67.9	-0.04	0	22.1	64.81	64.6	
3/6/18	10:32	116.5	-0.04	0.2	22.1	75.93	66.8	
3/6/18	10:33	318.2	-0.04	0	22.1	134.02	85.2	
3/6/18	10:34	477.4	-0.04	0	22	200.77	106.8	
3/6/18	10:35	534.1	-0.04	0	22	241.64	121.4	
3/6/18	10:36	546.7	-0.04	1.5	22	266.97	133.2	
3/6/18	10:37	522.9	0.01	3.9	22	266.59	133.2	
3/6/18	10:38	511.6	0.07	3.6	20.8	263.26	130.9	
3/6/18	10:39	426.2	0.07	1.8	19.5	253.31	134.2	
3/6/18	10:40	311.6	0.12	1.2	19	223.55	132	
3/6/18	10:41	292.5	0.13	1.6	19.4	210.5	128.8	
3/6/18	10:42	377.1	0.09	1.9	19.8	220.69	130.9	
3/6/18	10:43	517.6	0.18	3.8	20	254.88	139	
3/6/18	10:44	488.9	0.1	2.2	19.5	259.74	143.9	
3/6/18	10:45	493.4	0.09	2.5	19	262.56	145.9	
3/6/18	10:46	706.8	0.15	5.9	19.1	310.61	157.4	
3/6/18	10:47	840	0.06	6.5	18.6	364.98	172.6	
3/6/18	10:48	914	0.01	7.4	17.2	401.2	183.5	
3/6/18	10:49	806	0.01	7.2	16	396.17	184.2	
3/6/18	10:50	717.8	0.05	4	15	375.44	181.3	
3/6/18	10:51	720.9	0.08	3.9	15	373.24	182.1	
3/6/18	10:52	836	0.07	3.8	16	400	190.4	
3/6/18	10:53	927.1	0.05	5	16.6	435.57	200.5	
3/6/18	10:54	916.9	0.02	6.5	16.8	453.77	208.9	
3/6/18	10:55	884.5	-0.01	6.7	16.3	461.25	214.9	
3/6/18	10:56	871.6	-0.02	6.5	15.6	462.12	217.5	
3/6/18	10:57	891.9	-0.02	6.5	15.2	455.62	213.8	
3/6/18	10:58	866.6	-0.03	6.3	15	447.75	211.7	
3/6/18	10:59	843.3	-0.02	5.3	14.8	442.22	209	
3/6/18	11:00	832.2	-0.02	5.1	15	439.55	208.3	
3/6/18	11:01	833.3	-0.02	5.1	15.4	438.66	205.9	
3/6/18	11:02	837.5	-0.02	5.2	15.7	439.73	209.8	
3/6/18	11:03	844.8	-0.02	5.3	15.9	441.64	212	
3/6/18	11:04	849.7	-0.02	5.6	16	445.54	213.4	
3/6/18	11:05	854.3	-0.03	5.6	15.9	449.16	215.3	
3/6/18	11:06	853.6	-0.03	5.8	15.8	449.88	214.5	
3/6/18	11:07	863.8	-0.03	5.9	15.7	450.64	213.2	
3/6/18	11:08	873.2	-0.04	6	15.5	454.03	214.2	
3/6/18	11:09	888.2	-0.04	6.1	15.4	464.47	225.9	

3/6/18	11:10	1007.4	-0.04	8.2	15.3	481.97	233.9
3/6/18	11:11	1053.8	-0.02	9.1	15	492.94	231
3/6/18	11:12	978	-0.07	0.1	13.8	491.1	227.8
3/6/18	11:13	953.1	-0.07	0.1	14.6	487.79	226.9
3/6/18	11:14	943.4	-0.07	0	17.5	485.33	227.5
3/6/18	11:15	927.8	-0.08	0	19.4	482.15	227.9
3/6/18	11:16	894.9	-0.05	5.7	20.5	476.9	227.3
3/6/18	11:17	867.7	-0.05	6	20.4	464.7	225
3/6/18	11:18	882.3	-0.04	7.6	18.3	466.61	229.5
3/6/18	11:19	899	-0.04	6.1	16.9	470.42	229
3/6/18	11:20	847.2	-0.04	5.1	15.6	463.9	226.5
3/6/18	11:21	800	-0.03	4.3	15.5	456.95	226.8
3/6/18	11:22	812.1	-0.01	4.5	15.8	452.12	227.5
3/6/18	11:23	839.7	-0.06	5.1	16.3	445.9	224.4
3/6/18	11:24	776.7	-0.04	3.3	16.4	438.67	223.1
3/6/18	11:25	688.2	-0.02	2.3	16.5	425.8	220.3
3/6/18	11:26	718.1	-0.02	4.9	17.4	429.01	229.2
3/6/18	11:27	849	-0.08	7.4	17.9	453.15	233.4
3/6/18	11:28	909.6	-0.07	7.9	16.9	475.28	234.5
3/6/18	11:29	929.8	-0.07	8.3	15.5	480.29	232
3/6/18	11:30	933	-0.07	6.8	14.5	468.52	221.9
3/6/18	11:31	939.5	-0.07	8.4	13.9	473.01	226.3
3/6/18	11:32	955.4	-0.09	8.1	14.1	471.72	219
3/6/18	11:33	941.6	-0.09	7.9	13.6	471.4	218.3
3/6/18	11:34	944.8	-0.09	7.8	13.4	477	224.5
3/6/18	11:35	901.5	-0.09	6.7	13.3	480.66	234.8
3/6/18	11:36	828.7	-0.08	4.4	13.6	480.93	238.1
3/6/18	11:37	824.9	-0.08	5.8	14.2	472.54	234.9
3/6/18	11:38	948.6	-0.05	9.2	15.2	474.53	227.8
3/6/18	11:39	997.5	-0.02	10	14.7	478.97	221.9
3/6/18	11:40	1031	-0.07	10.2	13.4	484.56	219.2
3/6/18	11:41	1059.2	-0.06	10.2	12.5	490.7	220.6
3/6/18	11:42	1045.2	-0.06	9.1	11.9	486.95	217.9
3/6/18	11:43	1038.2	-0.06	8.9	11.7	484.26	217.1
3/6/18	11:44	1035.7	-0.07	8.9	11.8	485.24	217.4
3/6/18	11:45	1035.1	-0.07	8.7	12	483.01	215.5
3/6/18	11:46	973.4	-0.09	7.2	12	462.77	209.3
3/6/18	11:47	907.3	-0.1	6.1	12.4	445.2	203.6
3/6/18	11:48	907.4	-0.09	6.4	13.2	463.65	217.9
3/6/18	11:49	941.8	0	5.6	14	460.54	216.7
3/6/18	11:50	893.6	0	4.1	14.2	433.7	203
3/6/18	11:51	872.1	0	4.1	15.1	418.45	195.5
3/6/18	11:52	877.6	0	5.3	16	410.62	191.4
3/6/18	11:53	871.5	0	4.2	16.3	406.25	187.9
3/6/18	11:54	823.1	0	3.8	16.2	396.51	183.6
3/6/18	11:55	819.8	0	3.8	16.7	390.66	182.5
3/6/18	11:56	816.1	0	3.6	17	387.91	180.5
3/6/18	11:57	794.7	0	3.4	17.2	382.96	179.4

Test Start

3/6/18	11:58	777.3	0	3.4	17.5	376.97	179.8
3/6/18	11:59	775	0	3.4	17.7	371.91	178.1
3/6/18	12:00	776.4	0	3.2	17.8	369.46	175.8
3/6/18	12:01	760.9	0	3.3	17.9	366.85	173
3/6/18	12:02	742.9	0	3.1	18	362.31	170.9
3/6/18	12:03	735.3	0	3.1	18	358.02	168.8
3/6/18	12:04	732.4	0	3.2	18.1	355.56	167.5
3/6/18	12:05	746.2	0	3.3	18.2	354.77	166.8
3/6/18	12:06	759.1	0	3.2	18.1	354.77	167.2
3/6/18	12:07	762.6	0	3.3	18.1	354.74	168.9
3/6/18	12:08	758.1	0	3.2	18.1	353.6	168.4
3/6/18	12:09	758.1	0.01	3.1	18.1	352.39	167
3/6/18	12:10	763.5	0.02	3.1	18.2	351.3	166.8
3/6/18	12:11	773	0.04	3.5	18.2	351.67	166
3/6/18	12:12	798.5	0.04	4.3	18.3	355.03	165.4
3/6/18	12:13	801.9	0.02	5.2	18	356.35	166.2
3/6/18	12:14	810	0.05	5.2	17.4	356.08	167.2
3/6/18	12:15	810.8	0.02	4.9	16.9	356.53	168.9
3/6/18	12:16	823.2	0.05	5	16.6	357.47	169.3
3/6/18	12:17	836.6	0.03	5.3	16.5	362.66	169.4
3/6/18	12:18	825	0.04	5	16.3	362.96	168.3
3/6/18	12:19	843.7	0.08	5.4	16.2	364.5	169.5
3/6/18	12:20	851.7	0.05	5.6	16.2	366.5	171.4
3/6/18	12:21	861.7	0.01	5.9	16	368.96	170.9
3/6/18	12:22	879.6	0	6.3	15.8	373.28	170.3
3/6/18	12:23	885.6	0	6.4	15.5	376.42	170.2
3/6/18	12:24	877.3	0	6.3	15.3	379.06	171.4
3/6/18	12:25	884.5	0	6.5	15.1	381.44	172.5
3/6/18	12:26	886	0	6.6	15	383.31	173.8
3/6/18	12:27	890	0	6.9	14.9	384.5	175.3
3/6/18	12:28	896.6	0	6.8	14.8	386.58	174.1
3/6/18	12:29	898.4	0	6.8	14.6	387.44	173
3/6/18	12:30	895	0	6.8	14.5	388.66	176.6
3/6/18	12:31	889.9	0	6.6	14.5	387.93	174.6
3/6/18	12:32	881.3	0	6.5	14.5	386.43	174.3
3/6/18	12:33	875.6	0	6.5	14.6	385.33	173.8
3/6/18	12:34	871	0	6.5	14.6	384.86	172.8
3/6/18	12:35	872.3	0	6.6	14.7	384.49	175.7
3/6/18	12:36	873.9	0	6.7	14.7	384.85	176.3
3/6/18	12:37	870.5	0	6.6	14.7	384.37	175
3/6/18	12:38	860.6	0	6.4	14.6	382.86	172.1
3/6/18	12:39	854.5	0	6.2	14.7	382.49	172
3/6/18	12:40	855.6	0	6.5	14.8	381.09	174.5
3/6/18	12:41	865.2	0	6.7	14.8	381.58	175.1
3/6/18	12:42	874.5	0	6.8	14.8	382.55	173.9
3/6/18	12:43	882.7	0	6.9	14.7	384.3	173
3/6/18	12:44	892.1	0	7.1	14.5	386.82	174.1
3/6/18	12:45	899.4	0	7.1	14.4	388.4	176.3

3/6/18	12:46	896.9	0	7.2	14.3	390.22	175.9
3/6/18	12:47	887.9	0	7.1	14.2	391.41	176.7
3/6/18	12:48	880.8	0	7	14.1	390.74	175.5
3/6/18	12:49	873.6	0	7	14.1	389.13	175.3
3/6/18	12:50	872.5	0	7	14.2	388.38	174.2
3/6/18	12:51	872.1	0	7.1	14.2	388.47	174.3
3/6/18	12:52	874.2	0	7.2	14.2	388.82	174.3
3/6/18	12:53	878.1	0	7.2	14.1	388.99	174.2
3/6/18	12:54	881.2	0	7.2	14.1	389.55	174.7
3/6/18	12:55	882.2	0	7.3	14	389.85	174.6
3/6/18	12:56	882.8	0	7.2	14	390.83	174.7
3/6/18	12:57	883	0	7.2	14	390.8	173.8
3/6/18	12:58	875	0	6.8	14	389.02	173.2
3/6/18	12:59	869.5	0	6.6	14.1	387.61	173.1
3/6/18	13:00	864.6	0	6.6	14.2	387.74	172.8
3/6/18	13:01	859.8	0	6.5	14.4	386.94	172.9
3/6/18	13:02	857.7	0	6.4	14.5	386.74	172
3/6/18	13:03	850.3	0	6.4	14.5	385.46	171.1
3/6/18	13:04	845.6	0	6.4	14.6	384.37	172.7
3/6/18	13:05	842.9	0	6.4	14.6	383.04	174.5
3/6/18	13:06	842.1	0	6.4	14.7	381.6	174.3
3/6/18	13:07	843.9	0	6.4	14.6	380.46	173
3/6/18	13:08	844.5	0	6.5	14.6	380.93	171.7
3/6/18	13:09	844.1	0	6.5	14.6	381.92	173.8
3/6/18	13:10	843.3	0	6.4	14.5	381.33	173.6
3/6/18	13:11	842.5	0	6.4	14.5	380.71	171.9
3/6/18	13:12	843.2	0	6.3	14.5	380.88	172.8
3/6/18	13:13	842.3	0	6.3	14.6	381.12	173
3/6/18	13:14	838.9	0	6.2	14.6	380.52	174.1
3/6/18	13:15	838.6	0	6.1	14.6	380.05	173.9
3/6/18	13:16	834.5	0	6.1	14.7	379.35	172.3
3/6/18	13:17	831.8	0	6.1	14.8	378.72	173.2
3/6/18	13:18	831.6	0	6	14.8	379.26	172.6
3/6/18	13:19	830.1	0	6	14.9	378.25	170.9
3/6/18	13:20	826.3	0	6	14.9	377.2	172.2
3/6/18	13:21	821.7	0	5.9	15	376.44	172.3
3/6/18	13:22	818.2	0	5.9	15	376.4	170.6
3/6/18	13:23	816.9	0	5.9	15	375.77	171.7
3/6/18	13:24	817.4	0	5.9	15.1	375.05	171.6
3/6/18	13:25	816.7	0	5.8	15.1	373.94	171.5
3/6/18	13:26	813.7	0	5.8	15.1	374.78	172.8
3/6/18	13:27	810	0	5.8	15.2	373.38	172.8
3/6/18	13:28	808.8	0	5.8	15.3	371.28	170.4
3/6/18	13:29	805.2	0	5.7	15.3	370.09	170.4
3/6/18	13:30	803.5	0	5.7	15.3	369.83	169.5
3/6/18	13:31	799.6	0	5.7	15.3	370.22	169.8
3/6/18	13:32	795.3	0	5.7	15.3	368.57	169
3/6/18	13:33	794.6	0	5.7	15.3	367.85	171

3/6/18	13:34	793.6	0	5.7	15.4	367.82	172
3/6/18	13:35	792.8	0	5.7	15.4	367.48	169.6
3/6/18	13:36	789.8	0	5.7	15.4	366.27	169.8
3/6/18	13:37	784.7	0	5.8	15.4	365.47	169.6
3/6/18	13:38	780.6	0	5.8	15.4	364.46	170.1
3/6/18	13:39	779.3	0	5.9	15.4	364.83	170.4
3/6/18	13:40	778	0	5.9	15.3	363	170.9
3/6/18	13:41	779.1	0	5.9	15.3	361.5	170.8
3/6/18	13:42	780.6	0	6	15.2	361.3	171.1
3/6/18	13:43	783.7	0	5.9	15.2	361.3	169.1
3/6/18	13:44	788.7	0	5.9	15.2	361.82	168.5
3/6/18	13:45	787.6	0	5.8	15.2	361.71	168
3/6/18	13:46	780.2	0	5.8	15.2	360.63	169.1
3/6/18	13:47	774.9	0	5.8	15.2	359.59	168.9
3/6/18	13:48	768.7	0	5.6	15.2	358.46	167.5
3/6/18	13:49	755.5	0	5.2	15.2	356.11	166.9
3/6/18	13:50	751.7	0	5.2	15.4	354.34	166.8
3/6/18	13:51	749.7	0	5.2	15.5	353.12	167.8
3/6/18	13:52	748.4	0	5.1	15.6	352.12	169.2
3/6/18	13:53	750.5	0	4.9	15.7	351.68	169.4
3/6/18	13:54	752.2	0	4.9	15.8	351.09	167.5
3/6/18	13:55	749.2	0	4.8	16	350.93	167.3
3/6/18	13:56	748	0	4.8	16	351.59	167.6
3/6/18	13:57	745.7	0	4.7	16.1	351.12	168.4
3/6/18	13:58	744.5	0	4.7	16.2	349.56	167.7
3/6/18	13:59	741.7	0	4.7	16.3	348.81	166.9
3/6/18	14:00	740	0	4.7	16.3	347.96	166.8
3/6/18	14:01	734.1	0	4.4	16.4	347.6	165.9
3/6/18	14:02	722.2	0	4.3	16.4	344.33	164.6
3/6/18	14:03	715.7	0	4.3	16.5	342.27	165.1
3/6/18	14:04	710.2	0	4.3	16.7	341.02	165.7
3/6/18	14:05	702.7	0	4.2	16.7	338.9	164.1
3/6/18	14:06	693.5	0	4.2	16.8	335.85	163
3/6/18	14:07	688.2	0	4.1	16.9	333.31	163.1
3/6/18	14:08	685.8	0	4.1	16.9	332.24	161.6
3/6/18	14:09	683.9	0	4.1	17	330.88	160.7
3/6/18	14:10	681.8	0	4.1	17	329.64	160.6
3/6/18	14:11	680.4	0	4.1	17	328.47	160.2
3/6/18	14:12	678.1	0	3.9	17.1	327.64	158.2
3/6/18	14:13	675.1	0	3.9	17.1	326.67	159.5
3/6/18	14:14	675	0	3.9	17.2	326.53	160.1
3/6/18	14:15	675.1	0	4.1	17.2	326	160.1
3/6/18	14:16	675	0	4.1	17.3	326.26	161.4
3/6/18	14:17	674.3	0	4.1	17.2	325.92	159.9
3/6/18	14:18	672.8	0	4.1	17.2	324.84	158.6
3/6/18	14:19	671.7	0	4.1	17.1	324.35	157.6
3/6/18	14:20	670.8	0	4.1	17.1	324.34	156.7
3/6/18	14:21	670.1	0	4.1	17.1	323.92	157.5

3/6/18	14:22	670	0	4.1	17.1	324.07	156.9
3/6/18	14:23	670.1	0	4.1	17.1	322.94	157.2
3/6/18	14:24	671.7	0	4.1	17.1	323.05	157.4
3/6/18	14:25	673.8	0	4.2	17.1	323.78	158.4
3/6/18	14:26	674.2	0	4.2	17.1	324.15	158.8
3/6/18	14:27	672.7	0	4.1	17.1	323.66	158.5
3/6/18	14:28	672.3	0	4.1	17.1	323.34	158.2
3/6/18	14:29	673.4	0	4.1	17.1	323.48	157.4
3/6/18	14:30	672.9	0	4.1	17.1	323.95	157.1
3/6/18	14:31	671.6	0	4.1	17.1	323.73	157.4
3/6/18	14:32	670.1	0	4.1	17.1	323.61	157.1

General Average Report

Reporting Period: 03/06/2018 to 03/06/2018

Site Name: UNIT

Time of Report: 03/06/18 14:53

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	Stove Side front left CAT_PRE (Deg_F)	Stove Bottom TEMP_10 (Deg_F)	Stove Back TEMP_11 (Deg_F)	Stove Side TEMP_12 (Deg_F)	Stove Top TEMP_13 (Deg_F)	
3/6/18	10:30	65.6	66.83	66.75	67.46	65.5	Preburn
3/6/18	10:31	65.3	67.16	66.4	67.59	65.36	
3/6/18	10:32	65.2	67.09	66.92	67.32	65.73	
3/6/18	10:33	65.4	66.28	67.53	67.33	68.2	
3/6/18	10:34	65.6	66.39	69.55	67.93	74.3	
3/6/18	10:35	66.3	66.67	73.06	69.21	84.4	
3/6/18	10:36	67.5	67.06	78.93	70.56	96.54	
3/6/18	10:37	69.2	66.98	85.53	72.78	108.94	
3/6/18	10:38	71.3	67.35	92.47	75.59	119.29	
3/6/18	10:39	74.6	67.83	100.8	79.23	129.15	
3/6/18	10:40	77.5	68.65	107.21	82.56	138.08	
3/6/18	10:41	80	69.02	112.02	85.4	144.22	
3/6/18	10:42	82.1	69.52	115.62	88.31	147.81	
3/6/18	10:43	85	70.65	117	91.26	151.47	
3/6/18	10:44	87.3	71.95	118.86	93.71	157.59	
3/6/18	10:45	89.2	73.21	120.27	95.62	163.55	
3/6/18	10:46	90.6	73.66	122.14	97.63	170.02	
3/6/18	10:47	92.3	74.38	122.95	99.9	180.58	
3/6/18	10:48	93.8	75.76	123.25	101.94	197.9	
3/6/18	10:49	95.5	77.78	123.04	103.96	220.32	
3/6/18	10:50	97.9	78.8	124.51	106.71	241.14	
3/6/18	10:51	100.3	79.96	127.45	109.61	257.26	
3/6/18	10:52	102.7	81.31	130.82	112.4	267.89	
3/6/18	10:53	105.4	83.11	134.64	114.86	278.94	
3/6/18	10:54	108.3	84.55	138.35	117.47	293.73	
3/6/18	10:55	110.7	85.63	142.37	120.6	312.16	
3/6/18	10:56	113.3	87.08	146.7	123.88	328.2	
3/6/18	10:57	116.4	88.5	149.18	126.9	340.8	
3/6/18	10:58	120.3	90.22	153.3	130.6	352.88	
3/6/18	10:59	124.2	91.51	157.35	134.5	363.83	
3/6/18	11:00	128.6	93.17	160.58	138.52	372.01	
3/6/18	11:01	132	95.17	164.95	142.11	374.04	
3/6/18	11:02	136	97.63	168.89	145.78	379.92	
3/6/18	11:03	140.4	99.25	171.97	149.37	383.93	
3/6/18	11:04	144.1	101.21	175.63	153.34	387.69	
3/6/18	11:05	147.8	103.38	179.32	156.32	390.14	
3/6/18	11:06	151	105.97	182.09	159.16	392.26	
3/6/18	11:07	154.9	108.34	185.36	162.34	394.48	
3/6/18	11:08	158.6	110.65	189.34	166.26	399.19	
3/6/18	11:09	161.9	113.6	195.55	169.58	407.47	

3/6/18 11:10	164.9	116.5	199	172.1	412.84	
3/6/18 11:11	169.1	118.59	200.96	175.16	419.76	
3/6/18 11:12	173	121.14	205.01	179.23	428.39	
3/6/18 11:13	176.6	124.14	210.39	183.08	440.22	
3/6/18 11:14	181	127.47	216.9	186.5	449.47	
3/6/18 11:15	184.2	130.97	221.26	190.23	453.53	
3/6/18 11:16	188.2	133.68	224.27	194.41	454.33	
3/6/18 11:17	191.8	136.56	226.35	198.09	459.95	
3/6/18 11:18	196.7	140.09	232.88	201.17	459.23	
3/6/18 11:19	200.6	143.96	233.9	204.75	453.35	
3/6/18 11:20	204.6	147.04	235.32	208.52	450.3	
3/6/18 11:21	207.4	150.36	239.71	211.89	454.14	
3/6/18 11:22	212.2	154.4	243.28	214.95	447.63	
3/6/18 11:23	216.5	158.29	241.68	217.74	447.76	
3/6/18 11:24	220.5	161.73	244.15	220.93	441.96	
3/6/18 11:25	220.4	164.33	242.17	222.96	431.52	
3/6/18 11:26	220.7	166.26	239	224.23	426.12	
3/6/18 11:27	223.8	168.89	241.16	225.7	421.62	
3/6/18 11:28	224.8	172.67	242.37	227.77	417.84	
3/6/18 11:29	225.7	175.61	241.98	230.32	416.94	
3/6/18 11:30	227	177.81	237.56	232.34	420.04	
3/6/18 11:31	229.1	181.39	241.09	234.4	425.43	
3/6/18 11:32	230.8	181.79	239.22	235.67	423.44	
3/6/18 11:33	234.5	184.69	241.58	238.42	430.75	
3/6/18 11:34	234.9	187.88	246.28	239.96	438.47	
3/6/18 11:35	235.5	193.49	252.73	242.4	448.28	
3/6/18 11:36	239.1	197.54	258.72	245.27	453.65	
3/6/18 11:37	241.9	200.75	257.85	247.83	448.14	
3/6/18 11:38	243.5	201.26	259.26	250.04	443.67	
3/6/18 11:39	245.8	202.85	259.58	252.39	442.91	
3/6/18 11:40	247	205.17	262.07	254.46	444.57	
3/6/18 11:41	249.5	207.88	264.24	258.12	455.07	
3/6/18 11:42	251.2	209.77	262.06	260.95	459.07	
3/6/18 11:43	252.5	210.89	264.95	263.58	463.88	
3/6/18 11:44	255	213.42	266.8	266.22	471.84	
3/6/18 11:45	258.1	216.54	269.33	269.38	477.76	
3/6/18 11:46	260.6	220.33	267.06	272.67	482.33	
3/6/18 11:47	263.2	223.19	268.35	275	485.98	
3/6/18 11:48	264.3	228.41	278.94	278.23	497.31	
3/6/18 11:49	268.7	229.32	276.62	280.99	484.87	Test Start
3/6/18 11:50	270.9	229.87	272.99	283.92	477.77	
3/6/18 11:51	273.3	232.99	272.36	286.06	475.09	
3/6/18 11:52	275.9	235.65	271.49	288.25	467.61	
3/6/18 11:53	277.7	238.58	269.27	290.15	459.26	
3/6/18 11:54	279.4	240.85	267.12	292.29	455.45	
3/6/18 11:55	281.4	242.82	265.42	293.63	449.04	
3/6/18 11:56	282.6	244.56	260.8	294.18	442.14	
3/6/18 11:57	284	246.34	260.77	295.69	439.12	

3/6/18 11:58	284.9	248.58	256.14	296.72	434.39
3/6/18 11:59	285.8	248.65	251.83	296.02	428.36
3/6/18 12:00	285.9	251.07	251.52	295.35	421.59
3/6/18 12:01	285.6	252.77	248.77	294.73	414.24
3/6/18 12:02	285.8	255.31	246.89	294.13	410.28
3/6/18 12:03	285.8	255.57	242.63	293.71	406.15
3/6/18 12:04	285.2	255.99	240.41	292.76	400.53
3/6/18 12:05	284.6	256.71	239.68	291.29	393.49
3/6/18 12:06	284.1	257.08	236.73	291.29	392.46
3/6/18 12:07	283.3	258.7	234.86	290.41	388.94
3/6/18 12:08	282.6	258.02	231.48	288.59	387.04
3/6/18 12:09	282.1	259.54	229.2	287.71	383.53
3/6/18 12:10	281.3	261.56	228.35	287.01	378.48
3/6/18 12:11	280	262.63	225.98	286.24	375.23
3/6/18 12:12	278.6	262.75	224.13	284.46	372.77
3/6/18 12:13	278	264.04	224	283.36	369.67
3/6/18 12:14	276.5	265.69	223.62	282.47	367.56
3/6/18 12:15	275.3	266.73	221.79	281.44	368.87
3/6/18 12:16	274.4	266.52	220.35	279.7	367.63
3/6/18 12:17	272.9	268	218.86	278.26	367.45
3/6/18 12:18	272.2	267.65	215.96	277.27	369.22
3/6/18 12:19	272.3	268.99	216.49	276.7	371.98
3/6/18 12:20	271.5	269.05	214.77	275.39	374.75
3/6/18 12:21	270	269.58	215.86	274.03	376.22
3/6/18 12:22	268.9	270.72	215.23	273.63	377.52
3/6/18 12:23	268.7	272.07	214.97	273.34	379.86
3/6/18 12:24	268.3	273.53	214.29	272.03	381.43
3/6/18 12:25	267.6	273.39	214.03	271.01	385.21
3/6/18 12:26	267.7	274.22	214.64	270.85	392.7
3/6/18 12:27	267.1	275.49	214.72	270.45	393.42
3/6/18 12:28	266.3	276.99	213.97	269.53	393.83
3/6/18 12:29	265.4	276.84	213.08	269.41	399.39
3/6/18 12:30	265.5	277.4	214.12	269.5	402.35
3/6/18 12:31	265.6	278.26	214.39	269.56	403.46
3/6/18 12:32	266.3	279.56	214.93	269.9	406.54
3/6/18 12:33	266.5	279.08	214.55	269.64	406.76
3/6/18 12:34	266.1	279.62	215.23	269.87	411.31
3/6/18 12:35	266.7	280.23	214.98	270.71	413.94
3/6/18 12:36	267.3	281.13	215.09	271.23	414.49
3/6/18 12:37	267	282.02	215.49	270.54	412.48
3/6/18 12:38	266.5	281.66	215.51	270.68	412.3
3/6/18 12:39	267.8	282.59	216.25	272.35	416.81
3/6/18 12:40	268.8	283.7	216.35	273.38	419.8
3/6/18 12:41	269.9	284.93	217.02	273.61	419.46
3/6/18 12:42	269.2	284.86	218.13	273.25	415.29
3/6/18 12:43	270.2	285.3	218.56	274.27	416.47
3/6/18 12:44	271.2	286.53	218.18	275.12	420.69
3/6/18 12:45	271.9	287.73	218.84	276.13	421.5

3/6/18 12:46	272.1	287.71	220.41	275.41	423.48
3/6/18 12:47	273.3	287.63	220.28	275.83	423.57
3/6/18 12:48	273.7	287.81	219.22	277.89	423.03
3/6/18 12:49	274.1	288.84	220.16	278.21	425.75
3/6/18 12:50	275.6	289.9	221.57	278.57	427.15
3/6/18 12:51	276.5	289.82	223.45	279.4	426.87
3/6/18 12:52	277.7	290.11	223.92	281.35	427.28
3/6/18 12:53	279.5	291.57	224.24	282.54	431.65
3/6/18 12:54	280.5	292.17	225.89	282.11	433.38
3/6/18 12:55	280.9	292.02	226.93	283.46	434.57
3/6/18 12:56	281.5	292.53	226.25	284.64	432.87
3/6/18 12:57	281.6	293.32	227.99	285.37	433.07
3/6/18 12:58	283.2	294.1	229.2	285.96	435.13
3/6/18 12:59	284.6	293.76	229.31	286.5	436.46
3/6/18 13:00	285.6	295.15	229.74	288.37	437.65
3/6/18 13:01	287.2	295.22	230.78	288.63	436.31
3/6/18 13:02	288.8	296.05	232.14	289.35	435.21
3/6/18 13:03	289.7	296.73	234.28	289.56	433.52
3/6/18 13:04	291.7	295.98	234.35	291.21	435.13
3/6/18 13:05	292.4	296.7	234.92	291.77	434.24
3/6/18 13:06	293.1	299.54	235.78	292.35	432.4
3/6/18 13:07	294.3	299.45	235.72	292.89	430.35
3/6/18 13:08	295.6	299.47	236.21	294.07	428.52
3/6/18 13:09	296.3	299.7	236.41	294.96	429.08
3/6/18 13:10	297.1	301.26	239.37	295.38	430.24
3/6/18 13:11	298	301.8	239.98	295.18	427.93
3/6/18 13:12	299.8	301.4	239.83	296.29	428.04
3/6/18 13:13	299.6	301.4	239.88	297.44	428.28
3/6/18 13:14	300.7	302.19	240.91	297.21	429.43
3/6/18 13:15	301.5	303.07	241.22	297.66	428.99
3/6/18 13:16	302.1	304.43	242.85	298.66	424.38
3/6/18 13:17	302.9	304.07	243.73	299.95	425.28
3/6/18 13:18	303.9	302.65	244.05	299.59	425.3
3/6/18 13:19	304.1	302.93	245.91	299.54	422.03
3/6/18 13:20	306.8	306.19	247.32	300.44	422.8
3/6/18 13:21	307.4	308.68	247.9	301.68	419.09
3/6/18 13:22	307.9	309.34	248.7	302.09	415.31
3/6/18 13:23	308.5	308.13	250.78	302.03	416.84
3/6/18 13:24	309.7	309.5	252.12	302.62	417.41
3/6/18 13:25	310.1	309.41	252.67	303.44	418.47
3/6/18 13:26	309.8	307.92	251.39	304.27	415.82
3/6/18 13:27	311.4	309.03	253.22	304.13	412.61
3/6/18 13:28	313	312.66	255.17	304.38	408.33
3/6/18 13:29	313.5	312.9	258.29	305.19	406.92
3/6/18 13:30	313.8	314.25	258.23	305.68	404.56
3/6/18 13:31	314	314.48	258.27	305.55	403.78
3/6/18 13:32	315.1	313.95	260.84	306	402.76
3/6/18 13:33	316.9	314.27	262.15	306.87	406.79

3/6/18 13:34	318	315.26	262.17	307.28	406.34
3/6/18 13:35	317.5	313.87	263.08	307.75	401.14
3/6/18 13:36	316.9	313.64	263.64	307.83	403.16
3/6/18 13:37	317.5	314.67	265.22	308.48	398.89
3/6/18 13:38	318.2	315.47	266.77	309.67	401.79
3/6/18 13:39	319.8	317.24	267.62	309.4	397.01
3/6/18 13:40	319.9	317.6	270.91	309.59	393.56
3/6/18 13:41	319.9	319.33	272.99	310.29	398.84
3/6/18 13:42	320.4	319.25	271.38	310.33	395.06
3/6/18 13:43	321.2	319.54	274.14	310.83	390.87
3/6/18 13:44	321.5	319.94	275.09	311.19	389
3/6/18 13:45	321.3	322	275.35	311.68	388.83
3/6/18 13:46	322.7	322.89	276.8	312.62	392.04
3/6/18 13:47	323.2	323.65	278.16	312.7	389.85
3/6/18 13:48	324.2	324.26	280.38	312.87	389.76
3/6/18 13:49	324.5	325.51	282.32	313.67	390.6
3/6/18 13:50	325.1	326.61	282.66	314.52	390.23
3/6/18 13:51	325.2	327.14	281.73	314.89	392.43
3/6/18 13:52	325.8	328.35	283.42	315.17	390.47
3/6/18 13:53	326	329.31	284.01	315.65	389.75
3/6/18 13:54	326.6	330.16	283.26	316.71	388.01
3/6/18 13:55	327.4	331.01	283.67	317.31	385.92
3/6/18 13:56	327.7	331.82	284.1	317.67	385.09
3/6/18 13:57	326.7	332.04	283.02	318.49	386.96
3/6/18 13:58	327.2	332.92	283.05	319.41	387.77
3/6/18 13:59	328.3	334.34	282.76	320.15	384.26
3/6/18 14:00	328.3	334.06	281.23	320.36	385.16
3/6/18 14:01	327	335.52	280.94	320.82	383.13
3/6/18 14:02	326.8	336.5	281.45	322	380.53
3/6/18 14:03	327.7	336.99	279.92	322.72	379.07
3/6/18 14:04	327.7	338.9	280.35	322.73	375.61
3/6/18 14:05	327.3	338.97	279.32	323.12	370.93
3/6/18 14:06	326.4	339.98	280.73	323.95	372.31
3/6/18 14:07	327.3	341.58	279.12	324.88	371.47
3/6/18 14:08	327.9	340.62	279.15	324.83	368.88
3/6/18 14:09	326.1	338.56	278.39	324.43	364.84
3/6/18 14:10	325.1	339.52	278.16	325.22	364.96
3/6/18 14:11	326.6	339.86	277.09	326.05	359.93
3/6/18 14:12	324.8	339.92	276.5	326.27	356.93
3/6/18 14:13	324	340.61	276.2	326.39	358.04
3/6/18 14:14	322.8	341.11	276.15	326.39	355.2
3/6/18 14:15	322.6	341.34	274.03	326.93	355.42
3/6/18 14:16	322.8	341.07	274.18	326.94	351.99
3/6/18 14:17	323.3	341.85	274.09	326.83	345.51
3/6/18 14:18	322.4	343.33	274.87	326.91	341.77
3/6/18 14:19	320.7	344.13	272.51	327.51	338.82
3/6/18 14:20	319.1	344.62	272.46	327.61	341.07
3/6/18 14:21	318.6	346.1	273.1	326.86	339.96

3/6/18 14:22	318.4	347.53	272.51	326.89	336.26
3/6/18 14:23	317.5	348.07	273.73	327.45	335.01
3/6/18 14:24	318.1	348.5	274.2	327.5	335.91
3/6/18 14:25	318.3	348.19	271.85	326.85	336.8
3/6/18 14:26	318.4	348.81	273.53	326.81	334.52
3/6/18 14:27	317.9	349.8	272.91	326.68	334.36
3/6/18 14:28	317.3	350.04	273.29	326.58	333.61
3/6/18 14:29	317.1	350.99	273.6	326.15	330.29
3/6/18 14:30	316	351.86	274.59	325.81	332.05
3/6/18 14:31	315.7	353.03	274.8	326.2	330.72
3/6/18 14:32	314.2	353.53	273.58	326.32	329.88

Test End

A	B	C	D	E	F	G	H
1	Test ID	CSL-00010					
2	Technician	BV, KO'B					
3	Date	3/12/18					
4	Start Time	12:45					
5	End Time	12:58					
6	Barometric Pressure	29.8	in Hg				
7	Room Temperature	64	F				
8	Relative Humidity	39	%				
9	Saturation Pressure	0.295	psia				
10	Actual Fan Speed for Test (Hz)	16	Hz				
11	Pre Test Pitot		in. water				
12	Leak Rate (15 seconds)	0	in. water	<-- Must be 0			
13	Static Pressure in Appliance (no DT)	0	in. water	Static Pressure in Appliance must be taken within 1 ft of top of appliance			
14	Static Pressure in Appliance (DT)	0	in.				
15	Difference	0	in. water	"Difference" must be less than 0.005 in WC			
16	Diameter of Tunnel (in)	8	in.				
17	Static Pressure in Dilution Tunnel (beginning)	0	in. water				
18	Point			Port A		Port B	
19		% of Diameter	Distance (inches)	Δp (in water)	Temperature (F)	Δp (in water)	Temperature (F)
20	1	n/a	n/a	n/a	n/a	n/a	n/a
21	2	6.7	0.536	0.035	64	0.035	64
22	3	25	2.0	0.035	64	0.045	64
23	Center	50	4.0	0.045	64	0.05	64
24	4	77	6.0	0.05	64	0.055	64
25	5	93.3	7.46	0.055	64	0.06	64
26	6	n/a	n/a	n/a	n/a	n/a	n/a
27	Post Test Pitot						
28	Static Pressure (after test)	0	in. water				
29	Leak Rate (15 seconds)	0	in. water				

ISS-1 ΔH@	
ISS-2 ΔH@	

Signature: _____

PRELIMINARY VELOCITY DETERMINATION

Test ID	CSL-00010
Date	3/12/18

Static Pressure (Pg)	0.000 in W.C.
Pitot Coefficient	0.99 unitless
Gas Molecular Weight (MW) wet	29.0 lb/lb-mole
Diameter of Tunnel	8.000 inches
Dilution Tunnel Cross Sectional Area	0.349 FT ²

POINT	% of Diameter		Distance (inches)		Port A		Port B			
	n/a	n/a	Δp (in W.C.)	√Δp (in W.C.)	Temp (F)	Temp (R)	Δp (in water)	√Δp (in W.C.)	Temp (F)	Temp (R)
1										
2	6.7	0.54	0.035	0.19	64.0	524	n/a	#VALUE!	n/a	#VALUE!
3	25.0	2.00	0.035	0.19	64.0	524	0.035	0.19	64.0	524
Center	50.0	4.00	0.045	0.21	64.0	524	0.045	0.21	64.0	524
4	77.0	6.00	0.050	0.22	64.0	524	0.050	0.22	64.0	524
5	93.3	7.46	0.055	0.23	64.0	524	0.055	0.23	64.0	524
6	n/a	n/a	#VALUE!	#VALUE!	64.0	524	n/a	#VALUE!	n/a	#VALUE!
AVERAGE			n/a	0.21	n/a	524	n/a	#VALUE!	n/a	#VALUE!

DILUTION TUNNEL CALCULATIONS

Absolute Gas Temperature: Tst = Ts + 459.67°

Absolute Gas Pressure: Ps = Pb + Pg/13.6

Gas Velocity: Vs = (85.49) x Cp x (avg √ΔP) x √(Tst.avg/(Ps*Mw))

Gas Flow Rate: Qa = Vs x 60 x cross sectional area

Tst =	524 °R
Ps =	29.8 inches Hg
Vs =	14.14 FT/sec
Qa =	296 ACFM
AVERAGE	849 FT/min

V_{avg} CALCULATIONS

Absolute Gas Temperature: Tst = Ts + 459.67°

Absolute Gas Pressure: Ps = Pb + Pg/13.6

Gas Velocity: Vs = (85.49) x Cp x (avg √ΔP) x √(Tst.avg/(Ps*Mw))

Gas Flow Rate: Qa = Vs x 60 x cross sectional area

AVERAGE √Δp	0.21 (in W.C.)
Tst =	524 °R
Ps =	29.8 inches Hg
Vs =	14.09 FT/sec
Qa =	295 ACFM
AVERAGE	845 FT/min

V_{sect} CALCULATIONS

Absolute Gas Temperature: Tst = Ts + 459.67°

Absolute Gas Pressure: Ps = Pb + Pg/13.6

Gas Velocity: Vs = (85.49) x Cp x (avg √ΔP) x √(Tst.avg/(Ps*Mw))

Gas Flow Rate: Qa = Vs x 60 x cross sectional area

AVERAGE √Δp	0.22 (in W.C.)
Tst =	524 °R
Ps =	29.8 inches Hg
Vs =	14.35 FT/sec
Qa =	301 ACFM
AVERAGE	86.1 FT/min

METER BOX CALCULATIONS

Proposed Proportional Sampling Rate: PR

Sample Probe Inside Diameter

Sample Probe Cross Sectional Area

1.00	inches
.175	FT ²
.00017	

0.982	FF
-------	----

270	SCFM
-----	------

296	ACFM
14.696	psia
14.4	psia
0.295	psia
0.39	%/100
523.67	R
491.67	R

Signature _____

Test ID:	CSL-00010
Date:	3.12.18

Test Fuel Pieces Weight (lbs)	Total Spacer Weight (lbs)	Total Test Fuel Charge Weight
10.84	0.82	11.66

Fuel Type	Doug Fir Crib
Preburn or Test Fuel Charge	Preburn

Average Test Fuel MC%	Test Fuel Density	Dry Basis Weight (lbs)	Charcoal Bed Loading Range (lbs)
21.65	25	8.49	2.33 to 2.92

*must be between 19-25% **Test Fuel Loading Density must be between 25-36 lb/ft³ ***Invariable piece length snail closely approximate 5/16 the dimension of the firebox length *****Test Fuel Load Range 7lbs +/- 0.7 lbs per ft³

Piece Number	Piece Size (in):			Weight (lbs):	Moisture Content			Average MC (%)	Volume		Avg. MC% x Dry Basis Weight
	Length	Width	Height		Moisture #1 (%)	Moisture #2 (%)	Moisture #3 (%)		Cubic Inches	Volume	
1	14.50	3.50	1.50	1.36	21.2	20.1	22.4	21.23	76.125	76.125	0.00000
2	14.50	3.50	1.50	1.22	22.3	20.2	20.9	21.13	76.125	76.125	0.00000
3	14.50	3.50	1.50	1.22	19.6	20.2	23.6	21.13	76.125	76.125	0.00000
4	14.50	3.50	3.50	3.62	22.0	21.4	22.3	21.90	177.625	177.625	0.00000
5	14.50	3.50	3.50	3.42	22.7	22.9	23.0	22.87	177.625	177.625	0.00000
6								#DIV/0!	0	0	0.00000
7								#DIV/0!	0	0	0.00000
8								#DIV/0!	0	0	0.00000
9								#DIV/0!	0	0	0.00000
10								#DIV/0!	0	0	0.00000
11								#DIV/0!	0	0	0.00000
12								#DIV/0!	0	0	0.00000
13								#DIV/0!	0	0	0.00000
14								#DIV/0!	0	0	0.00000
15								#DIV/0!	0	0	0.00000
16								#DIV/0!	0	0	0.00000
17								#DIV/0!	0	0	0.00000
18								#DIV/0!	0	0	0.00000
19								#DIV/0!	0	0	0.00000
20								#DIV/0!	0	0	0.00000
21								#DIV/0!	0	0	0.00000
22								#DIV/0!	0	0	0.00000
23								#DIV/0!	0	0	0.00000
24								#DIV/0!	0	0	0.00000
25								#DIV/0!	0	0	0.00000

Total Test Fuel Volume (in³):	583.625
Total Test Fuel Volume (ft³):	0.3377

Technician Signature: 
 Quality Review

Number of Spacers	10
Total Spacer Weight (lbs)	0.82
Average Spacer Moisture (%)	14.35

Spacer Number	Piece Size (in)			Moisture Content (%)
	Length	Width	Height	
1	5.00	1.50	0.75	16.4
2	5.00	1.50	0.75	13.1
3	5.00	1.50	0.75	16.2
4	5.00	1.50	0.75	15.2
5	5.00	1.50	0.75	20.1
6	5.00	1.50	0.75	10.9
7	5.00	1.50	0.75	14.0
8	5.00	1.50	0.75	10.7
9	5.00	1.50	0.75	10.5
10	5.00	1.50	0.75	16.4
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

23-2/28
Kelli Oberlin

Test ID:	CSL-00010
Date:	3.12.18

Fuel Type	Doug Fir Crib
Preburn or Test Fuel Charge	Test Fuel



Test Fuel Pieces Weight (lbs)	Total Spacer Weight (lbs)	Total Test Fuel Charge Weight
11.06	0.82	11.88

Average Test Fuel MC%	Test Fuel Density	Dry Basis Weight (lbs)	Charcoal Bed Loading Range (lbs)
21.22	26	8.71	2.38 to 2.97

***Test Fuel Loading Density must be between 25-36 lb/ft³ dimension of the firebox length*

Piece Number	Piece Size (in):			Weight (lbs):	Moisture Content			Average MC (%)	Volume		Avg. MC% x Dry Basis Weight
	Length	Width	Height		Moisture #1 (%)	Moisture #2 (%)	Moisture #3 (%)		Cubic Inches	Avg. MC% x Dry Basis Weight	
1	14.50	3.50	1.50	1.34	21.2	20.4	20.8	20.80	76.125	0.00000	0.00000
2	14.50	3.50	1.50	1.44	20.2	20.0	21.0	20.40	76.125	0.00000	0.00000
3	14.50	3.50	1.50	1.40	20.2	20.2	21.4	20.60	76.125	0.00000	0.00000
4	14.50	3.50	3.50	3.34	22.3	22.0	22.6	22.30	177.625	0.00000	0.00000
5	14.50	3.50	3.50	3.54	21.3	22.0	22.7	22.00	177.625	0.00000	0.00000
6								#DIV/0!	0	0.00000	0.00000
7								#DIV/0!	0	0.00000	0.00000
8								#DIV/0!	0	0.00000	0.00000
9								#DIV/0!	0	0.00000	0.00000
10								#DIV/0!	0	0.00000	0.00000
11								#DIV/0!	0	0.00000	0.00000
12								#DIV/0!	0	0.00000	0.00000
13								#DIV/0!	0	0.00000	0.00000
14								#DIV/0!	0	0.00000	0.00000
15								#DIV/0!	0	0.00000	0.00000
16								#DIV/0!	0	0.00000	0.00000
17								#DIV/0!	0	0.00000	0.00000
18								#DIV/0!	0	0.00000	0.00000
19								#DIV/0!	0	0.00000	0.00000
20								#DIV/0!	0	0.00000	0.00000
21								#DIV/0!	0	0.00000	0.00000
22								#DIV/0!	0	0.00000	0.00000
23								#DIV/0!	0	0.00000	0.00000
24								#DIV/0!	0	0.00000	0.00000
25								#DIV/0!	0	0.00000	0.00000

Total Test Fuel Volume (in³):	583.625
Total Test Fuel Volume (ft³):	0.3377

Technician Signature: 
 Quality Review: 

Number of Spacers	10
Total Spacer Weight (lbs)	0.82
Average Spacer Moisture (%)	16.67

Spacer Number	Piece Size (in)			Spacer Weight (lbs)	Moisture Content (%)
	Length	Width	Height		
1	5.00	1.50	0.75	0.08	19.0
2	5.00	1.50	0.75	0.08	19.3
3	5.00	1.50	0.75	0.08	19.1
4	5.00	1.50	0.75	0.10	20.7
5	5.00	1.50	0.75	0.08	11.6
6	5.00	1.50	0.75	0.08	15.5
7	5.00	1.50	0.75	0.08	17.5
8	5.00	1.50	0.75	0.08	11.6
9	5.00	1.50	0.75	0.08	17.6
10	5.00	1.50	0.75	0.08	14.8
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					

RS
Kelli Oberlin

Method 28 Data Collection	
Date	3/12/18
Operator	BV, KO'B
Test Type	Method 28R
Run #	3
Wood Heater Information	
Manufacturer/Model	MF Fire, Nova
Test ID	CSL-00010
Volume of water in Appliance (gal)	n/a
Weight of Appliance (empty) (lbs)	303.2
Volume of water in Storage (gal)	n/a
Weight of Storage Tank(s) (empty) (lbs)	n/a
Primary Air Setting (Hz)	n/a single burnrate stove
Secondary Air Setting (Hz)	n/a single burnrate stove
Thermostat Setting (F)	n/a
Fuel Type	Doug Fir crib wood

Velocity Traverse	
Static Pressure (in WC)	0
Vstrav (ACFM)	295
Vscent (ACFM)	301
Pre-Test Conditions	
Desired Flow Rate (load Side) (GPM)	n/a
Pre-test destratification volume pumped (need 2x) (gal)	n/a
Pre-test temperature difference (post destratification) (F)	n/a
Test facility temp at test start (F)	68
Room air velocity (FPM)	9,11,5
Ambient relative humidity (%)	37
Ambient barometric pressure (in Hg)	29.8
Adjustments to pre-test fuel	See Kelvin
Coal-bed weight prior to test start (lbs)	2.66

Post-Test Conditions	
Time of TFS ₂₀ (nh:mm) (leave blank if Cat. III or IV)	
room air velocity immediately following run (FPM)	8,9,7
test facility temperature after run (F)	75
ambient relative humidity after run (%)	29
ambient barometric pressure after run (in Hg)	29.7
Weight of unburnt fuel (lbs)	n/a

Note** When inputting data from the logger, the start time of the input must coincide with the start time of the test.

Signature _____


ISS-2

		Filter Change 1	Filter Change 2	Filter Change 3	
Weight (lbs)					
Elapsed Time Paused (hh:mm:ss)		14:40			
Elapsed Time Resume (hh:mm:ss)		15:40			
Actual Time Pause (hh:mm:ss)		14:40:00	14:40:00	14:40:00	
Actual Time Resume (hh:mm:ss)		14:40:00	14:40:00	14:40:00	
Test ID	CSL-00010	Filter Assemblies			
Date	3/12/18	A	FH #	FH-07, FH-6, FF-5	
Start Time (hh:mm:ss)	14:40		Front Filter #	G-18-0027	
End Time (hh:mm:ss)	16:59		Back Filter #	G-18-0028	
Y (DGM calibration factor)	1.0032	B	FH #	FH-09, FH-08, FF-14	
Pre test leak (A cfm @ B in Hg)	0.00 @ 15 in. Hg		Front Filter #	G-18-0032	
Post test leak (A cfm @ B in Hg)	0.00 @ 5 in. Hg		Back Filter #	G-18-0031	
		C	FH #		
			Front Filter #		
			Back Filter #		
Duration (hh:mm:ss)	DGM (ft ³)	ΔH (in H ₂ O)	Module In Temp (°F)	Module Out Temp (°F)	Vacuum (in Hg)
0:00:00	798.613	0.15	67	67	2.0
0:10:00	801.062	0.15	67	67	2.0
0:20:00	803.420	0.15	68	67	2.0
0:30:00	805.760	0.15	69	68	2.0
0:40:00	808.074	0.15	70	68	2.0
0:50:00	810.400	0.15	70	69	2.0
1:00:00	812.584	0.15	71	69	2.0
1:10:00	814.670	0.15	72	70	2.0
1:20:00	817.085	0.15	73	71	2.0
1:30:00	819.522	0.15	74	72	2.0
1:40:00	821.880	0.15	75	73	2.0
1:50:00	824.351	0.15	75	74	2.0
2:00:00	826.738	0.15	76	74	2.0
2:10:00	829.118	0.15	76	75	2.0
2:20:00	831.117				
2:30:00					
2:40:00					
2:44:54					
3:00:00					
3:10:00					

*Pre and Post leak checks should be 60 seconds in duration

PM Sampling Flow may be 0.15-.25 cfm

Test ID:		CSL-00010				
Date:		3/12/18				
ISS# / AS#	Filter / FH ID #	Pre-Weight Avg (g)	Post Weight Avg (g)	Total Catch (g)	Total Catch (mg)	
Ambient	AS-1	G-18-0024	0.1163	0.1163	0.0000	0.000
	AS-1	FF-04	63.8933	63.8932	-0.0002	0.000
ISS 1	ISS-1	G-18-0025	0.1121	0.1155	0.0034	3.450
	ISS-1	G-18-0026	0.1117	0.1116	0.0000	0.000
	ISS-1	FF-08	63.9892	63.9891	-0.0001	0.000
ISS 2A	ISS-2	G-18-0027	0.1164	0.1196	0.0032	3.250
	ISS-2	G-18-0028	0.1128	0.1129	0.0001	0.100
	ISS-2	FF-05	63.8484	63.8484	0.0000	0.000
ISS 2B	ISS-2	G-18-0032	0.1180	0.1181	0.0001	0.100
	ISS-2	G-18-0031	0.1120	0.1117	-0.0003	0.000
	ISS-2	FF-14	63.9026	63.9026	0.0000	0.000
n/a	ISS-2				0.0000	0.000
	ISS-2				0.0000	0.000
	ISS-2				0.0000	0.000

Signature 

Quality Review 

Test ID: CO-00010
 Date: 9/12/18

Test Duration (hh:mm:ss)	IS-1						PR
	T	V _{avg}	V _{max}	T	V _{avg}	V _{max}	
0:00:00							
0:10:00	10	0.067	11.03261	291.2	313.9554	0.067	11.47466 311.0086 291.2056 95.82623
0:20:00	20	0.068	11.1216	291.3	314.2331	0.135	11.72802 314.15 291.3444 95.21312
0:30:00	30	0.068	11.1685	291.5	314.5389	0.204	11.72212 313.8 291.7631 96.12694
0:40:00	40	0.067	11.09454	291.7	314.0944	0.270	11.45179 311.7543 292.3167 95.41549
0:50:00	50	0.067	11.04654	291.9	313.9	0.338	11.17559 311.7422 292.8722 98.55991
1:00:00	60	0.066	11.08744	292.1	313.8722	0.403	11.44822 311.5489 293.15 94.38505
1:10:00	70	0.055	11.11924	292.3	313.8778	0.459	11.71641 311.4937 293.4278 88.00489
1:20:00	80	0.066	11.14514	292.5	313.4554	0.525	11.71432 311.3818 293.9833 95.80211
1:30:00	90	0.067	11.1469	292.8	313.4444	0.592	11.71186 311.7501 294.5389 96.68024
1:40:00	100	0.068	11.13767	293.0	313.8162	0.660	11.44017 311.1178 294.9556 98.28956
1:50:00	110	0.068	11.15793	293.2	312.9944	0.728	11.41639 312.9108 295.2331 99.31124
2:00:00	120	0.066	11.17436	293.4	312.2054	0.794	11.70222 312.7342 295.5111 93.89532
2:10:00	130	0.067	11.15197	293.5	313.0	0.863	11.41820 312.4930 295.7889 98.09588
2:20:00	140	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
2:30:00	150	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
2:40:00	160	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
2:44:54	165	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:00:00	180	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:10:00	190	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:20:00	200	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:30:00	210	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:40:00	220	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:50:00	230	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:00:00	240	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:10:00	250	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:20:00	260	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:30:00	270	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:40:00	280	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:50:00	290	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:00:00	300	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:10:00	310	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:20:00	320	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:30:00	330	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:40:00	340	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:50:00	350	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:00:00	360	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:10:00	370	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:20:00	380	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:30:00	390	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:40:00	400	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:50:00	410	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:00:00	420	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:10:00	430	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:20:00	440	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:30:00	450	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:40:00	460	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:50:00	470	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:00:00	480	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:10:00	490	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:20:00	500	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:30:00	510	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:40:00	520	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:50:00	530	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:00:00	540	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:10:00	550	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:20:00	560	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:30:00	570	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:40:00	580	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:50:00	590	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:00:00	600	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:10:00	610	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:20:00	620	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:30:00	630	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:40:00	640	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:50:00	650	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
11:00:00	660	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
11:10:00	670	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
11:20:00	680	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
11:30:00	690	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
11:40:00	700	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
11:50:00	710	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
12:00:00	720	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!

Test Duration (hh:mm:ss)	IS-2						PR
	T	V _{avg}	V _{max}	T	V _{avg}	V _{max}	
0:00:00							
0:10:00	10	0.069348	11.03261	292.5944	314.2054	0.069348	11.47466 311.0086 292.5944 95.80254
0:20:00	20	0.069771	11.1216	292.7331	313.9554	0.138742	11.72802 314.15 292.7331 92.97135
0:30:00	30	0.062261	11.1685	293.15	314.2331	0.202389	11.72212 313.8 293.15 93.71323
0:40:00	40	0.065525	11.09454	293.5667	314.5389	0.267906	11.45179 311.7543 293.5667 95.01817
0:50:00	50	0.068985	11.04654	293.8444	314.0944	0.333773	11.17559 311.7422 293.8444 97.43901
1:00:00	60	0.061844	11.08744	294.1222	313.9	0.395615	11.44822 311.5489 294.1222 90.93697
1:10:00	70	0.059909	11.11924	294.5389	313.8722	0.454484	11.71641 311.4937 294.5389 88.00772
1:20:00	80	0.063885	11.14514	295.0944	313.4554	0.513069	11.71432 311.3818 295.0944 99.40079
1:30:00	90	0.060908	11.1469	295.64	313.4444	0.570277	11.71186 311.7501 295.64 100.082
1:40:00	100	0.060771	11.13767	296.2056	313.8162	0.628844	11.44017 311.1178 296.2056 98.78964
1:50:00	110	0.060973	11.15793	296.8222	312.8162	0.688813	11.41639 312.9108 296.8222 102.9987
2:00:00	120	0.067562	11.17436	296.4	312.5844	0.746411	11.70222 312.7342 296.4 92.20771
2:10:00	130	0.067394	11.15197	297.1778	312.2054	0.803895	11.41820 312.4930 297.1778 98.87842
2:20:00	140	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
2:30:00	150	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
2:40:00	160	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
2:44:54	165	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:00:00	180	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:10:00	190	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:20:00	200	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:30:00	210	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:40:00	220	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
3:50:00	230	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:00:00	240	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:10:00	250	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:20:00	260	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:30:00	270	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:40:00	280	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
4:50:00	290	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:00:00	300	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:10:00	310	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:20:00	320	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:30:00	330	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:40:00	340	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
5:50:00	350	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:00:00	360	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:10:00	370	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:20:00	380	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:30:00	390	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:40:00	400	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
6:50:00	410	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:00:00	420	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:10:00	430	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:20:00	440	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:30:00	450	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:40:00	460	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
7:50:00	470	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:00:00	480	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:10:00	490	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:20:00	500	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:30:00	510	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:40:00	520	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
8:50:00	530	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:00:00	540	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:10:00	550	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:20:00	560	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:30:00	570	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:40:00	580	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
9:50:00	590	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:00:00	600	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:10:00	610	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:20:00	620	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.2869 Error #VALUE!
10:30:00	630	Error	#VALUE!	Error	314.9278	Error	#N/D! 312.

Test ID	CSL-00010
Date	3/12/18

Module 2			
Variable	Description	Value	Units
	final volume module 2	812.584	cubic feet
	initial volume module 2	798.613	cubic feet
V _{m2}	total gas volume collected (module 2)	13.971	cubic feet
Average ΔH	average delta H over entirety of run	0.15	in water
T _m	average gas meter temperature	67	°F
P _{bar}	barometric pressure	29.8	in Hg
Y	DGM calibration factor	1.003	unitless
K _s	volume corrected to standard conditions	17.64	°F/(in Hg)
V _{mstd}	volume gas sampled (corrected to standard conditions)	13.9943261	dscf
Total Catch	total catch (raw data)	3.35	mg
C _s	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00023938	g/dscf

Ambient			
Variable	Description	Value	Units
	final volume ambient	91.9520	cubic meters
	initial volume ambient	91.9520	cubic meters
V _{m8}	total gas volume collected (ambient)	0.0000	cubic feet
Average ΔH	average delta H over entirety of run	4.00	in water
T _m	average gas meter temperature	68.6	°F
P _{bar}	barometric pressure	29.8	in Hg
Y	DGM calibration factor	1.002	unitless
K _s	volume corrected to standard conditions	17.64	°F/(in Hg)
V _{mstd}	volume gas sampled (corrected to standard conditions)	0	dscf
Total Catch	total catch (raw data)	0	mg
C ₈	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	#DIV/0!	g/dscf

Total Particulate Matter (based on ISS-2 and AS-1 data)			
Variable	Description	Value	Units
C _s	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00023938	g/dscf
C _R	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0	g/dscf
Q _{std}	average gas flow rate through dilution tunnel	285.978588	dscf/min
B _{ws}	water vapor in gas stream (assumed) (proportion by volume)	0.02	unitless
v _s	average velocity of gas through dilution tunnel	15.0219268	ft/s
A	cross-sectional area of dilution tunnel	0.349	square ft
T _s	average gas temperature in dilution tunnel	566.87	R
T _{std}	absolute average gas temperature in dilution tunnel	528	R
P _s	average gas static pressure in dilution tunnel	29.8	in Hg
P _{std}	standard absolute pressure	29.92	in Hg
F _p	adjustment factor for center of tunnel pitot tube placement	0.98	unitless
V _{trav}	average gas velocity after multi point pitot traverse	295	ACFM
V _{cent}	average gas velocity at center of dilution tunnel calculated after pitot tube traverse	301	ACFM
K _p	pitot tube constant	85.49	ft ² /(in Hg)/(ft ³ /min)
C _p	pitot tube coefficient	0.99	unitless
ΔP _{avg}	average velocity pressure in dilution tunnel	0.05	in H ₂ O
M _i	dilution tunnel dry gas MW (assumed)	29	lb/(lb-mol)
Θ	total sampling time	60.00	min
E _T	total particulate emissions	4.10750012	g

[Handwritten Signature]

Signature _____

[Handwritten Signature]

Quality Review _____

Test ID	CSL-00010
Date	3/12/18

Module 1			
Variable	Description	Value	Units
	final volume module 1	526.481	cubic feet
	initial volume module 1	493.972	cubic feet
V_{col}	total gas volume collected (module 1)	32.509	cubic feet
Average ΔH	average delta H over entirety of run	0.15	in water
T_m	average gas meter temperature	69	°F
P_{bar}	barometric pressure	29.8	in Hg
Y	DGM calibration factor	1.004	unitless
K_1	volume corrected to standard conditions	17.64	R/(in Hg)
V_{total}	volume gas sampled (corrected to standard conditions)	32.4789829	dscf
Total Catch	total catch (raw data)	3.45	mg
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00010622	g/dscf

Module 2			
Variable	Description	Value	Units
	final volume module 2	831.117	cubic feet
	initial volume module 2	798.613	cubic feet
V_{col}	total gas volume collected (module 2)	32.504	cubic feet
Average ΔH	average delta H over entirety of run	0.15	in water
T_m	average gas meter temperature	71	°F
P_{bar}	barometric pressure	29.8	in Hg
Y	DGM calibration factor	1.003	unitless
K_1	volume corrected to standard conditions	17.64	°F/(in Hg)
V_{total}	volume gas sampled (corrected to standard conditions)	32.31509317	dscf
Total Catch	total catch (raw data)	3.45	mg
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.000106761	g/dscf

Ambient			
Variable	Description	Value	Units
	final volume ambient	92.2500	cubic meters
	initial volume ambient	91.9520	cubic meters
V_{col}	total gas volume collected (ambient)	10.5238	cubic feet
Average ΔH	average delta H over entirety of run	3.57	in water
T_m	average gas meter temperature	71.8	°F
P_{bar}	barometric pressure	29.8	in Hg
Y	DGM calibration factor	1.002	unitless
K_1	volume corrected to standard conditions	17.64	°F/(in Hg)
V_{total}	volume gas sampled (corrected to standard conditions)	10.52621601	dscf
Total Catch	total catch (raw data)	0	mg
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0	g/dscf

Total Particulate Matter (based on ISS-2 and AS-1 data)			
Variable	Description	Value	Units
C_1	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0.00010649	g/dscf
C_2	concentration of PM in tunnel gas (dry basis, corrected to standard conditions)	0	g/dscf
Q_{dil}	average gas flow rate through dilution tunnel	286.272424	dscf/min
B_{dil}	water vapor in gas stream (assumed) (proportion by volume)	0.02	unitless
V_c	average velocity of gas through dilution tunnel	15.4321401	ft/s
A	cross-sectional area of dilution tunnel	0.349	square ft
T_c	average gas temperature in dilution tunnel	562.116429	R
T_{dil}	absolute average gas temperature in dilution tunnel	528	R
P_c	average gas static pressure in dilution tunnel	29.8	in Hg
P_{std}	standard absolute pressure	29.92	in Hg
F_p	adjustment factor for center of tunnel pitot tube placement	0.98	unitless
V_{meas}	average gas velocity after multi-point pitot traverse	295	ACFM
V_{total}	average gas velocity at center of dilution tunnel calculated after pitot tube traverse	301	ACFM
K_p	pitot tube constant	85.49	$\frac{ft \cdot lb}{lb \cdot ft^2} = \frac{ft \cdot lb}{lb \cdot ft^2}$
C_p	pitot tube coefficient	0.99	unitless
ΔP_{meas}	average velocity pressure in dilution tunnel	0.05321429	in H ₂ O
M _d	dilution tunnel dry gas MW (assumed)	29	lb/(lb-mol)
θ	total sampling time	139.00	min
E_T	total particulate emissions	4.3855394	g

Signature: 
 Quality Review

Test ID:	CSL-00010
Date:	3/12/18

Q _{in}	Btu	#DIV/0!	
Q _{in UNV}		#DIV/0!	
Q _{in Condens}	Btu	#DIV/0!	
Q _{out}	Btu	#VALUE!	(3 sig figs)
Heat Output Rate	Btu/hr	#VALUE!	(3 sig figs)
Load Draw	Btu/hr		0
E _{g/MJ}	g/MJ	#VALUE!	
E _{lb/MMBtu}	lb/MMBtu	#VALUE!	
E _{g/kg}	g/kg	#REF!	
E _{g/hr}	g/hr		1.893038588
Θ ₁	min		0.00
Θ ₂	min		0.00
Θ ₃	min		139.00
Θ ₄	hours		0
Θ	hours		2.32
η _{out}	%	#VALUE!	
η _{out UNV}	%	#VALUE!	

E ₁	g		4.10750
E ₂	g	#DIV/0!	
E ₃	g		0.00000
E _{1, g/kg}	g/kg	#REF!	
E _{2, g/kg}	g/kg	#DIV/0!	
E _{3, g/kg}	g/kg	#N/A	
ET	g		4.385539395

Run #			4
Wood Weight	lbs		0.00
Wood Moisture	%DB	#DIV/0!	
Min H ₂ O Temp (T ₂)	°F	#N/A	

CO _{in}	Startup CO emission (g)	#N/A
CO _{in}	Steady State CO emission (g)	#N/A
CO _{out}	End CO emission (g)	#N/A
COT	Total CO emission (g)	#N/A

Fill in boxes in light red. Calculated values are yellow.

Measurement Uncertainty for Total Particulate Emissions

	Measured Value	Measurement Uncertainty (+/-)	Units
Sample Filter Catch Average ISS1 and ISS2 (Fc):	0.00345	0.000273205	g
Sample Flow Rate (Qsample):	0.23	0.0023	dscfm
Sampling Duration (theta):	139	0.1	minutes
Background Filter Catch (BGc):	0	0.000273205	g
Background Filter Flow Rate (Qbg):	0.076	0.00076	dscfm
Tunnel Flow Rate (Qstd):	296	5.92	dscfm

Number of Total Weighings Required to Find Sample Filter Catch:	3
Number of Total Weighings Required to Find Background Filter Catch:	3

$E_t = (C_s - C_r)Q_{std}(\Theta)$
 $C_s = \text{sample filter catch} / (\text{sample flow rate} * \text{test duration}) \text{ g/dscf}$
 $C_r = \text{room background filter catch} / (\text{sample flow} * \text{test duration}) \text{ g/dscf}$
 $Q_{std} = \text{average dilution tunnel flow rate, dscf/min}$
 $\Theta = \text{sampling time, minutes}$

Calculating MU of Cs	
Cs	0.000107914
Delta Cs/Delta Fc	0.031279324
Delta Cs/Delta Qsample	-0.00046919
Delta Cs/Delta Theta	-7.76357E-07
MU of Cs	8.61389E-06 g

Calculating MU of Cr	
Cr	0
Delta Cr/DeltaBGc	0.094661113
Delta Cr/Delta Qbg	0
Delta Cr/Delta Theta	0
MU of Cr	2.58619E-05 g

Calculating MU of Et	
Et	4.44 g
Delta Et/Delta Cs	41144
Delta Et/Delta Cr	41144
Delta Et/Delta Qstd	0.015
Delta Et/Delta theta	0.031942446
MU of Et	1.125046502 g

ET =	4.44 grams
with a 95% Confidence Interval of:	1.125046502 (+/-) grams

Reporting Period: 03/12/2018 to 03/12/2018

Site Name: SAMPLE

Time of Report: 03/12/18 17:35

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	Z (none)	COND2OUI (Deg_F)	DIL_CO2 (%)	DILRATIO (RATIO)	FILT1OUT (Deg_F)	FILT2OUT (Deg_F)	ROOM_TMI (Deg_F)	TUNL_TMP (Deg_F)	UNIT_WT (lbs)	Fuel consumed + coal bed
3/12/18	14:40	1	63.6		3.142	66.7	67.4	65.4	107.2	14.54	11.88
3/12/18	14:41	1	63.5		2.95	67.4	71.3	65	112.7	14.54	11.88
3/12/18	14:42	1	63.3		3.01	68.5	74.4	65.3	116.2	14.59	11.93
3/12/18	14:43	1	63.1		3.164	69.3	75.1	65	108	14.27	11.61
3/12/18	14:44	1	63		3.087	69.9	75.5	64.9	106.5	14.1	11.44
3/12/18	14:45	1	63.1		3.029	70.4	76.1	65	106	13.91	11.25
3/12/18	14:46	1	63		3.048	71	76.7	65.1	105.2	13.72	11.06
3/12/18	14:47	1	63		3.034	71.5	76.9	65.2	105	13.56	10.9
3/12/18	14:48	1	62.9		2.984	71.9	77.3	65.2	104.9	13.41	10.75
3/12/18	14:49	1	62.7		2.997	72.3	77.6	65	104.5	13.25	10.59
3/12/18	14:50	1	62.7		2.984	72.6	77.9	65	104.6	13.1	10.44
3/12/18	14:51	1	62.6		3.018	73	78	65.3	104.4	12.94	10.28
3/12/18	14:52	1	62.7		2.994	73.1	78.1	65.2	104.4	12.77	10.11
3/12/18	14:53	1	62.5		3.03	73.3	78.3	65.5	104.3	12.61	9.95
3/12/18	14:54	1	62.2		2.999	73.6	78.6	65.6	104.4	12.46	9.8
3/12/18	14:55	1	61.8		3.018	74	78.9	65.6	104.2	12.32	9.66
3/12/18	14:56	1	61.3		3.035	74.1	79	65.6	104	12.16	9.5
3/12/18	14:57	1	60.6		3.032	74.3	79.1	65.6	103.8	11.99	9.33
3/12/18	14:58	1	59.9		3.002	74.4	79	65.8	103.9	11.81	9.15
3/12/18	14:59	1	59.6		2.967	74.6	79.5	65.7	103.9	11.67	9.01
3/12/18	15:00	1	59.1		3.046	74.6	79.4	65.8	103.7	11.52	8.86
3/12/18	15:01	1	58.7		3.054	74.7	79.5	66	103.4	11.35	8.69
3/12/18	15:02	1	58.2		3.089	74.8	79.5	66	103.3	11.21	8.55
3/12/18	15:03	1	57.9		3.048	74.8	79.6	65.7	103.6	11.03	8.37
3/12/18	15:04	1	57.6		3.021	75	79.7	65.8	103.9	10.84	8.18
3/12/18	15:05	1	57.3		3.06	75	79.7	65.9	103.3	10.69	8.03
3/12/18	15:06	1	57.1		3.102	75.2	79.8	66.2	103.1	10.52	7.86
3/12/18	15:07	1	56.9		3.008	75.3	80	65.9	103.9	10.38	7.72
3/12/18	15:08	1	56.7		2.98	75.4	80.2	66.3	104.1	10.23	7.57
3/12/18	15:09	1	56.6		2.922	75.6	80.3	66.3	104.7	10.07	7.41
3/12/18	15:10	1	56.3		2.941	75.7	80.5	66.3	104.3	9.91	7.25
3/12/18	15:11	1	56		2.974	75.7	80.5	66.6	104.4	9.75	7.09
3/12/18	15:12	1	55.8		2.941	75.8	80.5	66.3	104.4	9.61	6.95
3/12/18	15:13	1	55.7		3.023	76	80.7	66.6	103.7	9.44	6.78
3/12/18	15:14	1	55.6		3.046	76.2	80.7	67.2	103.7	9.28	6.62
3/12/18	15:15	1	55.5		3.027	76.4	80.8	67.2	104.6	9.11	6.45
3/12/18	15:16	1	55.5		3.011	76.5	80.9	66.8	105.1	8.96	6.3
3/12/18	15:17	1	55.5		2.971	76.7	81.1	66.8	105.5	8.82	6.16
3/12/18	15:18	1	55.5		2.876	76.8	81.2	66.7	105.7	8.67	6.01
3/12/18	15:19	1	55.1		2.812	76.8	81.3	66.9	106.3	8.52	5.86
3/12/18	15:20	1	55		2.906	76.6	81.1	67.1	105.8	8.39	5.73
3/12/18	15:21	1	55		2.887	76.7	81.2	67	106	8.28	5.62
3/12/18	15:22	1	54.9		2.888	76.7	81.3	66.8	105.7	8.15	5.49
3/12/18	15:23	1	54.7		2.922	76.7	81.4	66.7	105.6	8.05	5.39
3/12/18	15:24	1	54.7		2.956	76.7	81.3	66.8	105	7.93	5.27
3/12/18	15:25	1	54.7		2.953	76.7	81.3	67	104.8	7.83	5.17
3/12/18	15:26	1	54.5		2.902	76.7	81.4	66.3	104.4	7.71	5.05
3/12/18	15:27	1	54.5		2.879	76.7	81.3	66.5	104.4	7.61	4.95
3/12/18	15:28	1	54.4		2.875	76.5	81.1	66.6	104.6	7.53	4.87
3/12/18	15:29	1	54.3		2.899	76.6	81.3	66.5	104.2	7.43	4.77
3/12/18	15:30	1	54.2		2.908	76.7	81.2	66.6	103.5	7.32	4.66
3/12/18	15:31	1	54.2		2.897	76.5	81	66.6	103.7	7.23	4.57
3/12/18	15:32	1	54.1		2.918	76.3	80.9	66.3	103.3	7.12	4.46
3/12/18	15:33	1	54.2		2.912	76.3	80.9	66.4	103.6	7.03	4.37
3/12/18	15:34	1	54.2		2.932	76.3	80.9	66.4	103.4	6.93	4.27
3/12/18	15:35	1	54		2.955	76.2	80.7	66.5	102.7	6.82	4.16
3/12/18	15:36	1	53.9		2.987	76.1	80.7	66.3	102.1	6.72	4.06
3/12/18	15:37	1	53.9		3.03	76.2	80.9	67	103.1	6.62	3.96
3/12/18	15:38	1	53.7		3.083	76.4	81	67.7	103.3	6.51	3.85
3/12/18	15:39	1	53.8		3.159	76.6	81.3	68.2	103.4	6.42	3.76
3/12/18	15:40	1	54.3		3.199	76.3	113.6	68.3	103.5	6.35	3.69
3/12/18	15:41	1	55.6		3.186	75.8	94.3	68.4	103.3	6.26	3.6
3/12/18	15:42	1	55.8		3.124	76.1	76.1	68.5	103.5	6.17	3.51

3/12/18	15:43	1	55.1	3.126	76.4	77.7	68.6	103.7	6.08	3.42
3/12/18	15:44	1	54.9	3.136	76.7	78.7	68.7	103.9	6	3.34
3/12/18	15:45	1	54.5	3.14	76.8	79.3	68.9	104.3	5.95	3.29
3/12/18	15:46	1	54.3	3.16	76.9	79.6	69	104.1	5.86	3.2
3/12/18	15:47	1	54.3	3.109	77.3	80.1	68.7	104.2	5.79	3.13
3/12/18	15:48	1	54.1	3.116	77.5	80.5	69.1	104	5.72	3.06
3/12/18	15:49	1	54.1	3.122	77.8	80.7	69.3	103.4	5.66	3
3/12/18	15:50	1	54	3.114	77.9	80.9	69.4	103.4	5.58	2.92
3/12/18	15:51	1	54.1	3.168	78.1	81.2	69.6	103.4	5.53	2.87
3/12/18	15:52	1	54.1	3.191	78.2	81.4	69.8	103.5	5.45	2.79
3/12/18	15:53	1	54	3.196	78.3	81.6	69.7	103.3	5.38	2.72
3/12/18	15:54	1	54	3.149	78.6	81.7	69.9	103.3	5.31	2.65
3/12/18	15:55	1	53.9	3.159	78.6	81.9	69.7	103.2	5.24	2.58
3/12/18	15:56	1	54.1	3.185	78.9	82.1	69.8	103	5.18	2.52
3/12/18	15:57	1	54.2	3.218	78.8	82.2	70.1	103	5.11	2.45
3/12/18	15:58	1	54.2	3.166	78.9	82.2	70.1	103.1	5.04	2.38
3/12/18	15:59	1	54.2	3.188	79	82.2	70.2	102.6	4.98	2.32
3/12/18	16:00	1	54.2	3.188	79.2	82.3	70.3	102.7	4.93	2.27
3/12/18	16:01	1	54.1	3.189	79.2	82.5	70.4	103	4.86	2.2
3/12/18	16:02	1	54.2	3.235	79.3	82.5	70.7	102.8	4.8	2.14
3/12/18	16:03	1	54.2	3.274	79.3	82.5	70.7	102.3	4.74	2.08
3/12/18	16:04	1	54.2	3.289	79.4	82.5	70.6	102.1	4.68	2.02
3/12/18	16:05	1	54.2	3.294	79.6	82.7	70.7	102	4.63	1.97
3/12/18	16:06	1	54.2	3.268	79.5	82.8	70.6	102.2	4.57	1.91
3/12/18	16:07	1	54.2	3.269	79.6	82.8	70.8	102.2	4.52	1.86
3/12/18	16:08	1	54.2	3.263	79.6	82.8	70.8	102	4.47	1.81
3/12/18	16:09	1	54.2	3.186	79.7	82.8	70.7	102.1	4.38	1.72
3/12/18	16:10	1	54.2	3.208	79.7	83	70.8	101.9	4.33	1.67
3/12/18	16:11	1	54.5	3.224	79.6	82.8	70.7	101.8	4.29	1.63
3/12/18	16:12	1	54.3	3.246	79.6	82.8	70.6	101.6	4.23	1.57
3/12/18	16:13	1	54.5	3.24	79.7	83	71	101.5	4.19	1.53
3/12/18	16:14	1	54.4	3.263	79.7	82.9	71.4	101.3	4.11	1.45
3/12/18	16:15	1	54.4	3.284	79.7	82.9	71.4	101.4	4.06	1.4
3/12/18	16:16	1	54.4	3.278	79.7	82.9	71.5	101.6	4	1.34
3/12/18	16:17	1	54.4	3.299	79.8	83.1	71.5	101.6	3.96	1.3
3/12/18	16:18	1	54.4	3.295	79.9	83.1	71.4	101.5	3.91	1.25
3/12/18	16:19	1	54.5	3.3	79.8	83	71.6	101.5	3.85	1.19
3/12/18	16:20	1	54.5	3.254	79.9	83.1	70.7	101	3.82	1.16
3/12/18	16:21	1	54.4	3.242	79.8	83	71.2	100.4	3.77	1.11
3/12/18	16:22	1	54.4	3.264	79.7	82.8	71.3	100.3	3.74	1.08
3/12/18	16:23	1	54.6	3.337	79.7	82.8	71.9	100	3.69	1.03
3/12/18	16:24	1	54.7	3.345	79.8	82.9	71.9	100.4	3.65	0.99
3/12/18	16:25	1	54.6	3.343	79.7	82.9	71.9	100.6	3.61	0.95
3/12/18	16:26	1	54.5	3.339	79.7	83	72	100.7	3.59	0.93
3/12/18	16:27	1	54.5	3.348	79.6	82.8	71.6	100.2	3.52	0.86
3/12/18	16:28	1	54.7	3.352	79.5	82.7	71.6	99.8	3.5	0.84
3/12/18	16:29	1	54.6	3.392	79.6	82.7	71.6	99	3.46	0.8
3/12/18	16:30	1	54.6	3.344	79.6	82.7	71.8	99.6	3.45	0.79
3/12/18	16:31	1	54.5	3.385	79.5	82.7	72.2	99.8	3.37	0.71
3/12/18	16:32	1	54.5	3.437	79.5	82.7	72.2	99.6	3.36	0.7
3/12/18	16:33	1	54.7	3.393	79.5	82.7	71.9	99.6	3.35	0.69
3/12/18	16:34	1	54.6	3.368	79.6	82.7	71.6	99.3	3.32	0.66
3/12/18	16:35	1	54.6	3.408	79.5	82.7	71.7	99.1	3.26	0.6
3/12/18	16:36	1	54.6	3.368	79.5	82.6	71.8	99.5	3.25	0.59
3/12/18	16:37	1	54.7	3.434	79.4	82.5	72.3	99.3	3.23	0.57
3/12/18	16:38	1	54.7	3.471	79.4	82.4	72.4	99.1	3.2	0.54
3/12/18	16:39	1	54.6	3.488	79.4	82.5	72.4	98.8	3.16	0.5
3/12/18	16:40	1	54.6	3.451	79.5	82.5	72.1	98.6	3.15	0.49
3/12/18	16:41	1	54.6	3.478	79.4	82.4	72.3	98.7	3.14	0.48
3/12/18	16:42	1	54.6	3.499	79.3	82.4	72.3	98.5	3.12	0.46
3/12/18	16:43	1	54.7	3.457	79.5	82.5	72.1	98.5	3.07	0.41
3/12/18	16:44	1	54.7	3.409	79.5	82.4	71.8	98.1	3.05	0.39
3/12/18	16:45	1	54.7	3.36	79.4	82.3	72.1	98.4	3.03	0.37
3/12/18	16:46	1	54.7	3.434	79.3	82.2	72.2	98.2	3.01	0.35
3/12/18	16:47	1	54.7	3.5	79.3	82	72.3	97.9	3	0.34
3/12/18	16:48	1	54.8	3.54	79.3	81.9	72.4	97.6	2.95	0.29
3/12/18	16:49	1	54.9	3.541	79.3	81.9	72	97	2.95	0.29
3/12/18	16:50	1	54.9	3.514	79.3	82	72.3	97.4	2.92	0.26
3/12/18	16:51	1	54.9	3.514	79.2	81.9	72.2	97.4	2.91	0.25
3/12/18	16:52	1	54.8	3.556	79.2	81.9	72.4	97.3	2.88	0.22
3/12/18	16:53	1	54.9	3.523	79.2	81.8	72.3	97.5	2.86	0.2

3/12/18	16:54	1	55.1	3.494	79.1	81.8	72	97.2	2.85	0.19
3/12/18	16:55	1	55.1	3.491	79.2	81.9	72.1	97.1	2.83	0.17
3/12/18	16:56	1	55	3.479	79.2	81.9	72.2	97.1	2.79	0.13
3/12/18	16:57	1	54.9	3.445	79.2	81.9	72.2	97.1	2.76	0.1
3/12/18	16:58	1	55	3.447	79.1	81.7	71.7	96.3	2.76	0.1
3/12/18	16:59	1	55.7	3.443	78.7	80.4	71.8	96.3	2.75	0

General Average Report

Reporting Period: 03/12/2018 to 03/12/2018

Site Name: UNIT

Time of Report: 03/12/18 17:34

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	TEMP_10 (Deg_F)	TEMP_11 (Deg_F)	TEMP_12 (Deg_F)	TEMP_13 (Deg_F)	CAT_PRE (Deg_F)	
3/12/18	14:40	267.49	218.62	293.83	567.21	279.9	325.41 Average Surface Temp
3/12/18	14:41	271.86	220.67	298.92	564.8	281.4	
3/12/18	14:42	273.98	219.1	302.28	560.94	284.4	
3/12/18	14:43	270.19	220.35	300.81	541.77	287.4	
3/12/18	14:44	272.77	222.21	302.97	539.06	290.5	
3/12/18	14:45	275.27	223.58	305.08	533.69	292.6	
3/12/18	14:46	275.78	223.4	305.81	531.88	293.5	
3/12/18	14:47	275.23	221.79	304.95	529.39	292.9	
3/12/18	14:48	276.43	221.38	307.08	533.68	293.6	
3/12/18	14:49	279.4	224	309.42	528.6	294.3	
3/12/18	14:50	281.43	225.19	310.29	528.51	297.5	
3/12/18	14:51	282.31	226.55	311.15	528.4	296.8	
3/12/18	14:52	282.79	224.75	311.4	532.7	293.7	
3/12/18	14:53	282.38	220.57	310.12	528.71	294.9	
3/12/18	14:54	283.21	223.19	310.36	532.07	295	
3/12/18	14:55	285.73	223.77	311.74	531.51	294.4	
3/12/18	14:56	287.01	225.8	311.29	530.92	294.1	
3/12/18	14:57	286.59	224.69	309.91	534.67	293.7	
3/12/18	14:58	287.33	223	309.76	531.61	294.1	
3/12/18	14:59	288.4	224.56	310.08	533.68	293.4	
3/12/18	15:00	288.91	224.07	311.42	533.28	295.9	
3/12/18	15:01	289.74	226.53	309.11	539	294.1	
3/12/18	15:02	290.44	226.19	311.19	545.93	292.8	
3/12/18	15:03	290.6	225.11	310.41	546.34	291.9	
3/12/18	15:04	289.68	223.48	311.47	542	294.9	
3/12/18	15:05	292.48	227.05	312.47	552.54	297	
3/12/18	15:06	291.41	228.46	311.75	546.85	296.8	
3/12/18	15:07	292.21	226.67	310.99	560.95	294.5	
3/12/18	15:08	290.61	225.74	309.8	562.45	292.4	
3/12/18	15:09	290.43	222.6	310.03	552.27	294.7	
3/12/18	15:10	290.84	223.03	311.3	555.05	295.1	
3/12/18	15:11	292.77	224.53	312.91	559.54	296.7	
3/12/18	15:12	293.02	222.59	312.72	561.14	297.5	
3/12/18	15:13	299.47	223.89	322.33	584.41	307.3	
3/12/18	15:14	301.15	229.51	323.92	588.91	307	
3/12/18	15:15	297.64	230.65	318.57	579.76	301.2	
3/12/18	15:16	295.42	227.12	318.02	577.49	299.1	
3/12/18	15:17	296.96	224.76	319.11	581.64	297.9	
3/12/18	15:18	298.23	224.73	319.46	588.44	297.8	
3/12/18	15:19	297.58	226.78	320.05	584.95	300.3	
3/12/18	15:20	297.74	222.99	320.47	585.18	304.2	
3/12/18	15:21	298.29	222.92	320.56	589.86	304.6	
3/12/18	15:22	298.97	224.51	321.17	589.95	302	

3/12/18	15:23	301.34	223.47	322.45	589.56	301.4
3/12/18	15:24	301.48	224.05	323.06	589.12	302.6
3/12/18	15:25	302.05	223.61	324.09	575.79	307.8
3/12/18	15:26	303.63	225.98	323.4	572.62	307.8
3/12/18	15:27	303.91	226.95	324.09	565.92	309.5
3/12/18	15:28	305.58	226.76	326.27	564.34	308.9
3/12/18	15:29	305.49	229.95	325.87	565.85	307.6
3/12/18	15:30	305.42	228.72	325.96	552.46	309.8
3/12/18	15:31	305.94	227.29	327.65	545.87	312.5
3/12/18	15:32	307.51	229.91	328.71	550.42	312.2
3/12/18	15:33	307.53	227.16	329.11	543.95	313.5
3/12/18	15:34	309.04	227.45	328.79	541.12	312.3
3/12/18	15:35	308.25	228.36	328.53	540.02	312.4
3/12/18	15:36	311.37	228.99	332.62	540.48	318.6
3/12/18	15:37	317.84	235.23	337.14	558.44	325.2
3/12/18	15:38	319.54	240.25	337.65	560.6	324.5
3/12/18	15:39	320.72	242.6	337.85	560.67	326.4
3/12/18	15:40	322.17	244.02	339.42	559.03	326.5
3/12/18	15:41	323.72	243.43	341.06	559.94	327.9
3/12/18	15:42	324.75	244.08	340.95	556.64	329
3/12/18	15:43	325.52	245.95	342.99	555.82	329.8
3/12/18	15:44	327	248.2	344.25	553.96	331.2
3/12/18	15:45	328.75	248.37	345.51	550.89	330.6
3/12/18	15:46	329.65	248.97	345.91	548.8	331.8
3/12/18	15:47	330.04	249	347.81	543.06	331.9
3/12/18	15:48	331.32	249.43	347.91	541.39	332.8
3/12/18	15:49	333.17	250.52	349.25	536.88	333.5
3/12/18	15:50	334.39	250.4	349.13	534.45	333.7
3/12/18	15:51	335.28	251.75	350.05	531.82	334.8
3/12/18	15:52	335.97	252.7	350.76	529.46	334.3
3/12/18	15:53	337.11	253.1	350.62	524.37	334
3/12/18	15:54	339.15	253.25	350.24	521.31	335.8
3/12/18	15:55	339.87	254.35	350.25	520.96	336.6
3/12/18	15:56	340.29	255.57	350.83	516.74	337.8
3/12/18	15:57	340.73	256.02	352.16	513.89	336.5
3/12/18	15:58	341.79	256.52	352.39	512.6	336.4
3/12/18	15:59	341.97	256.35	353.35	510.81	336.3
3/12/18	16:00	342.74	256.68	352.7	506.88	337
3/12/18	16:01	343.46	257.36	352.65	503.65	336.6
3/12/18	16:02	344.72	257.62	353.73	501.29	336.7
3/12/18	16:03	345.85	258.31	353.02	501.1	337.6
3/12/18	16:04	346.01	259.15	352.97	499.58	337.7
3/12/18	16:05	346.34	259.48	353.86	496.93	337.6
3/12/18	16:06	347.5	260.65	353.94	494.77	336.9
3/12/18	16:07	348.18	259.64	354.49	493.24	336.9
3/12/18	16:08	348.16	260.07	355.84	488.71	336.1
3/12/18	16:09	348.35	260.51	356.93	489.6	336.4
3/12/18	16:10	349.23	260.62	355.45	487.22	335.9
3/12/18	16:11	350.34	261.44	354.41	484.47	335.9
3/12/18	16:12	350.23	262.98	355.16	481.18	336.1
3/12/18	16:13	350.99	264.05	354.83	482	337.3

3/12/18	16:14	352.23	264.31	354.48	483.87	338.7	
3/12/18	16:15	352.97	265.32	354.09	481.93	337.7	
3/12/18	16:16	353.31	265.59	353.62	479.94	337.1	
3/12/18	16:17	353.32	265.56	354.03	480.3	337.3	
3/12/18	16:18	354.08	265.76	354.15	481.14	338.1	
3/12/18	16:19	355	265.95	353.81	479.74	338	
3/12/18	16:20	355.18	265.35	354.78	479.72	337.5	
3/12/18	16:21	355.62	266.87	355.39	478.28	337.5	
3/12/18	16:22	355.86	267.46	355.5	477.71	338.8	
3/12/18	16:23	356.52	267.93	354.79	474.05	337.9	
3/12/18	16:24	356.91	269.81	355.07	472.8	336.5	
3/12/18	16:25	357.26	270.71	354.5	472.45	336.6	
3/12/18	16:26	357.47	271.19	354.72	471.44	336	
3/12/18	16:27	358.17	269.71	355.15	469.28	336.4	
3/12/18	16:28	359.71	270.25	353.74	467.17	338.1	
3/12/18	16:29	359.4	270.84	354.28	466.87	337.2	
3/12/18	16:30	360.2	271.54	353.82	464.88	337.9	
3/12/18	16:31	360.89	272.1	354.64	463.28	337.8	
3/12/18	16:32	361.7	273.6	353.94	461.55	337.8	
3/12/18	16:33	362.03	273.67	353.09	459.88	337.1	
3/12/18	16:34	361.6	274.96	353.21	454.94	335.4	
3/12/18	16:35	361.84	275.78	352.95	454.52	336.4	
3/12/18	16:36	363.01	276.79	352.52	452.66	336.8	
3/12/18	16:37	363.62	276.64	352.63	452.05	335.6	
3/12/18	16:38	363.44	277.35	353.23	449.36	336	
3/12/18	16:39	363.77	277.31	353.32	445.58	336.1	
3/12/18	16:40	364.71	277.85	352.93	442.94	335.6	
3/12/18	16:41	365.53	279.11	352.22	439.81	335.6	
3/12/18	16:42	365.36	280.13	352.41	436.93	335.8	
3/12/18	16:43	365.21	279.24	352.47	435.85	335.2	
3/12/18	16:44	364.73	278.64	352.72	432.34	333.8	
3/12/18	16:45	366.25	278.63	351.13	430.45	333.3	
3/12/18	16:46	366.35	279.83	350.72	429.07	333.3	
3/12/18	16:47	366.61	280.48	350.57	426.21	333.9	
3/12/18	16:48	367.21	280.54	350.92	424.28	334.4	
3/12/18	16:49	367.53	280.7	351.19	421.49	334.1	
3/12/18	16:50	368.12	282.89	350.1	419.15	333	
3/12/18	16:51	368.12	283.21	350.98	416.97	333.2	
3/12/18	16:52	368.37	284.17	350.23	416.06	333.5	
3/12/18	16:53	368.96	284.15	348.52	413.25	332.9	
3/12/18	16:54	369.67	284.66	348.5	411.1	332.8	
3/12/18	16:55	369.37	284.22	348.74	409.27	332.7	
3/12/18	16:56	369.62	284.1	348.38	407.7	332.2	
3/12/18	16:57	369.96	285.13	347.25	406.05	332.6	
3/12/18	16:58	370.86	285.97	347.32	404.63	332.4	
3/12/18	16:59	371.3	286.74	346.96	403.81	332.2	348.202 Average Surface Temp

General Average Report

Reporting Period: 03/12/2018 to 03/12/2018

Site Name: UNIT

Time of Report: 03/12/18 17:34

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	CO2 (%)	CAT_PRE (Deg_F)	CO (%)	CAT_POST (Deg_F)	O2 (%)	STK_CSA (Deg_F)	STK_TMP (Deg_F)
3/12/18	14:40	7.2	279.9	0	911	-999<	419.39	196.8
3/12/18	14:41	5.8	281.4	0.01	881.9	-999<	426.15	204.9
3/12/18	14:42	4.8	284.4	0.09	851.7	-999<	437.99	217.8
3/12/18	14:43	5.5	287.4	0.06	860.8	-999<	416.43	201
3/12/18	14:44	8.3	290.5	0.04	899	-999<	409.07	193.2
3/12/18	14:45	9.9	292.6	0.03	910.8	-999<	408.04	189.3
3/12/18	14:46	9.4	293.5	0.02	918.7	-999<	407.81	187.3
3/12/18	14:47	8.6	292.9	0	915.3	-999<	407.79	186
3/12/18	14:48	8.4	293.6	0	905.5	-999<	406.04	183.6
3/12/18	14:49	8.3	294.3	0.01	908.5	-999<	404.71	183.3
3/12/18	14:50	8.2	297.5	0.01	908.1	-999<	404.01	183.2
3/12/18	14:51	8.9	296.8	0.01	908.1	-999<	404.27	183.3
3/12/18	14:52	8.9	293.7	0.01	914.9	-999<	404.43	182.5
3/12/18	14:53	8.9	294.9	0.01	912.2	-999<	404.01	183.2
3/12/18	14:54	8.7	295	0.02	918.1	-999<	403.5	182
3/12/18	14:55	9	294.4	0.01	911.3	-999<	402.87	182
3/12/18	14:56	9.1	294.1	0.01	915	-999<	403.23	182.2
3/12/18	14:57	9.2	293.7	0.02	922.8	-999<	403.36	181.5
3/12/18	14:58	9.3	294.1	0.01	930	-999<	403.39	180.1
3/12/18	14:59	9.6	293.4	0	933.8	-999<	404	179
3/12/18	15:00	10	295.9	0	938.1	-999<	405.56	181.1
3/12/18	15:01	10.3	294.1	0	952.3	-999<	405.99	180.4
3/12/18	15:02	10.4	292.8	0	966.7	-999<	406.66	181.2
3/12/18	15:03	11	291.9	0	987	-999<	408.95	181.1
3/12/18	15:04	10.9	294.9	0	989.7	-999<	410.78	180.8
3/12/18	15:05	10.8	297	0	980.6	-999<	410.57	180.4
3/12/18	15:06	10.7	296.8	0	972.1	-999<	410.27	180.8
3/12/18	15:07	10.5	294.5	0	965.2	-999<	409.63	180.4
3/12/18	15:08	10.6	292.4	0	961.4	-999<	409.66	178.8
3/12/18	15:09	10.9	294.7	0	965.9	-999<	409.97	178.3
3/12/18	15:10	11.1	295.1	0	974.1	-999<	409.38	178.1
3/12/18	15:11	11.5	296.7	0	980.6	-999<	409.23	179.1
3/12/18	15:12	12	297.5	0	993.6	-999<	410.07	178.3
3/12/18	15:13	12.5	307.3	0	1007.6	-999<	410.42	178.6
3/12/18	15:14	12.9	307	0	1026.5	-999<	410.41	178.5
3/12/18	15:15	12.6	301.2	0	1029.7	-999<	411.2	180.5
3/12/18	15:16	12.5	299.1	0	1031.4	-999<	414.04	182.2
3/12/18	15:17	12.2	297.9	0	1027.5	-999<	416.47	181.7
3/12/18	15:18	11.4	297.8	0	1018.6	-999<	416.67	179
3/12/18	15:19	10.9	300.3	0	1007.1	-999<	415.35	177.7

3/12/18	15:20	10.6	304.2	0	996.6 -999<	413.99	179.4
3/12/18	15:21	10.3	304.6	0	989.5 -999<	413.37	179.4
3/12/18	15:22	9.6	302	0.02	969 -999<	411.43	179.2
3/12/18	15:23	9.1	301.4	0.01	946.8 -999<	407.95	180.3
3/12/18	15:24	8.7	302.6	0.03	936.8 -999<	404.83	179.8
3/12/18	15:25	8.4	307.8	0.03	930.8 -999<	402.84	178.6
3/12/18	15:26	8.3	307.8	0.03	922.4 -999<	400.48	176.8
3/12/18	15:27	8.3	309.5	0.03	916.8 -999<	397.13	175.5
3/12/18	15:28	8.3	308.9	0.04	912.4 -999<	395.56	176
3/12/18	15:29	8.2	307.6	0.05	909.4 -999<	394.05	175.6
3/12/18	15:30	8.2	309.8	0.06	909.4 -999<	393.11	173.9
3/12/18	15:31	8.3	312.5	0.05	905.8 -999<	391.54	174.2
3/12/18	15:32	8.5	312.2	0.06	904.2 -999<	390.11	174.2
3/12/18	15:33	8.6	313.5	0.05	904.8 -999<	390.04	174.8
3/12/18	15:34	8.7	312.3	0.05	904.2 -999<	390.15	175
3/12/18	15:35	8.9	312.4	0.06	904.8 -999<	388.98	173.5
3/12/18	15:36	9.1	318.6	0.06	904.8 -999<	388.22	173.4
3/12/18	15:37	8.7	325.2	0.09	900.2 -999<	387.81	176.4
3/12/18	15:38	8.3	324.5	0.1	903.4 -999<	387.5	177.5
3/12/18	15:39	7.9	326.4	0.1	902.7 -999<	386.69	179.5
3/12/18	15:40	7.7	326.5	0.1	893.5 -999<	386.09	180.9
3/12/18	15:41	7.6	327.9	0.1	885.8 -999<	384.38	179.3
3/12/18	15:42	7.4	329	0.1	878 -999<	382.94	178
3/12/18	15:43	7.3	329.8	0.11	870.5 -999<	381.91	178.3
3/12/18	15:44	7.2	331.2	0.11	864.1 -999<	379.91	178.9
3/12/18	15:45	7.2	330.6	0.11	856.8 -999<	379.25	179.9
3/12/18	15:46	7.1	331.8	0.12	850.6 -999<	378.72	180
3/12/18	15:47	7	331.9	0.12	844.6 -999<	377.77	179
3/12/18	15:48	7	332.8	0.13	838.1 -999<	375.75	177.8
3/12/18	15:49	6.9	333.5	0.13	833.2 -999<	373.4	175.7
3/12/18	15:50	6.9	333.7	0.13	829.2 -999<	371.48	175.2
3/12/18	15:51	6.9	334.8	0.13	826.3 -999<	370.66	176.8
3/12/18	15:52	6.9	334.3	0.13	823.8 -999<	369.56	177.1
3/12/18	15:53	6.9	334	0.13	820.9 -999<	368.59	177.2
3/12/18	15:54	6.9	335.8	0.13	818.4 -999<	367.67	175.2
3/12/18	15:55	6.8	336.6	0.13	813.8 -999<	366.48	175.5
3/12/18	15:56	6.7	337.8	0.13	808.6 -999<	365.36	175.7
3/12/18	15:57	6.7	336.5	0.12	804.2 -999<	363.7	175.8
3/12/18	15:58	6.6	336.4	0.12	801.1 -999<	362.37	174.6
3/12/18	15:59	6.7	336.3	0.12	799.9 -999<	362.39	173.4
3/12/18	16:00	6.6	337	0.11	798.2 -999<	362.69	173.7
3/12/18	16:01	6.6	336.6	0.11	794.8 -999<	361.85	174.2
3/12/18	16:02	6.6	336.7	0.11	792.3 -999<	361.09	174.6
3/12/18	16:03	6.6	337.6	0.1	789.4 -999<	360.16	174.4
3/12/18	16:04	6.6	337.7	0.1	786.4 -999<	359.09	174.3
3/12/18	16:05	6.6	337.6	0.1	784.7 -999<	357.57	174
3/12/18	16:06	6.5	336.9	0.09	784.6 -999<	357.04	173.7
3/12/18	16:07	6.6	336.9	0.09	782.1 -999<	357	173.3

3/12/18	16:08	6.5	336.1	0.09	779.3 -999<	357.15	172.7
3/12/18	16:09	6.6	336.4	0.08	775.2 -999<	355.6	170.6
3/12/18	16:10	6.6	335.9	0.08	772.5 -999<	354.25	170.7
3/12/18	16:11	6.6	335.9	0.08	770.9 -999<	353.34	170.8
3/12/18	16:12	6.6	336.1	0.08	769.9 -999<	353.09	171.2
3/12/18	16:13	6.6	337.3	0.08	768.7 -999<	352.39	169.7
3/12/18	16:14	6.9	338.7	0.06	768.6 -999<	350.56	169.1
3/12/18	16:15	7.1	337.7	0.05	775.2 -999<	350.25	169.9
3/12/18	16:16	7.1	337.1	0.05	780.6 -999<	350.51	170.2
3/12/18	16:17	6.8	337.3	0.06	780.4 -999<	351.2	170.6
3/12/18	16:18	6.4	338.1	0.05	774.5 -999<	350.68	170.5
3/12/18	16:19	6.3	338	0.05	767.9 -999<	349.59	170.1
3/12/18	16:20	6.3	337.5	0.04	764.2 -999<	348.61	169.3
3/12/18	16:21	6.2	337.5	0.04	760.1 -999<	346.92	165.9
3/12/18	16:22	6.2	338.8	0.05	756.3 -999<	345.4	166.1
3/12/18	16:23	6.1	337.9	0.04	752.7 -999<	343.93	165.8
3/12/18	16:24	6.1	336.5	0.04	750.2 -999<	342.98	167.1
3/12/18	16:25	6	336.6	0.04	747.2 -999<	342.4	167.8
3/12/18	16:26	6	336	0.04	744.2 -999<	342.03	167.6
3/12/18	16:27	6.1	336.4	0.04	742.4 -999<	341.04	167.4
3/12/18	16:28	6.2	338.1	0.03	741.9 -999<	339.29	166.2
3/12/18	16:29	6.2	337.2	0.03	741.5 -999<	338.63	164.3
3/12/18	16:30	6.1	337.9	0.03	739.7 -999<	338.7	164.9
3/12/18	16:31	5.9	337.8	0.02	737.1 -999<	337.57	165.6
3/12/18	16:32	5.6	337.8	0.02	730.7 -999<	337.16	166.4
3/12/18	16:33	5.4	337.1	0.02	723.8 -999<	335.94	165.7
3/12/18	16:34	5.4	335.4	0.02	719 -999<	335.12	164.9
3/12/18	16:35	5.3	336.4	0.01	715.6 -999<	333.35	165.2
3/12/18	16:36	5.3	336.8	0.01	713.4 -999<	332.25	165.2
3/12/18	16:37	5.3	335.6	0.01	710.4 -999<	331.6	165
3/12/18	16:38	5.3	336	0.01	706.7 -999<	330.85	165.1
3/12/18	16:39	5.3	336.1	0.01	703 -999<	329.82	164.3
3/12/18	16:40	5.3	335.6	0.01	701.1 -999<	328.25	163.6
3/12/18	16:41	5.3	335.6	0	698.1 -999<	327.39	164.1
3/12/18	16:42	5.3	335.8	0	695.8 -999<	326.99	164
3/12/18	16:43	5.3	335.2	0	693 -999<	326.04	163.3
3/12/18	16:44	5.3	333.8	0	690.5 -999<	324.93	161.5
3/12/18	16:45	4.7	333.3	0.01	683.3 -999<	323.69	160.7
3/12/18	16:46	4.5	333.3	0	674.7 -999<	322.39	161.3
3/12/18	16:47	4.5	333.9	0	670.2 -999<	321.53	161.8
3/12/18	16:48	4.5	334.4	0	667.5 -999<	319.79	161.5
3/12/18	16:49	4.5	334.1	0	665.9 -999<	317.82	160.3
3/12/18	16:50	4.5	333	0	663.1 -999<	317.25	160.4
3/12/18	16:51	4.5	333.2	0	661.5 -999<	317.89	160.5
3/12/18	16:52	4.4	333.5	0	659.7 -999<	317.03	160.8
3/12/18	16:53	4.3	332.9	0	656.7 -999<	315.98	161
3/12/18	16:54	4.3	332.8	0	654.8 -999<	315.25	160.1
3/12/18	16:55	4.4	332.7	0	653 -999<	314.89	159.3

3/12/18	16:56	4.4	332.2	0	651.2 -999<	314.53	158.7
3/12/18	16:57	4.3	332.6	0	649.5 -999<	313.64	158.1
3/12/18	16:58	4.4	332.4	0	646.8 -999<	312.4	156.5
3/12/18	16:59	4.4	332.2	0	644.9 -999<	312.16	156.1

General Average Report

Reporting Period: 03/12/2018 to 03/12/2018

Site Name: SAMPLE

Time of Report: 03/12/18 17:32

Preburn

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	Z (none)	COND2OUT (Deg_F)	DIL_CO2 (%)	DILRATIO (RATIO)	FILT1OUT (Deg_F)	FILT2OUT (Deg_F)	ROOM_TMI (Deg_F)	TUNL_TMP (Deg_F)	UNIT_WT (lbs)
3/12/18	13:04	1	64.3		0.698	66.2	68.1	64.6	67.1	1.66
3/12/18	13:05	1	64.3		-0.277	66.1	67.9	64.4	66.7	1.65
3/12/18	13:06	1	64.3		0.45	66	67.7	64.4	66.8	1.72
3/12/18	13:07	1	64.2		0.119	66	67.6	64.4	68	1.57
3/12/18	13:08	1	64.2		1.253	65.9	67.5	64.4	69.6	1.48
3/12/18	13:09	1	64.2		2.196	65.9	67.3	64.2	74.4	1.38
3/12/18	13:10	1	64.1		3.033	65.8	67.1	64.2	78	1.29
3/12/18	13:11	1	64.1		3.409	65.6	66.9	64.2	79.4	1.2
3/12/18	13:12	1	64		3.41	65.7	66.9	64.5	83.9	1.03
3/12/18	13:13	1	64		3.371	65.8	66.8	64.5	89.7	0.91
3/12/18	13:14	1	64		3.509	65.7	66.7	64.3	92	4.24
3/12/18	13:15	1	63.9		3.854	65.6	66.6	64.3	89.8	12.38
3/12/18	13:16	1	63.8		3.688	65.7	66.5	64.4	91.9	12.19
3/12/18	13:17	1	63.7		3.474	65.8	66.5	64.5	96.6	11.92
3/12/18	13:18	1	63.9		3.567	65.8	66.5	65.2	95.9	11.75
3/12/18	13:19	1	64		3.599	65.8	66.5	65.2	95.2	11.59
3/12/18	13:20	1	64		3.705	65.7	66.4	65.1	95.3	11.45
3/12/18	13:21	1	64		3.758	65.8	66.5	64.9	95.7	11.3
3/12/18	13:22	1	63.9		3.779	65.9	66.5	64.8	96.3	11.2
3/12/18	13:23	1	63.9		3.778	65.8	66.4	64.7	96	11.06
3/12/18	13:24	1	63.9		3.659	65.9	66.5	64.7	97	10.81
3/12/18	13:25	1	63.8		3.486	65.9	66.5	64.4	100.4	10.82
3/12/18	13:26	1	63.9		3.401	65.9	66.4	64.6	104.8	10.71
3/12/18	13:27	1	64		3.451	65.9	66.4	64.8	107	10.21
3/12/18	13:28	1	64		3.427	65.9	66.5	64.9	110	9.99
3/12/18	13:29	1	63.9		3.533	66	66.5	65	109.2	9.83
3/12/18	13:30	1	63.9		3.576	66.1	66.5	65.1	107.5	9.84
3/12/18	13:31	1	64		3.415	66.2	66.5	65	110.4	9.77
3/12/18	13:32	1	64		3.458	66.3	66.6	65.1	112	9.17
3/12/18	13:33	1	64		3.35	66.4	66.7	65.2	114.8	8.9
3/12/18	13:34	1	64		3.318	66.4	66.6	65.3	117	8.67
3/12/18	13:35	1	64.2		3.288	66.6	67	65.3	118.1	8.42
3/12/18	13:36	1	64.3		3.317	66.7	67	65.3	119.2	8.24
3/12/18	13:37	1	64.3		3.307	66.8	67	65.3	120.1	8.02
3/12/18	13:38	1	64.4		3.322	67.1	67.2	65.5	120.1	7.85
3/12/18	13:39	1	64.4		3.211	67	67.1	65.1	119.1	7.59
3/12/18	13:40	1	64.4		3.045	67	67.1	64.6	119.2	7.38
3/12/18	13:41	1	64.5		2.966	66.8	66.9	64.2	119.4	7.21
3/12/18	13:42	1	64.4		3.074	66.8	66.9	64.4	118.7	7.02
3/12/18	13:43	1	64.4		3.127	66.8	66.8	64.8	120.9	6.86
3/12/18	13:44	1	64.5		3.053	66.6	66.6	64.8	122.8	6.67
3/12/18	13:45	1	64.5		2.989	66.5	66.6	64.7	123.9	6.5
3/12/18	13:46	1	64.4		3.008	66.6	66.7	65	125.6	6.34
3/12/18	13:47	1	64.5		3.001	66.4	66.5	65.1	126.1	6.16
3/12/18	13:48	1	64.1		3.002	66.3	66.5	64.9	126.7	5.99
3/12/18	13:49	1	64.3		3.012	66.3	66.3	65.1	126.5	5.83
3/12/18	13:50	1	64.3		2.981	66.3	66.4	65.5	126.9	5.67
3/12/18	13:51	1	64.3		2.964	66.3	66.3	65.2	126.5	5.49

3/12/18	13:52	1	64.3	3	66.2	66.3	65	126	5.29
3/12/18	13:53	1	64.2	3.073	66.2	66.3	65.4	126.1	5.13
3/12/18	13:54	1	64.2	3.145	66.6	66.6	65.9	125	4.98
3/12/18	13:55	1	64.3	3.163	66.6	66.7	66.3	125.8	4.8
3/12/18	13:56	1	64.2	3.179	66.7	66.7	66.4	126.2	4.65
3/12/18	13:57	1	64.2	3.097	66.9	67	66.3	127.9	4.52
3/12/18	13:58	1	64.4	3.168	66.8	66.9	66.5	127	4.41
3/12/18	13:59	1	64.2	3.101	67	67.1	66.1	128.1	4.25
3/12/18	14:00	1	64.6	3.017	67.2	67.4	66.1	129.5	4.28
3/12/18	14:01	1	64.5	3.079	67.2	67.3	65.8	124.8	4
3/12/18	14:02	1	64.5	2.997	67.2	67.2	65.7	125	4.16
3/12/18	14:03	1	64.5	3.021	67.1	67.1	65.7	123.1	3.75
3/12/18	14:04	1	64.5	2.93	67	67	65.4	123.5	4.75
3/12/18	14:05	1	64.5	2.959	67.2	67.2	65.5	123.3	3.83
3/12/18	14:06	1	64.4	3.141	67.1	67	65.2	112.6	3.47
3/12/18	14:07	1	64.4	2.811	67.1	66.9	64.8	121	3.4
3/12/18	14:08	1	64.3	2.897	67	66.8	64.5	121.7	3.34
3/12/18	14:09	1	64.3	2.958	66.9	66.7	64.4	119.7	3.31
3/12/18	14:10	1	64.2	2.955	66.9	66.6	64.1	116.7	3.32
3/12/18	14:11	1	64.3	2.849	66.8	66.6	64.7	120.6	3.41
3/12/18	14:12	1	64.3	2.864	66.8	66.4	64.9	120.5	3.03
3/12/18	14:13	1	64.3	2.946	66.7	66.4	64.7	117.3	3.3
3/12/18	14:14	1	64.2	3.117	66.6	66.3	64.6	110.8	4.99
3/12/18	14:15	1	64.1	2.833	66.7	66.3	64.3	112.2	4.96
3/12/18	14:16	1	64	2.701	66.7	66.3	64.5	116.3	4.67
3/12/18	14:17	1	63.8	2.742	66.7	66.2	64.2	115.6	4.45
3/12/18	14:18	1	63.9	2.773	66.6	66.2	64.7	116.2	4.22
3/12/18	14:19	1	63.9	2.764	66.5	66	64.5	117	3.99
3/12/18	14:20	1	63.8	2.725	66.5	66	64.3	118.6	3.77
3/12/18	14:21	1	63.7	2.813	66.4	65.9	64.4	119.4	3.56
3/12/18	14:22	1	63.7	2.921	66.6	66.1	64.8	119.6	3.38
3/12/18	14:23	1	63.7	2.892	66.6	66.3	64.2	120.3	3.57
3/12/18	14:24	1	63.6	2.911	66.6	66.2	64.4	121.8	3.76
3/12/18	14:25	1	63.5	2.807	66.6	66.2	64.7	125.8	4.98
3/12/18	14:26	1	63.7	2.809	66.6	66.3	64.5	126.7	4.89
3/12/18	14:27	1	63.5	2.977	66.7	66.4	64.7	120.1	4.74
3/12/18	14:28	1	63.6	2.957	66.8	66.5	64.3	117	4.71
3/12/18	14:29	1	63.8	2.924	66.9	66.7	64.5	119	4.19
3/12/18	14:30	1	63.8	2.939	67	66.7	64.8	120.2	3.97
3/12/18	14:31	1	63.8	2.938	66.9	66.7	64.8	121.2	3.79
3/12/18	14:32	1	63.8	3.022	66.7	66.6	65.5	120.8	3.61
3/12/18	14:33	1	63.9	3.067	66.7	66.7	65.8	119.7	3.45
3/12/18	14:34	1	63.9	3.043	66.8	66.8	65.7	120.1	3.82
3/12/18	14:35	1	63.8	3.089	66.9	66.9	65.6	118.3	3.2
3/12/18	14:36	1	63.9	3.012	66.8	66.8	65.3	119.1	3.06
3/12/18	14:37	1	63.8	2.974	66.7	66.9	65.4	119.8	2.94
3/12/18	14:38	1	63.8	3.139	66.7	66.8	65.5	114.6	3.27
3/12/18	14:39	1	63.8	3.181	66.6	66.7	65.5	109.3	2.74
3/12/18	14:40	1	63.6	3.142	66.7	67.4	65.4	107.2	2.67

General Average Report

Reporting Period: 03/12/2018 to 03/12/2018

Preburn

Site Name: UNIT

Time of Report: 03/12/18 17:29

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	CAT_PRE (Deg_F)	CO (%)	CO2 (%)	STK_CSA (Deg_F)	STK_TMP (Deg_F)
3/12/18	13:04	63.4	-0.07	-0.2	66.32	65.4
3/12/18	13:05	63	-0.07	-0.2	65.99	65.2
3/12/18	13:06	63.1	-0.07	-0.2	65.73	65.2
3/12/18	13:07	63.3	-0.07	-0.1	66.15	65.4
3/12/18	13:08	62.9	-0.06	0	77.43	69.1
3/12/18	13:09	62.7	-0.07	0	116.89	86.2
3/12/18	13:10	63	-0.07	0	160.53	105.4
3/12/18	13:11	63.7	-0.07	0	180.87	115.4
3/12/18	13:12	64.9	-0.07	0	212.17	129.9
3/12/18	13:13	66.4	-0.07	0	258.98	149.3
3/12/18	13:14	67.9	-0.07	-0.1	277.22	161.4
3/12/18	13:15	70.1	-0.07	-0.1	263.88	162.5
3/12/18	13:16	72.7	-0.07	-0.1	277.86	165.6
3/12/18	13:17	75.7	-0.07	0	321.36	176.1
3/12/18	13:18	78.2	-0.08	-0.1	341.01	174.7
3/12/18	13:19	80.9	-0.08	-0.1	338.35	173.1
3/12/18	13:20	83.9	-0.08	-0.1	339.62	176.9
3/12/18	13:21	87.6	-0.08	-0.1	341.37	180.8
3/12/18	13:22	90.9	-0.08	-0.1	339.93	183.9
3/12/18	13:23	93.8	-0.09	-0.1	333.67	182.7
3/12/18	13:24	96.6	-0.09	-0.1	330.33	183
3/12/18	13:25	100.1	-0.09	0	344.64	189.8
3/12/18	13:26	103.2	-0.09	0	393.29	201.1
3/12/18	13:27	105.8	-0.09	0	420.4	210.3
3/12/18	13:28	108.2	-0.09	-0.1	434.1	219.5
3/12/18	13:29	110.5	-0.1	-0.1	429.89	221.1
3/12/18	13:30	113.3	-0.1	-0.1	426.85	216.5
3/12/18	13:31	116.5	-0.1	-0.1	426.97	219.9
3/12/18	13:32	119.5	-0.1	0	427.57	227.1
3/12/18	13:33	122.4	-0.1	0	443.71	231
3/12/18	13:34	125.9	-0.1	0	455.91	236.4
3/12/18	13:35	129.3	-0.11	0	458.88	238.8
3/12/18	13:36	132.5	-0.11	0	456.53	244
3/12/18	13:37	136.1	-0.11	0	452.83	246.6
3/12/18	13:38	139.1	-0.11	0	450.96	246.9
3/12/18	13:39	138.7	-0.12	0	452.65	238.7
3/12/18	13:40	140.7	-0.12	0	453.79	230.7
3/12/18	13:41	145.2	-0.12	0	453.81	227.9
3/12/18	13:42	149	-0.12	0	453.61	231.3
3/12/18	13:43	152.1	-0.13	0	452.18	240.2

3/12/18	13:44	155.7	-0.13	0	452.89	241.8
3/12/18	13:45	160.1	-0.1	2.5	454.84	241.5
3/12/18	13:46	163.6	-0.05	6.8	455.25	247.5
3/12/18	13:47	166.9	-0.04	7	456.41	248.2
3/12/18	13:48	169.6	-0.05	6.9	455.86	250.4
3/12/18	13:49	172.2	-0.05	7.1	455.18	250.1
3/12/18	13:50	175.2	-0.06	7.5	455.57	248.5
3/12/18	13:51	178.3	-0.08	7.9	457.67	246.8
3/12/18	13:52	184.1	-0.09	8.4	458.42	248
3/12/18	13:53	188.9	-0.1	8.4	459.96	252
3/12/18	13:54	191.8	-0.11	8	461.13	251.9
3/12/18	13:55	195.8	-0.11	7.6	462.22	254.6
3/12/18	13:56	199.3	-0.1	6.9	462.55	256.6
3/12/18	13:57	202.4	-0.09	6.2	458.98	257.2
3/12/18	13:58	206.2	-0.08	6	456.3	257.9
3/12/18	13:59	208.7	-0.07	5.7	455.85	258.3
3/12/18	14:00	207	-0.08	4.8	453.04	257.4
3/12/18	14:01	209	-0.12	6.1	440.93	247.5
3/12/18	14:02	212.2	-0.12	5	440.29	243.2
3/12/18	14:03	214.8	-0.13	5.7	436.9	239
3/12/18	14:04	218	-0.13	4.8	436.51	235.4
3/12/18	14:05	220	-0.1	3.6	427.22	236.2
3/12/18	14:06	221.4	-0.12	3.4	402.47	213.9
3/12/18	14:07	223.1	-0.18	0	410.98	222.5
3/12/18	14:08	226	-0.13	0	408.04	230
3/12/18	14:09	227.8	0	-0.2	401.66	227.7
3/12/18	14:10	229.9	-0.01	-0.1	395.21	219.3
3/12/18	14:11	232	0.24	5.8	395.5	223.7
3/12/18	14:12	234.5	0.65	10.8	393.02	224.1
3/12/18	14:13	234	0.34	7.9	388.67	219.7
3/12/18	14:14	236.5	0.28	2.9	369.68	207.7
3/12/18	14:15	237.5	0.07	3.4	368.53	199.1
3/12/18	14:16	238	0.08	7.1	385.81	204.4
3/12/18	14:17	239	0.04	11.8	415.73	205
3/12/18	14:18	238.6	0.04	13.3	443.09	207.5
3/12/18	14:19	238.8	0.22	12.5	460.39	209.5
3/12/18	14:20	239	0.48	10.8	473.39	212.3
3/12/18	14:21	240.4	0.18	11.4	482.01	219
3/12/18	14:22	240.6	0	10.5	484.17	224.9
3/12/18	14:23	239.7	0	9.2	480.91	226.4
3/12/18	14:24	241.7	0.02	8.3	477.67	231.3
3/12/18	14:25	245.3	0.04	6.7	480.94	236.1
3/12/18	14:26	245.9	0.05	8.3	478.18	239.2
3/12/18	14:27	249	0.08	12	473.03	229.2
3/12/18	14:28	252.4	0.08	12.7	469.6	220
3/12/18	14:29	254.4	0.15	13.2	483.64	224.1
3/12/18	14:30	256.7	0.03	11.6	492.73	227.7
3/12/18	14:31	260.9	0.01	10.9	496.42	230.5

3/12/18	14:32	271.6	0.07	10.5	497.02	232.5
3/12/18	14:33	271.4	-0.01	9.1	495.2	231
3/12/18	14:34	267.5	-0.01	8.5	491.24	231.1
3/12/18	14:35	267.9	-0.01	8.1	482.19	228.7
3/12/18	14:36	270.3	-0.02	7.6	479.47	227.4
3/12/18	14:37	270.9	-0.02	7.8	480.34	227.1
3/12/18	14:38	274.3	-0.02	8.3	463.98	219.4
3/12/18	14:39	277.1	-0.01	8.2	435.43	205
3/12/18	14:40	279.9	-0.01	7.2	419.39	196.8

General Average Report

Reporting Period: 03/12/2018 to 03/12/2018

Preburn

Site Name: UNIT

Time of Report: 03/12/18 17:30

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	CAT_PRE (Deg_F)	TEMP_10 (Deg_F)	TEMP_11 (Deg_F)	TEMP_12 (Deg_F)	TEMP_13 (Deg_F)
3/12/18	13:04	63.4	64.3	63	64.97	63.91
3/12/18	13:05	63	64.36	63.15	64.73	64.01
3/12/18	13:06	63.1	64.69	63.44	64.48	64.45
3/12/18	13:07	63.3	64.56	63.17	64.72	64.12
3/12/18	13:08	62.9	64.19	63.29	64.55	64.5
3/12/18	13:09	62.7	64.27	63.39	64.42	67.08
3/12/18	13:10	63	64.54	63.66	64.89	72.88
3/12/18	13:11	63.7	64.64	63.4	65.56	80.38
3/12/18	13:12	64.9	64.31	63.33	66.53	88.97
3/12/18	13:13	66.4	64.31	63.66	67.57	100.54
3/12/18	13:14	67.9	64.52	64.2	68.93	115.77
3/12/18	13:15	70.1	65.04	64.48	70.9	130.77
3/12/18	13:16	72.7	65.12	64.51	72.95	144.66
3/12/18	13:17	75.7	65.41	65.06	74.49	161.6
3/12/18	13:18	78.2	66.02	66.1	76.74	185.65
3/12/18	13:19	80.9	67.1	66.96	79.63	213.08
3/12/18	13:20	83.9	67.82	67.3	82.96	236.46
3/12/18	13:21	87.6	68.45	68.34	85.7	255.12
3/12/18	13:22	90.9	69.45	69.76	88.66	269.51
3/12/18	13:23	93.8	70.81	70.93	91.64	278.16
3/12/18	13:24	96.6	72.16	71.5	94.66	285.33
3/12/18	13:25	100.1	73.1	72.72	97.14	293.32
3/12/18	13:26	103.2	74.52	74.29	99.24	301.48
3/12/18	13:27	105.8	76.56	76.11	102.04	318.94
3/12/18	13:28	108.2	78.77	77.32	105.45	342.39
3/12/18	13:29	110.5	80.24	78.75	108.41	364.29
3/12/18	13:30	113.3	81.84	80.05	111.31	380.21
3/12/18	13:31	116.5	83.81	81.67	114.51	397.51
3/12/18	13:32	119.5	86.16	82.65	117.48	409.93
3/12/18	13:33	122.4	88.68	84.45	120.52	418.69
3/12/18	13:34	125.9	90.63	86.66	123.42	429.47
3/12/18	13:35	129.3	92.99	89.03	126.72	443.88
3/12/18	13:36	132.5	95.83	90.73	130.77	457.61
3/12/18	13:37	136.1	98.38	92.05	134.28	465.08
3/12/18	13:38	139.1	100.92	94.4	137.25	469.4
3/12/18	13:39	138.7	102.83	97.16	139.38	458.71
3/12/18	13:40	140.7	105.45	99.62	143.56	457.46
3/12/18	13:41	145.2	108.49	101.81	148.18	457.65
3/12/18	13:42	149	110.33	103.88	150.57	458.14
3/12/18	13:43	152.1	112.64	106.39	154.54	461.11

3/12/18	13:44	155.7	115.82	108.42	159.39	462.99
3/12/18	13:45	160.1	119.19	110.37	163.01	456.95
3/12/18	13:46	163.6	122.19	112.34	166.61	459.67
3/12/18	13:47	166.9	124.98	115.26	169.61	461.33
3/12/18	13:48	169.6	127.96	117.65	171.94	460.62
3/12/18	13:49	172.2	131.53	119.52	176.37	460.1
3/12/18	13:50	175.2	134.83	122	179.97	459.85
3/12/18	13:51	178.3	137.95	124.31	184.08	462.84
3/12/18	13:52	184.1	142.25	126.07	190.89	470.86
3/12/18	13:53	188.9	146.11	127.93	196.81	474.08
3/12/18	13:54	191.8	150.28	130.34	200.71	477.74
3/12/18	13:55	195.8	153.87	132.82	204.79	484.83
3/12/18	13:56	199.3	157.51	135.98	208.78	490.1
3/12/18	13:57	202.4	161.5	137.89	213.34	493.28
3/12/18	13:58	206.2	165.72	140.24	217.52	493.41
3/12/18	13:59	208.7	169.08	143.36	219.81	487.92
3/12/18	14:00	207	170.15	144.93	221.03	481.64
3/12/18	14:01	209	172.48	149.02	222.78	473.13
3/12/18	14:02	212.2	176.01	150.79	225.58	465.96
3/12/18	14:03	214.8	178	153.43	227.84	464.38
3/12/18	14:04	218	181.52	155.63	231.52	464.34
3/12/18	14:05	220	186.41	155.74	236.64	465.58
3/12/18	14:06	221.4	189.63	159.68	238.66	462.36
3/12/18	14:07	223.1	194.13	163.6	240.52	457.99
3/12/18	14:08	226	198.69	168.29	242.94	454.56
3/12/18	14:09	227.8	201.47	170.65	245.13	442.99
3/12/18	14:10	229.9	204.55	170.2	247.83	436.01
3/12/18	14:11	232	208.85	171.23	250.17	434.06
3/12/18	14:12	234.5	210.79	173.63	251.29	427.96
3/12/18	14:13	234	212.68	178.57	252.92	418.05
3/12/18	14:14	236.5	216.08	180.43	253.6	411.73
3/12/18	14:15	237.5	219.58	181.53	253.84	403.87
3/12/18	14:16	238	222.21	183.87	254.54	397.05
3/12/18	14:17	239	224	187.37	256.04	394.46
3/12/18	14:18	238.6	225.12	189.33	256.23	402.11
3/12/18	14:19	238.8	225.55	189.6	254.63	412.46
3/12/18	14:20	239	228.16	192.49	254.46	432.25
3/12/18	14:21	240.4	232.25	193.48	256.24	462.21
3/12/18	14:22	240.6	231.35	197.1	255.02	476.15
3/12/18	14:23	239.7	232.72	198.62	254.48	490.62
3/12/18	14:24	241.7	238.33	197.64	257.87	504.92
3/12/18	14:25	245.3	241.82	199.5	258.53	514.45
3/12/18	14:26	245.9	245.24	203.1	259.43	516.28
3/12/18	14:27	249	246.55	205.31	261.66	518.31
3/12/18	14:28	252.4	249.28	205.87	263.73	518.57
3/12/18	14:29	254.4	253.95	206.68	268.63	529.64
3/12/18	14:30	256.7	254.42	208.93	270.42	538.76
3/12/18	14:31	260.9	254.92	210.58	271.86	550.69

3/12/18	14:32	271.6	260.88	210.18	282.07	573.78
3/12/18	14:33	271.4	260.59	214.31	282.03	576.16
3/12/18	14:34	267.5	256.87	214.5	278.13	572.21
3/12/18	14:35	267.9	258.44	213.81	281.03	577.29
3/12/18	14:36	270.3	261.22	216.46	284.67	577.14
3/12/18	14:37	270.9	261.19	216.89	287.41	574.42
3/12/18	14:38	274.3	263.46	215.71	290.06	568.35
3/12/18	14:39	277.1	265.82	216.98	292.2	570.21
3/12/18	14:40	279.9	267.49	218.62	293.83	567.21


CSL-00010

Appendix D



Kelvin Notes from MF FIRE Testing CSL-00010 V1

Date:	Time:	Comment:	Picture:
Test #1			
3.5.18	9:55	"preburn fuel 11.28 lbs"	
3.5.18	10:13	"1.44 lbs kindling added"	
3.5.18	10:19	"added preburn fuel. 11.28 lbs. Scale weight was 11.82 lbs."	


3.5.18	10:44	"test fuel crib ready 11.72 lbs"	
3.5.18	10:47	"opened stove door, poked coals"	
3.5.18	10:55	"poked coals"	
3.5.18	11:03	"poked fuel"	
3.5.18	11:05	"added 1.76 lbs"	
3.5.18	11:15	"removed 2.9 lbs"	
3.5.18	11:16	"added 1.3 lbs"	
3.5.18	11:18	"poked coals"	
3.5.18	11:21	"added 1.42 lbs"	
3.5.18	11:25	"added 1.66 lbs"	
3.5.18	11:30	"poked coals"	
3.5.18	11:33	"poked coals"	
3.5.18	11:37	"coal bed status"	
3.5.18	11:41	"Start time 11:41 am"	
3.5.18	11:42	"14.20 lbs"	
3.5.18	11:42	"2.6 coal bed"	
3.5.18	11:44	"Start Pic"	
3.5.18	11:56	"Closed door during start at 55 sec"	
3.5.18	14:19	"Stop time 14:19"	
Test #2			

3.6.18	9:20	"preburn fuel 11.52 lbs"	
3.6.18	10:16	"1.46 lbs of kindling and paper"	
3.6.18	10:30	"lighting kindling"	
3.6.18	10:39	"added preburn fuel"	

3.6.18	10:40	"test fuel 11.98 lbs"	
3.6.18	11:18	"poked coals"	
3.6.18	11:22	"added 2.96 lbs to preburn"	
3.6.18	11:23	"Removed 4.12 lbs"	
3.6.18	11:24	"added 1.8 lbs"	
3.6.18	11:31	"poked coals"	
3.6.18	11:36	"added 2.06 lbs"	
3.6.18	11:38	"poked coals"	
3.6.18	11:49	"test start"	
3.6.18	11:49	"Test Start 11:49"	
3.6.18	14:32	"test end"	
Test # 3			

3.12.18	10:55	"preburn fuel"	 <p>The screenshot shows a mobile application interface with a green header bar containing a back arrow and the text "Comment Details". Below the header is a photograph of a stack of light-colored wooden planks, likely pine, stacked on a concrete floor. The planks are arranged in a neat stack, with some showing their end grain.</p>
3.12.18	12:17	"test fuel"	 <p>The screenshot shows a mobile application interface with a green header bar containing a back arrow and the text "Comment Details". Below the header is a photograph of a stack of light-colored wooden planks, similar to the first image, but they are resting on a wooden workbench. The background shows a workshop environment with various tools and equipment.</p>

3.12.18	13:04	"1.60 kindling and paper"	
3.12.18	13:06	"lighting kindling"	
3.12.18	13:15	"added 11.66 lbs preburn fuel"	
3.12.18	13:25	"repositioned fuel"	

3.12.18	13:26	"secondary air is noticeably better, working"	
3.12.18	13:32	"poked fuel"	
3.12.18	13:37	"poked fuel"	
3.12.18	14:01	"poked fuel"	
3.12.18	14:07	"poked fuel"	
3.12.18	14:14	"Removed 0.4 lbs bad coals, added 2.42 lbs preburn"	
3.12.18	14:25	"added 2.06 lbs to preburn"	
3.12.18	14:39	"coal bed pre-raked"	
3.12.18	14:43	"ignore o2. O2 will be derived from"	
3.12.18	16:03	"Test start 2:40 pm"	
3.12.18	17:25	"Test ended 14:19"	
3.12.18	17:28	"Incorrect. Test ended at 4:59 pm"	

CSL-00010

Appendix E



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
RESEARCH TRIANGLE PARK, NC 27711

Ms. Kelli O'Brien
Lab Manager
ClearStak
99 Canal Street
Putnum, CT 06260

MAR 06 2018

OFFICE OF
AIR QUALITY PLANNING
AND STANDARDS

Dear Ms. O'Brien,

I am writing in response to your letter dated March 4, 2018, regarding certification testing of the Nova model wood stove, a prototype single burn rate wood stove manufactured by MF Fire. You are requesting to use alternative test procedures for recovery and preparation of the particulate matter (PM) samples from the front half filter and probe assembly. In particular, you propose use of the acetone probe rinse and filter sample recovery and preparation procedures described in sections 8.7 and 11.0 of Method 5, Determination of Particulate Matter Emissions from Stationary Sources (40 CFR 60, Appendix A), in lieu of the procedures in section 10.2.2 of ASTM E2515-11, Standard Test Method for Determination of Particulate Matter Emissions Collected by a Dilution Tunnel which is required under 40 CFR 60, Subparts AAA and QQQQ.

The difference between the sample recovery and preparation procedures of Method 5 and ASTM E2515-11 is that Method 5 determines PM in the probe and filter assembly by (1) collecting PM in the probe through acetone rinses of the probe, drying down the rinse in beakers, dessication, followed by weighing and (2) removal of the filter, dessicating, and then weighing, as opposed to ASTM E2515-11 where the entire 100+ gram probe assembly is weighed before and after a test run. We understand that ClearStak typically performs gravimetric analysis of their PM samples (acetone rinses and filters) at an offsite location and not in the wood heater emission testing laboratory to ensure quality low mass (e.g., milligram) measurements uninfluenced by ground vibrations caused by daily operations of testing facilities.

You state that through past experience, you have found that probe PM collected through acetone rinses which are then transported in sample jars offer far less possible sample contamination than handling the front half probe and filter assembly. You propose to collect the acetone rinses after testing according to section 8.7 of Method 5, transport them to your laboratory, then transfer the rinses from the jars to clean and desiccated pre-weighed 100 mL beakers where they are dried down and desiccated according to section 11.2.2 of Method 5, and finally weighed according ASTM E2515-11 in 6-hour intervals until two consecutive weights are achieved within 0.2mg. Likewise, the filters (which were pre-weighed before testing as required in section 8.1.3 of Method 5) are recovered according to section 8.7 of Method 5, transported to the laboratory, dessicated according to section 11.2.1 of Method 5, and weighed according ASTM E2515-11.

We understand ClearStak is requesting to use these alternative procedures for PM recovery, dry down, and desiccation of the front half probe and filter assembly samples for ASTM E2515-11 testing of MF Fire's prototype single burn rate stove, Nova, and for all future ASTM E2515-11 emissions testing of residential wood heaters, hydronic heaters, and forced-air furnaces per 40 CFR Part 60 Subparts AAA and QQQQ.

With this letter, we are approving your alternative test procedures detailed above in conjunction with ASTM E2515-11 for certification testing of the MF Fire's prototype single burn rate stove, Nova, as well as all wood heaters, hydronic heaters, and forced-air furnaces subject to 40 CFR Part 60 Subpart AAA and QQQQ. A copy of this letter must be included in each certification test report where this alternative test method is utilized.

It is reasonable that this alternative test method approval be broadly applicable to certification testing of all wood heaters, hydronic heaters, and forced-air furnaces subject to the requirements of 40 CFR part 60, Subparts AAA and QQQQ. For this reason, we will post this letter as ALT-126 on our website at <http://www3.epa.gov/ttn/emc/approalt.html> for use by other interested parties. This alternative method approval is valid until such time that Subparts AAA and QQQQ are revised or replaced to require a different certification method, and at such time, this alternative will be reconsidered and possibly withdrawn.

If you have additional questions regarding this approval, please contact Michael Toney of my staff at 919-541-5247 or toney.mike@epa.gov.

Sincerely,



Steffan M. Johnson, Group Leader
Measurement Technology Group

cc: Amanda Aldridge, EPA/OAQPS/OID
Adam Baumgart-Getz, EPA/OAQPS/OID
Rafael Sanchez, EPA/OECA
Michael Toney, EPA/OAQPS/AQAD

CSL-00010

Appendix F



SCOPE OF ACCREDITATION TO ISO/IEC 17025:2005

CLEARSTAK, LLC¹
 99 Canal Street
 PO BOX 109
 Putnam, Connecticut 06260
 Ms. Kelli O'Brien Phone: 860-237-8245
 e-mail: kelli@clearstak.com

CHEMICAL

Valid To: February 28, 2019

Certificate Number: 3968.01

In recognition of the successful completion of the A2LA evaluation process, accreditation is granted to this laboratory at the location listed above as well as the one satellite laboratory location listed below to perform the following tests on wood heaters:

<u>Test Description</u>	<u>Test Method(s)</u>
Particulate Emissions and Efficiency	EPA Method 28 EPA Method 28 WHH EPA Method 28 WHH PTS ASTM E2618 ASTM E2779 ASTM E2780
Carbon Monoxide, Carbon Dioxide and Oxygen	CSA B415
Standard Test Method for Determination of Particulate Matter Emissions Collected by a Dilution Tunnel	ASTM E2515
Determination of Particulate Matter from Stationary Sources – Sample Recovery	EPA Method 5 section 8.7

¹ This accreditation covers testing performed at the main laboratory listed above, and at the satellite laboratories indicated below.

CLEARSTAK, LLC
479 Tolland Turnpike
Willington, CT 06279

Test Description

Test Method(s)

Standard Test Method for Determination of Particulate Matter Emissions Collected by a Dilution Tunnel

ASTM E2515

Determination of Particulate Matter from Stationary Sources – Sample Recovery

EPA Method 5 section 8.7

A handwritten signature in black ink, appearing to be 'L. S. L.', is located in the bottom right area of the page.



Accredited Laboratory

A2LA has accredited

CLEARSTAK, LLC
Putnam, CT

for technical competence in the field of

Chemical Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005 General requirements for the competence of testing and calibration laboratories. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated 8 January 2009).



Presented this 21st day of March 2017.

A handwritten signature in black ink, appearing to read 'L. ...', positioned above a horizontal line.

President and CEO
For the Accreditation Council
Certificate Number 3968.01
Valid to February 28, 2019